

FORT MYERS HARBOR, FL, USA

WMO: 997346

Lat: 26.6471N

Lon: 81.8709W

Elev: 20

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	44.0	47.8	N/A	N/A	N/A	N/A	N/A	N/A	23.4	61.4	18.9	60.2	8.3	20	0.322

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.8	92.0	N/A	90.7	N/A	89.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.3	280

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
17.7	14.8	12.6	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	75.2	64.1	67.6	69.7	74.6	78.5	81.6	82.9	83.5	81.9	78.6	70.9	67.9
	DBStd	8.12	7.45	7.07	5.45	3.71	2.70	2.40	2.05	1.81	2.06	4.38	5.73	6.91
	HDD50	8	6	1	0	0	0	0	0	0	0	0	0	1
	HDD65	262	108	54	25	1	0	0	0	0	0	2	18	54
	CDD50	9196	442	494	609	739	883	948	1019	1037	956	886	626	557
	CDD65	3974	78	127	169	290	418	498	554	572	506	423	194	145
	CDH74	34512	262	549	818	1977	3560	5063	5893	6326	4876	3618	960	610
	CDH80	11100	15	50	74	402	1076	1885	2260	2461	1641	1030	142	64
Wind	WSAvg	6.1	6.7	6.2	7.3	6.4	6.3	5.7	4.9	5.1	5.6	6.5	6.7	6.1
Precipitation	PrecAvg	54.7	2.0	2.1	2.8	1.7	3.4	9.8	8.8	9.8	8.3	2.9	1.8	1.6
	PrecMax	74.8	8.0	10.8	18.6	5.7	10.3	20.1	14.5	16.8	17.2	11.0	8.1	5.2
	PrecMin	32.8	0.0	0.0	0.0	0.0	0.2	2.0	2.3	4.0	1.9	0.0	0.0	0.0
	PrecStd	10.0	1.9	1.8	3.1	1.5	2.5	4.3	3.1	3.5	3.7	2.6	1.9	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.0	84.1	84.3	87.5	90.8	93.0	93.4	93.6	91.7	89.8	87.1	84.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	79.3	81.5	82.1	85.7	88.7	90.8	91.4	92.0	90.1	88.2	84.1	81.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	77.2	79.6	80.4	84.2	87.0	89.3	90.2	90.5	88.9	86.9	81.6	79.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	74.7	77.7	78.7	82.5	85.4	87.9	88.8	89.1	87.4	85.5	79.6	77.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	16.1	15.6	15.9	14.9	14.3	13.0	12.9	12.8	12.3	12.3	14.7	15.2
		MCDBR	16.5	15.5	16.3	16.2	16.3	14.9	14.5	14.2	13.4	12.9	14.6	15.2
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.349	0.364	0.377	0.392	0.419	0.444	0.460	0.449	0.421	0.400	0.362	0.353	
	taud	2.513	2.481	2.430	2.368	2.346	2.353	2.300	2.360	2.419	2.447	2.495	2.528	
	Ebn at Noon	286	290	291	288	278	269	265	268	273	274	279	279	
	Edh at Noon	30	33	36	39	40	40	42	39	36	33	30	28	
All-Sky Solar Radiation	RadAvg	1176	1437	1750	2036	2095	1885	1848	1787	1612	1503	1268	1085	
	RadStd	83	85	113	86	140	166	122	90	100	86	67	76	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (34 neighbors)	+0.74	+1.57	N/A	N/A	N/A	N/A	-2	-45	+263	+200

Nomenclature: See separate page