

FERNANDINA BEACH, FL, USA

WMO: 997347

Lat: 30.6753N

Lon: 81.4651W

Elev: 7

StdP: 101.24

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 1.5	(c) 3.7	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 10.7	(k) 12.3	(l) 9.3	(m) 10.9	(n) 4.9	(o) 330	(p) 0.368

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 5.8	(c) 33.7	(d) N/A	(e) 32.5	(f) N/A	(g) 31.5	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 2.6	(p) 130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 9.0	(b) 7.8	(c) 6.9	(e) DB	(f) -1.1	(g) 35.2	(h) 2.4	(i) 1.8	(j) -2.8	(k) 36.5	(l) -4.2	(m) 37.5	(n) -5.6	(o) 38.5	(p) -7.3	(q) 39.8	(r) N/A
			(e) WB	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A	(q) N/A	(r) N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	21.1	12.2	14.4	16.7	20.5	24.2	27.1	28.0	28.3	26.8	22.9	17.2	15.2
	DBStd	6.50	4.87	4.52	3.93	2.97	2.40	1.57	1.35	1.51	2.02	3.49	3.86	4.53
	HDD10.0	61	34	12	4	0	0	0	0	0	0	0	2	9
	HDD18.3	598	196	122	78	14	0	0	0	0	0	7	63	117
	CDD10.0	4128	102	135	211	313	439	512	558	567	505	399	219	169
	CDD18.3	1623	6	12	26	78	181	262	299	308	255	148	30	18
	CDH23.3	14115	5	27	54	270	1126	2498	3188	3414	2499	932	68	32
	CDH26.7	4180	0	1	2	28	223	739	1086	1228	704	163	3	2
(14) Wind	WSAvg	3.1	3.3	3.1	3.4	3.4	3.1	3.0	2.9	2.6	2.9	3.1	3.4	3.3
(15) Precipitation	PrecAvg	1315	87	92	100	69	75	143	153	157	193	109	59	74
	PrecMax	1914	238	256	255	226	214	283	339	510	605	350	137	313
	PrecMin	818	6	19	3	6	2	32	36	55	17	4	0	1
	PrecStd	250	57	56	64	45	53	67	69	88	121	92	40	62
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.1	25.8	27.0	29.2	33.5	34.4	35.0	35.1	34.9	31.9	27.0	26.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	22.1	24.0	24.8	27.4	30.5	32.6	33.0	33.5	32.0	29.7	25.2	24.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	20.5	22.0	23.5	26.1	28.9	31.3	31.9	32.1	30.7	28.3	24.0	22.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	19.2	20.5	22.1	24.9	27.7	30.2	30.8	31.1	29.9	27.3	22.8	21.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(35) Mean Daily Temperature Range	MDBR		7.4	7.4	7.2	6.8	6.0	6.1	6.1	5.8	4.8	5.7	6.5	7.0
	5% DB	MCDBR	8.1	8.5	8.2	8.0	8.0	7.9	7.5	7.3	6.1	5.9	7.1	7.4
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(40) Clear-Sky Solar Irradiance	taub		0.338	0.348	0.373	0.399	0.440	0.486	0.510	0.495	0.429	0.401	0.360	0.348
	taud		2.533	2.510	2.455	2.372	2.291	2.221	2.160	2.209	2.389	2.431	2.498	2.532
	Ebn at Noon		893	916	912	895	855	812	790	800	845	846	859	863
	Edh at Noon		87	97	109	123	134	143	152	143	115	103	89	83
(44) All-Sky Solar Radiation	RadAvg		3.07	3.69	4.84	5.96	6.42	6.06	6.05	5.58	4.75	4.18	3.36	2.75
	RadStd		0.21	0.42	0.45	0.36	0.37	0.40	0.38	0.35	0.40	0.37	0.20	0.23

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (29 neighbors)	+0.45	+0.76	N/A	N/A	N/A	N/A	-16	-68	+160	+114

Nomenclature: See separate page