

KEY WEST HARBOR, FL, USA

WMO: 997348

Lat: 24.5558N

Lon: 81.8078W

Elev: 23

StdP: 14.68

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 55.6	(c) 58.5	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 25.8	(k) 64.1	(l) 23.8	(m) 64.6	(n) 7.7	(o) 10	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 9.2	(c) 92.2	(d) N/A	(e) 91.3	(f) N/A	(g) 90.6	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 1.2	(p) 160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 17.9	(b) 14.5	(c) 11.8	(e) 51.4	(f) 93.3	(g) 3.7	(h) 0.6	(i) 48.7	(j) 93.8	(k) 46.5	(l) 94.1	(m) 44.4	(n) 94.4	(o) 41.7	(p) 94.9		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	78.8	70.3	71.6	73.9	78.0	81.2	84.3	85.6	85.9	84.2	81.5	75.3	73.3		
	DBStd	6.74	5.92	5.88	4.86	3.38	2.56	2.44	2.03	1.91	2.16	3.00	4.38	5.36		
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD65	57	25	16	6	0	0	0	0	0	0	0	1	9		
	CDD50	10514	628	606	741	840	969	1030	1104	1113	1025	976	759	723		
	CDD65	5096	188	202	282	390	504	580	639	648	575	511	310	267		
	CDH74	51178	613	893	1411	3021	5213	7296	8485	8737	7178	5375	1725	1231		
	CDH80	18779	29	79	145	614	1500	3116	4089	4323	2994	1548	227	115		
(14) Wind	WSAvg	2.9	5.6	4.0	3.3	4.0	2.0	1.6	1.6	1.7	2.0	3.1	2.9	3.5		
(15) Precipitation	PrecAvg	40.0	2.0	1.6	1.7	1.9	3.4	4.9	3.5	5.4	6.2	4.8	2.4	2.0		
	PrecMax	62.9	17.6	4.9	9.7	10.6	12.9	14.4	11.7	13.5	18.5	21.6	27.7	11.2		
	PrecMin	20.0	0.0	0.1	0.0	0.0	0.6	0.3	0.4	2.2	1.7	0.7	0.0	0.0		
	PrecStd	9.3	3.0	1.2	1.7	1.9	2.8	3.5	2.2	2.7	3.0	3.9	4.2	2.0		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.5	84.1	84.5	87.3	89.5	92.5	93.2	93.2	92.2	90.1	87.2	84.3		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	81.0	82.3	83.0	86.0	88.4	91.3	92.1	92.2	91.0	88.6	84.5	82.9		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	79.5	80.8	81.8	84.9	87.3	90.3	91.2	91.3	89.7	87.2	82.7	81.6		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	77.6	79.1	80.3	83.7	86.2	89.1	90.2	90.4	88.6	85.9	81.2	79.7		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.3	8.6	8.6	8.5	8.5	8.8	9.2	9.2	8.9	7.5	7.2	7.6		
		MCDBR	9.2	9.2	9.4	9.4	9.6	10.0	9.7	10.0	9.9	8.9	8.7	8.3		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.363	0.376	0.383	0.400	0.424	0.439	0.450	0.433	0.417	0.409	0.377	0.371		
	taud		2.549	2.515	2.476	2.407	2.394	2.421	2.394	2.463	2.478	2.485	2.522	2.549		
	Ebn at Noon		285	288	291	286	277	271	268	273	276	274	278	277		
	Edh at Noon		29	32	35	38	39	37	38	36	35	33	30	28		
(44) All-Sky Solar Radiation	RadAvg		1234	1543	1899	2143	2171	2016	2055	1951	1713	1538	1336	1173		
	RadStd		97	113	83	91	185	159	98	70	92	103	73	102		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (16 neighbors)		+0.61	+1.51	N/A	N/A	N/A	N/A	N/A	-27	+196	+162

Nomenclature: See separate page