

CAPE CANAVERAL TRIDENT PIER, FL, USA

WMO: 997354

Lat: 28.4160N

Lon: 80.5930W

Elev: 10

StdP: 101.20

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 6.1	(c) 8.2	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 10.0	(k) 14.6	(l) 9.0	(m) 15.5	(n) 4.5	(o) 310	(p) 0.356

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 5.9	(c) 31.9	(d) N/A	(e) 31.3	(f) N/A	(g) 30.8	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 3.4	(p) 130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 8.6	(b) 7.6	(c) 6.9	(e) 3.9	(f) 33.7	(g) 2.3	(h) 0.9	(i) 2.3	(j) 34.3	(k) 1.0	(l) 34.9	(m) -0.3	(n) 35.4	(o) -2.0	(p) 36.1		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	23.2	16.8	18.4	19.5	22.7	25.0	27.1	27.8	28.1	27.4	25.0	20.9	19.2		
	DBStd	4.76	4.16	3.96	3.35	2.25	1.66	1.25	1.12	0.98	1.11	2.51	3.19	3.91		
	HDD10.0	9	6	2	0	0	0	0	0	0	0	0	0	2		
	HDD18.3	207	78	43	29	2	0	0	0	0	0	2	15	38		
	CDD10.0	4817	215	238	294	382	465	512	551	561	521	466	326	288		
	CDD18.3	1973	29	46	64	133	207	262	293	303	271	209	91	66		
	CDH23.3	16158	38	96	155	583	1391	2537	3141	3323	2792	1663	307	133		
	CDH26.7	4234	1	6	8	49	215	691	1017	1109	822	299	17	2		
(14) Wind	WSAvg	3.4	3.6	3.3	3.8	3.8	3.6	3.3	2.9	3.0	3.2	3.5	3.6	3.3		
(15) Precipitation	PrecAvg	1324	59	54	77	60	89	180	171	191	174	130	54	59		
	PrecMax	1804	143	180	311	142	302	362	279	520	345	310	206	235		
	PrecMin	961	0	3	0	15	21	14	67	47	94	22	6	12		
	PrecStd	232	34	37	73	33	60	74	63	89	65	74	45	56		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.0	27.5	27.8	29.6	31.1	32.9	32.5	32.7	31.9	30.8	28.7	26.7		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	24.5	25.6	26.0	27.9	29.5	31.4	31.6	31.9	31.1	29.8	27.1	25.7		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	23.4	24.5	25.1	27.0	28.6	30.6	31.0	31.3	30.6	29.1	26.0	24.9		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	DB	22.3	23.3	24.0	26.2	27.9	29.8	30.4	30.7	30.1	28.4	25.2	24.0		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.1	7.1	7.0	6.4	5.8	5.9	5.7	5.9	5.8	5.8	6.3	6.6		
		MCDBR	7.1	7.1	6.7	6.4	6.3	6.7	6.0	6.2	6.0	5.5	6.1	6.0		
	5% WB	MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.347	0.359	0.374	0.397	0.428	0.456	0.473	0.463	0.426	0.402	0.365	0.354		
	taud		2.544	2.521	2.467	2.383	2.337	2.335	2.284	2.328	2.423	2.460	2.514	2.549		
	Ebn at Noon		896	912	916	900	867	838	823	830	853	856	867	871		
	Edh at Noon		88	98	109	122	128	128	134	128	113	103	90	85		
(44) All-Sky Solar Radiation	RadAvg		3.35	4.06	5.12	6.09	6.28	5.95	5.96	5.65	4.93	4.35	3.53	3.04		
	RadStd		0.24	0.25	0.34	0.24	0.43	0.56	0.29	0.34	0.32	0.28	0.19	0.20		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only		N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
(47) Regional (31 neighbors)		+0.41	N/A	N/A	N/A	N/A	N/A	N/A	-40	+153	+112

Nomenclature: See separate page