

VIRGINIA KEY, FL, USA

WMO: 997355

Lat: 25.7315N

Lon: 80.1619W

Elev: 33

StdP: 14.68

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 49.9	(c) 54.6	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 23.3	(k) 72.3	(l) 20.9	(m) 72.6	(n) 7.5	(o) 340	(p) 0.395

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 5.2	(c) 87.4	(d) N/A	(e) 86.7	(f) N/A	(g) 86.3	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 8.8	(p) 100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 20.9	(b) 18.9	(c) 17.4	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	76.8	68.9	71.3	71.4	75.5	78.2	81.6	82.7	83.4	82.2	79.7	74.3	71.8	
	DBStd	6.41	6.62	5.52	4.86	3.23	2.22	2.09	1.94	1.62	1.85	3.16	4.60	6.01	
	HDD50	2	1	0	0	0	0	0	0	0	0	0	0	1	
	HDD65	101	44	19	13	0	0	0	0	0	0	0	4	21	
	CDD50	9777	586	595	663	764	876	949	1014	1035	967	921	729	678	
	CDD65	4400	163	194	211	314	411	499	549	570	517	456	283	233	
	CDH74	40672	349	593	625	1787	3522	5827	6917	7411	6231	4709	1690	1011	
	CDH80	10837	0	1	13	75	282	1726	2582	3018	2087	959	91	3	
Wind	WSAvg	8.9	8.7	9.0	9.6	10.1	9.7	8.5	7.9	7.8	7.8	9.2	9.0	9.2	
Precipitation	PrecAvg	59.5	1.9	2.2	2.3	3.1	5.1	9.1	6.7	8.1	9.3	6.7	2.8	2.2	
	PrecMax	73.3	7.1	5.5	6.3	6.2	11.2	16.6	10.7	12.6	15.1	14.6	9.1	10.9	
	PrecMin	49.8	0.3	0.1	0.2	0.4	0.2	3.1	3.6	3.0	5.3	1.6	0.4	0.4	
	PrecStd	7.0	1.6	1.5	1.5	1.6	2.7	4.1	2.1	2.4	2.9	4.0	2.4	2.3	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.7	79.5	81.8	85.1	84.8	88.2	88.0	87.9	89.2	86.5	83.4	80.4	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	77.8	78.5	79.3	81.7	83.0	86.5	86.9	87.2	86.6	85.1	82.4	79.6	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	77.1	77.9	78.0	80.4	82.2	85.8	86.3	86.7	86.0	84.3	81.4	79.0	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	10%	DB	76.3	77.2	77.1	79.7	81.5	85.0	85.9	86.3	85.3	83.6	80.0	78.2	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	8.1	6.8	7.0	5.5	4.9	5.0	5.2	5.2	5.6	5.5	7.1	6.9	
		MCDBR	5.5	5.6	7.2	6.9	5.8	5.8	5.6	5.5	6.1	5.7	5.8	4.7	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Clear-Sky Solar Irradiance	taub	0.365	0.375	0.387	0.398	0.425	0.457	0.462	0.453	0.430	0.415	0.381	0.374	
taud		2.527	2.511	2.465	2.418	2.387	2.357	2.338	2.389	2.449	2.460	2.503	2.520		
Ebn at Noon		282	287	289	286	276	266	264	267	272	271	274	274		
Edh at Noon		30	32	35	38	39	40	41	38	35	33	30	29		
All-Sky Solar Radiation	RadAvg	1177	1430	1751	1984	1995	1826	1878	1805	1588	1453	1246	1095		
	RadStd	78	85	82	94	162	160	82	96	81	104	58	79		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Regional (27 neighbors)	+0.70	+1.58	N/A	N/A	N/A	N/A	N/A	N/A	-36	+243	+205

Nomenclature: See separate page