

EAGLE POINT, TX, USA

WMO: 997361

Lat: 29.481N

Lon: 94.917W

Elev: 33

StdP: 14.68

Time Zone: -6.00 (NAC)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 34.4	(c) 38.1	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 26.4	(k) 57.5	(l) 24.1	(m) 55.1	(n) 11.6	(o) 10	(p) 0.523

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 8.1	(c) 89.7	(d) N/A	(e) 88.8	(f) N/A	(g) 87.7	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 10.7	(p) 180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 32.3	(b) 25.6	(c) 22.4	(e) 31.3	(f) 92.8	(g) 3.9	(h) 2.0	(i) 28.5	(j) 94.3	(k) 26.3	(l) 95.5	(m) 24.1	(n) 96.6	(o) 21.3	(p) 98.1		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	70.2	53.3	56.7	63.3	69.7	76.0	82.0	82.9	83.8	80.6	73.1	62.6	57.2		
	DBStd	12.17	7.97	8.26	6.92	5.11	3.92	2.21	2.02	2.01	3.13	6.10	7.64	7.88		
	HDD50	134	58	35	7	0	0	0	0	0	0	0	8	26		
	HDD65	1147	367	244	110	20	1	0	0	0	0	13	131	261		
	CDD50	7491	160	221	419	590	805	961	1021	1047	917	715	387	248		
	CDD65	3028	4	10	57	159	341	511	556	582	467	263	59	19		
	CDH74	30230	2	5	23	337	2382	6053	6945	7540	5067	1792	74	10		
	CDH80	9913	0	0	2	15	185	2044	2670	3227	1533	235	2	0		
(14) Wind	WSAvg	11.5	10.1	11.3	12.6	14.9	14.6	13.0	10.7	9.7	10.2	10.6	10.3	10.1		
(15) Precipitation	PrecAvg	48.8	4.3	2.9	3.3	3.4	3.6	4.4	3.8	4.4	6.0	4.7	4.0	4.1		
	PrecMax	67.9	10.3	8.3	7.5	8.6	9.3	13.1	11.8	13.1	12.1	12.9	13.3	9.4		
	PrecMin	26.5	0.7	0.5	0.3	0.5	0.0	0.5	0.4	0.6	1.3	0.4	0.5	1.1		
	PrecStd	11.2	2.4	2.2	1.9	2.3	2.5	3.0	2.7	3.4	2.8	3.4	2.8	2.0		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.4	74.2	76.5	81.9	86.0	91.4	90.8	91.5	90.4	85.6	78.3	75.4		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	69.2	71.3	74.0	78.4	83.2	88.3	88.8	90.0	88.5	83.9	76.3	73.0		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	67.0	69.3	72.9	77.1	81.8	86.8	87.7	89.1	86.8	82.6	74.8	70.7		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	64.5	67.2	71.6	76.0	81.0	85.9	86.9	88.2	85.5	81.2	72.9	68.3		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.5	9.9	7.9	7.5	6.4	6.6	7.4	8.1	7.1	8.8	9.5	10.4		
		MCDBR	13.0	11.7	7.4	8.2	7.4	8.6	8.5	9.4	8.4	8.2	10.1	13.0		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.346	0.363	0.378	0.437	0.477	0.469	0.493	0.478	0.454	0.385	0.374	0.355		
	taud		2.511	2.474	2.422	2.256	2.180	2.257	2.212	2.256	2.287	2.471	2.447	2.493		
	Ebn at Noon		282	286	288	273	261	262	255	259	261	275	269	273		
	Edh at Noon		29	32	36	44	48	44	46	43	41	32	30	28		
(44) All-Sky Solar Radiation	RadAvg		921	1042	1434	1709	1924	1992	1895	1815	1578	1393	1058	821		
	RadStd		88	173	120	125	129	149	178	149	168	167	107	95		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (31 neighbors)		+0.61	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+203	+169

Nomenclature: See separate page