

SABINE PASS NORTH, TX, USA

WMO: 997368

Lat: 29.728N

Lon: 93.870W

Elev: 10

StdP: 14.69

Time Zone: -6.00 (NAC)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 32.7	(c) 37.0	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 26.6	(k) 46.2	(l) 24.6	(m) 45.3	(n) 12.6	(o) 10	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 9.0	(c) 90.4	(d) N/A	(e) 89.2	(f) N/A	(g) 88.2	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 9.0	(p) 210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 24.3	(b) 21.2	(c) 19.3	(e) 29.2	(f) 93.7	(g) 3.7	(h) 1.1	(i) 26.6	(j) 94.5	(k) 24.4	(l) 95.2	(m) 22.3	(n) 95.8	(o) 19.6	(p) 96.6		
			DB		WB											
			N/A		N/A		N/A		N/A		N/A		N/A		N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	69.4	51.8	56.1	62.3	68.7	75.5	82.2	83.0	83.9	79.8	71.7	61.2	56.1
	DBStd	12.66	8.15	8.34	7.18	5.59	4.38	2.35	2.26	2.43	3.31	6.59	7.95	8.11
	HDD50	171	76	39	8	1	0	0	0	0	0	0	13	34
	HDD65	1302	410	256	133	29	3	0	0	0	0	21	160	290
	CDD50	7265	133	210	389	563	790	965	1023	1050	895	674	349	224
	CDD65	2922	2	7	49	141	328	515	558	585	445	230	46	16
	CDH74	29264	0	1	24	295	2257	6081	6874	7464	4581	1638	43	6
CDH80	9791	0	0	2	15	203	2099	2685	3237	1321	229	0	0	
Wind	WSAvg	10.0	10.3	11.0	10.7	12.1	11.6	9.5	7.7	7.6	9.4	9.3	10.3	10.3
Precipitation	PrecAvg	58.3	5.3	3.9	3.7	3.9	4.1	5.9	5.9	5.3	6.1	5.4	4.4	4.8
	PrecMax	81.8	12.9	7.8	8.0	8.1	11.7	10.7	13.3	13.9	11.1	19.2	11.3	10.9
	PrecMin	38.9	0.2	1.1	0.9	0.7	0.0	0.7	2.1	0.7	1.4	0.2	0.9	2.3
	PrecStd	11.1	3.3	2.2	1.8	2.2	3.1	2.7	3.0	3.4	3.0	4.7	2.5	2.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	70.8	72.8	76.8	81.9	86.4	92.5	91.4	93.5	90.0	86.2	77.8	74.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	67.9	70.4	73.8	78.0	83.6	88.9	89.3	90.9	87.6	84.1	75.2	71.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	65.6	68.4	72.7	76.8	82.1	87.3	88.4	89.5	86.4	82.5	73.2	69.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	12.0	10.7	9.8	9.0	7.7	7.6	8.5	9.0	8.8	11.3	11.7	11.9
		MCDBR	12.6	10.4	8.9	9.0	8.5	8.7	9.4	9.9	9.3	9.7	10.9	12.3
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		0.346	0.361	0.378	0.433	0.476	0.483	0.495	0.478	0.455	0.387	0.374	0.354
	taud		2.523	2.490	2.433	2.278	2.190	2.221	2.220	2.272	2.299	2.474	2.451	2.501
	Ebn at Noon		282	287	288	274	262	259	255	259	261	274	269	272
	Edh at Noon		28	32	36	43	47	45	45	43	40	32	30	28
All-Sky Solar Radiation	RadAvg		921	1051	1459	1756	1978	2020	1910	1806	1593	1411	1067	820
	RadStd		91	172	131	131	130	147	159	150	167	173	104	92

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (34 neighbors)	+0.63	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+205	+160

Nomenclature: See separate page