

SABINE PASS NORTH, TX, USA

WMO: 997368

Lat: 29.728N

Lon: 93.870W

Elev: 3

StdP: 101.29

Time Zone: -6.00 (NAC)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 0.4	(c) 2.8	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 11.9	(k) 7.9	(l) 11.0	(m) 7.4	(n) 5.6	(o) 10	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 5.0	(c) 32.4	(d) N/A	(e) 31.8	(f) N/A	(g) 31.2	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 4.0	(p) 210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 10.9	(b) 9.5	(c) 8.6	(e) DB	(f) -1.5	(g) 34.3	(h) 2.1	(i) 0.6	(j) -3.0	(k) 34.7	(l) -4.2	(m) 35.1	(n) -5.4	(o) 35.4	(p) -6.9	(q) 35.9	(r) N/A
(a) 10.9	(b) 9.5	(c) 8.6	(e) WB	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A	(q) N/A	(r) N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	20.8	11.0	13.4	16.8	20.4	24.2	27.9	28.3	28.8	26.6	22.1	16.2	13.4		
	DBStd	7.03	4.53	4.63	3.99	3.11	2.43	1.30	1.26	1.35	1.84	3.66	4.42	4.51		
	HDD10.0	95	42	22	4	1	0	0	0	0	0	0	7	19		
	HDD18.3	723	228	142	74	16	2	0	0	0	0	12	89	161		
	CDD10.0	4036	74	117	216	313	439	536	568	583	497	374	194	124		
	CDD18.3	1623	1	4	27	78	182	286	310	325	247	128	26	9		
	CDH23.3	16258	0	1	13	164	1254	3378	3819	4147	2545	910	24	3		
	CDH26.7	5439	0	0	1	8	113	1166	1492	1798	734	127	0	0		
(14) Wind	WSAvg	4.5	4.6	4.9	4.8	5.4	5.2	4.2	3.4	3.4	4.2	4.2	4.6	4.6		
(15) Precipitation	PrecAvg	1481	134	98	93	100	105	150	150	134	155	137	111	123		
	PrecMax	2077	328	198	202	207	297	271	338	352	283	488	287	276		
	PrecMin	989	4	28	22	17	0	17	54	17	35	4	22	58		
	PrecStd	281	83	56	45	55	79	69	75	86	77	119	63	56		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.6	22.7	24.9	27.7	30.2	33.6	33.0	34.2	32.2	30.1	25.4	23.7		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	19.9	21.3	23.2	25.5	28.6	31.6	31.9	32.7	30.9	29.0	24.0	22.1		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	18.7	20.2	22.6	24.9	27.8	30.7	31.3	32.0	30.2	28.0	22.9	20.9		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	17.4	19.1	21.8	24.3	27.2	30.2	30.8	31.5	29.5	27.3	21.9	19.9		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.7	5.9	5.4	5.0	4.3	4.2	4.7	5.0	4.9	6.3	6.5	6.6		
		MCDBR	7.0	5.8	5.0	5.0	4.7	4.8	5.2	5.5	5.2	5.4	6.1	6.8		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.346	0.361	0.378	0.433	0.476	0.483	0.495	0.478	0.455	0.387	0.374	0.354		
	taud		2.523	2.490	2.433	2.278	2.190	2.221	2.220	2.272	2.299	2.474	2.451	2.501		
	Ebn at Noon		889	905	908	865	825	815	804	815	822	865	848	859		
	Edh at Noon		89	100	112	135	148	143	143	134	127	100	95	87		
(44) All-Sky Solar Radiation	RadAvg		2.90	3.31	4.60	5.54	6.24	6.37	6.02	5.69	5.02	4.45	3.36	2.58		
	RadStd		0.29	0.54	0.41	0.41	0.41	0.46	0.50	0.47	0.53	0.55	0.33	0.29		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (34 neighbors)		+0.35	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+114	+89

Nomenclature: See separate page