

PRUDHOE BAY HARBOR, AK, USA

WMO: 997386

Lat: 70.400N

Lon: 148.527W

Elev: 5

StdP: 101.26

Time Zone: -9.00 (NAK)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-40.3	-38.2	N/A	N/A	N/A	N/A	N/A	N/A	22.6	-18.7	20.9	-18.8	4.1	270	1.169

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.3	13.8	N/A	11.8	N/A	9.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.3	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
19.4	17.3	15.3	-41.2	18.1	2.0	2.3	-42.6	19.7	-43.8	21.1	-44.9	22.4	-46.4	24.0		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-9.5	-25.4	-23.2	-22.9	-14.4	-4.1	2.3	5.7	5.6	2.4	-4.2	-15.2	-21.2
	DBStd	12.87	7.14	8.52	7.23	6.09	4.93	2.65	2.66	2.85	2.92	3.52	6.71	7.27
	HDD10.0	7124	1099	931	1021	733	437	233	137	143	229	441	755	967
	HDD18.3	10156	1357	1164	1279	983	695	482	392	396	479	699	1005	1225
	CDD10.0	11	0	0	0	0	0	1	3	6	1	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
	WSAvg	6.5	6.2	6.7	6.3	5.9	6.1	6.7	6.3	6.6	7.4	7.4	6.3	5.7
Precipitation	PrecAvg	186	10	7	7	5	7	14	28	37	28	22	12	11
	PrecMax	335	31	23	34	12	22	43	65	89	75	52	32	34
	PrecMin	109	1	0	0	0	1	3	7	10	4	9	2	1
	PrecStd	49	7	5	6	3	5	10	13	20	19	10	8	8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-2.6	-1.3	-2.0	2.7	5.5	15.8	16.2	16.6	12.8	4.2	-0.4	-2.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	-11.3	-4.7	-6.3	-0.6	3.4	11.6	13.4	13.7	10.2	2.1	-3.7	-5.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	-14.2	-8.4	-10.1	-3.5	2.4	8.2	11.5	11.7	8.1	0.6	-5.0	-8.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	-16.1	-11.4	-13.5	-5.9	1.5	5.4	9.5	9.9	5.9	-0.1	-6.5	-11.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	5.9	7.1	7.3	7.1	4.8	4.3	4.3	3.5	2.7	3.5	5.7	5.8
		MCDBR	8.6	10.7	8.0	8.1	5.3	9.2	7.9	6.6	6.8	2.9	6.0	7.7
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		N/A	0.198	0.239	0.296	0.317	0.330	0.344	0.330	0.295	0.217	N/A	N/A
	taud		N/A	2.046	2.204	2.114	2.160	2.297	2.411	2.517	2.533	2.171	N/A	N/A
	Ebn at Noon		0	538	784	826	855	857	831	804	733	501	0	0
	Edh at Noon		0	36	68	107	117	106	92	74	54	31	0	0
All-Sky Solar Radiation	RadAvg		0.00	0.34	1.92	4.26	5.90	6.29	5.13	2.94	1.46	0.42	0.00	0.00
	RadStd		0.00	0.03	0.08	0.20	0.29	0.38	0.38	0.29	0.13	0.06	0.00	0.00

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (3 neighbors)	+1.14	N/A	N/A	N/A	N/A	N/A	-501	-494	N/A	N/A

Nomenclature: See separate page