

NORTH EQUATORIAL 2 BUOY 41041, USA

WMO: 997397

Lat: 14.500N

Lon: 46.000W

Elev: 10

StdP: 14.69

Time Zone: -3.00 (W03)

Period: 05-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	73.6	74.5	62.9	85.8	76.5	64.0	89.3	76.7	26.7	75.5	25.8	75.7	18.4	70	0.693

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	2.6	83.5	78.0	83.3	77.9	82.9	77.6	82.5	82.6	81.8	82.0	80.5	81.5	14.0	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
82.4	169.1	82.6	81.8	165.5	81.9	80.2	157.0	81.3	46.4	82.5	45.5	81.6	44.1	81.3	85.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.8	23.4	22.4	DB	71.2	85.1	0.9	2.3	70.6	86.8	70.1	88.1	69.6	89.4	68.9	91.1	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	78.7	77.1	76.1	76.4	77.0	78.2	78.7	79.2	80.2	81.1	81.2	80.3	78.7
	DBStd	2.05	1.19	1.12	1.28	1.31	1.35	1.15	1.04	1.11	1.02	1.08	1.16	1.14
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	10474	840	731	819	810	873	861	906	937	932	967	908	890
	CDD65	4999	375	311	354	360	408	411	441	472	482	502	458	425
	CDH74	43771	2574	1696	1941	2270	3260	3545	4109	4903	5309	5641	4785	3738
	CDH80	4020	1	0	0	23	59	107	187	613	1060	1239	632	99
(14) Wind	WSAvg	16.1	18.1	18.3	16.2	15.9	16.7	17.7	16.8	14.3	12.8	14.6	15.2	16.4
(15) Precipitation	PrecAvg	21.4	0.8	0.2	0.3	0.2	0.2	0.5	1.3	3.0	4.1	5.0	3.7	2.0
	PrecMax	31.0	3.9	1.2	3.8	0.9	0.8	1.9	4.1	8.8	9.4	11.3	7.7	5.6
	PrecMin	12.0	0.1	0.0	0.0	0.0	0.0	0.1	0.1	0.6	1.0	0.6	1.2	0.0
	PrecStd	4.1	0.9	0.2	0.7	0.2	0.2	0.4	0.9	1.9	2.0	2.3	1.7	1.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	80.4	79.1	79.5	82.2	81.5	82.3	82.4	83.6	84.2	84.4	83.5	82.4
		MCWB	73.4	75.3	74.9	74.6	75.3	75.9	76.2	77.9	78.1	80.9	76.8	75.1
	2%	DB	79.7	78.5	79.3	80.6	81.3	81.6	82.2	83.1	83.4	83.5	83.0	81.7
		MCWB	72.7	73.7	74.6	74.3	75.2	75.5	76.1	77.7	78.0	78.3	76.5	74.7
	5%	DB	79.3	78.3	78.8	79.5	80.9	81.2	81.7	82.5	83.1	83.3	82.4	81.2
		MCWB	72.4	73.4	74.0	73.7	74.9	75.4	76.0	77.5	77.9	78.2	76.3	74.4
	10%	DB	79.0	78.1	78.3	78.8	80.4	80.8	81.2	82.2	82.7	83.0	82.2	80.5
		MCWB	72.3	72.8	73.3	73.2	74.6	75.2	75.8	77.4	77.8	77.9	76.2	74.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	77.5	78.4	78.5	78.3	76.9	78.3	78.9	82.4	83.0	83.5	78.4	77.1
		MCDB	77.6	78.5	78.6	78.5	80.7	80.6	80.2	82.5	83.1	83.6	81.4	80.2
	2%	WB	75.8	77.5	77.7	77.4	76.3	77.5	78.2	81.7	82.3	82.9	78.0	76.3
		MCDB	77.5	77.6	77.9	77.7	80.2	80.1	80.2	81.8	82.4	83.0	81.3	79.9
	5%	WB	75.0	76.6	76.8	76.4	75.9	77.1	77.7	80.2	81.7	82.0	77.4	75.7
		MCDB	77.6	77.3	77.7	77.9	79.9	80.0	80.2	81.3	81.8	82.2	81.2	79.7
	10%	WB	74.1	73.9	75.4	74.9	75.4	76.5	77.2	79.0	80.6	80.2	77.2	75.3
		MCDB	77.8	77.2	77.7	78.0	79.6	79.9	80.2	81.1	81.6	81.7	81.2	79.5
(35) Mean Daily Temperature Range	5% DB	MDBR	2.4	2.4	1.8	2.0	1.7	1.6	1.9	2.4	2.5	2.6	2.4	2.2
		MCDBR	2.4	2.3	1.9	2.6	1.8	2.0	2.3	2.8	2.9	2.8	2.7	2.6
		MCWBR	2.1	2.8	2.4	2.3	1.7	2.1	2.1	2.3	2.5	2.3	2.0	2.4
	5% WB	MCDBR	2.4	2.1	1.9	2.8	1.9	2.0	2.3	3.1	3.4	3.4	2.8	2.4
		MCWBR	2.2	3.3	2.7	2.3	1.9	2.1	2.0	3.1	3.2	3.3	2.4	2.4
(40) Clear-Sky Solar Irradiance	taub		0.394	0.418	0.406	0.439	0.486	0.572	0.553	0.492	0.473	0.414	0.399	0.404
	taud		2.479	2.373	2.441	2.356	2.196	1.962	2.023	2.243	2.309	2.519	2.544	2.487
	Ebn at Noon		286	283	289	277	260	236	241	259	266	281	283	279
	Edh at Noon		34	39	37	41	47	59	56	45	42	33	32	33
(44) All-Sky Solar Radiation	RadAvg		1641	1878	2074	2156	2110	2058	2076	2076	1964	1727	1612	1559
	RadStd		83	75	68	58	88	73	42	67	86	81	90	90

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page