

LA PUSH, WA, USA

WMO: 997696

Lat: 47.9134N

Lon: 124.6370W

Elev: 10

StdP: 14.69

Time Zone: -8.00 (NAP)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	27.6	29.8	N/A	N/A	N/A	N/A	N/A	N/A	32.3	46.6	26.7	49.6	4.3	80	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.6	65.7	N/A	63.3	N/A	61.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.9	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.4	19.3	16.6	DB	22.0	78.2	2.9	7.1	19.9	83.2	18.2	87.4	16.6	91.3	14.5	96.5	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	48.7	42.0	42.6	43.6	45.7	49.6	53.3	56.2	56.7	55.4	50.8	45.6	41.8
	DBStd	6.88	4.88	4.66	3.84	3.57	3.66	2.86	2.88	2.56	3.82	4.23	5.62	5.41
	HDD50	1297	249	208	199	137	49	4	0	0	3	40	151	257
	HDD65	5968	712	627	662	581	476	352	273	256	289	440	582	718
	CDD50	806	2	2	2	7	38	102	193	209	164	65	19	3
	CDD65	2	0	0	0	0	0	0	1	0	1	0	0	0
	CDH74	33	0	0	0	1	2	0	20	1	9	0	0	0
	CDH80	10	0	0	0	0	0	0	9	0	1	0	0	0
Wind	WSAvg	6.0	6.8	6.0	6.9	6.5	6.1	5.4	5.2	4.4	5.0	5.8	6.7	6.7
Precipitation	PrecAvg	98.1	15.5	9.4	11.7	7.2	4.1	3.3	1.5	2.5	3.9	10.5	15.2	13.4
	PrecMax	127.7	26.2	26.5	22.5	13.4	8.3	8.6	4.7	13.9	12.6	20.4	27.1	22.4
	PrecMin	68.0	8.3	0.0	1.1	1.0	0.1	0.1	0.0	0.0	0.0	0.9	4.5	6.0
	PrecStd	14.8	4.2	5.5	5.0	3.3	2.1	1.9	1.1	3.0	3.0	5.0	6.3	4.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.1	56.0	57.9	60.3	67.2	64.1	71.6	67.8	73.8	64.6	59.1	56.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	52.5	53.2	53.3	55.3	59.6	61.0	63.5	63.7	65.7	60.4	56.5	53.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	50.6	51.1	51.5	52.9	56.6	59.4	61.9	62.2	62.8	59.0	54.7	51.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	48.9	49.3	50.0	51.2	54.9	58.1	60.5	61.0	61.1	57.4	53.3	49.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	9.2	9.0	9.7	9.8	8.7	7.4	6.8	7.6	10.0	10.8	10.4	8.8
		MCDBR	10.8	11.3	12.3	13.7	12.3	9.6	9.1	9.5	13.5	11.5	9.7	8.4
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.319	0.319	0.335	0.362	0.384	0.357	0.348	0.351	0.343	0.337	0.324	0.314	
	taud	2.524	2.552	2.519	2.420	2.374	2.481	2.543	2.534	2.546	2.548	2.519	2.506	
	Ebn at Noon	243	271	282	283	279	287	288	283	276	259	238	229	
	Edh at Noon	20	23	28	34	37	33	31	30	27	23	20	18	
All-Sky Solar Radiation	RadAvg	306	593	909	1362	1664	1820	1846	1568	1226	713	373	257	
	RadStd	42	76	98	119	132	149	128	125	97	82	53	33	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (64 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page