

LA PUSH, WA, USA

WMO: 997696

Lat: 47.9134N

Lon: 124.6370W

Elev: 3

StdP: 101.29

Time Zone: -8.00 (NAP)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 12	(b) -2.4	(c) -1.2	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 14.4	(k) 8.1	(l) 12.0	(m) 9.8	(n) 1.9	(o) 80	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 4.2	(c) 18.7	(d) N/A	(e) 17.4	(f) N/A	(g) 16.5	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 2.6	(p) 330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.5	8.6	7.4	-5.5	25.6	1.6	3.9	-6.7	28.5	-7.6	30.8	-8.5	33.0	-9.7	35.8
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.3	5.6	5.9	6.5	7.6	9.8	11.8	13.5	13.7	13.0	10.4	7.6	5.5
	DBStd	3.82	2.71	2.59	2.13	1.98	2.03	1.59	1.60	1.42	2.12	2.35	3.12	3.01
	HDD10.0	721	138	116	111	76	27	2	0	0	2	22	84	143
	HDD18.3	3316	396	348	368	323	264	196	152	142	161	244	323	399
	CDD10.0	448	1	1	1	4	21	57	107	116	91	36	11	2
	CDD18.3	1	0	0	0	0	0	0	1	0	1	0	0	0
	CDH23.3	18	0	0	0	1	1	0	11	1	5	0	0	0
	CDH26.7	6	0	0	0	0	0	0	5	0	1	0	0	0
(14) Wind	WSAvg	2.7	3.0	2.7	3.1	2.9	2.7	2.4	2.3	1.9	2.2	2.6	3.0	3.0
(15) Precipitation	PrecAvg	2493	393	239	297	183	103	84	38	63	99	267	385	340
	PrecMax	3244	665	673	571	341	210	218	119	353	320	517	688	569
	PrecMin	1726	210	0	28	26	3	3	0	0	0	23	115	153
	PrecStd	376	107	140	128	84	54	47	28	75	76	127	160	112
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.8	13.3	14.4	15.7	19.6	17.8	22.0	19.9	23.2	18.1	15.0	13.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	11.4	11.8	11.8	12.9	15.4	16.1	17.5	17.6	18.7	15.8	13.6	11.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	10.3	10.6	10.9	11.6	13.6	15.2	16.6	16.8	17.1	15.0	12.6	10.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	9.4	9.6	10.0	10.7	12.7	14.5	15.8	16.1	16.2	14.1	11.9	9.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(35) Mean Daily Temperature Range	MDBR		5.1	5.0	5.4	5.5	4.9	4.1	3.8	4.2	5.5	6.0	5.8	4.9
	5% DB	MCDBR	6.0	6.3	6.8	7.6	6.9	5.3	5.1	5.3	7.5	6.4	5.4	4.7
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(40) Clear-Sky Solar Irradiance	taub		0.319	0.319	0.335	0.362	0.384	0.357	0.348	0.351	0.343	0.337	0.324	0.314
	taud		2.524	2.552	2.519	2.420	2.374	2.481	2.543	2.534	2.546	2.548	2.519	2.506
	Ebn at Noon		765	853	889	891	879	905	909	893	869	816	749	721
	Edh at Noon		62	74	88	107	116	105	98	95	85	73	62	56
(44) All-Sky Solar Radiation	RadAvg		0.97	1.87	2.87	4.29	5.25	5.74	5.82	4.94	3.87	2.25	1.18	0.81
	RadStd		0.13	0.24	0.31	0.38	0.42	0.47	0.40	0.39	0.30	0.26	0.17	0.10

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (64 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page