

PELLICER CREEK, FL, USA

WMO: 998000

Lat: 29.6577N

Lon: 81.2328W

Elev: 4

StdP: 101.28

Time Zone: -5.00 (NAE)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.9	3.1	-6.7	2.1	5.0	-3.5	2.8	7.6	9.0	9.7	8.0	10.1	1.4	270	0.313

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.2	32.9	26.2	31.8	26.0	30.8	26.0	29.9	30.1	28.2	28.8	26.9	29.1	2.3	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
29.9	27.0	30.1	28.1	24.3	28.4	26.3	21.8	27.8	98.7	29.9	90.4	28.8	84.2	29.4	35.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years					
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max				
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.4	6.4	5.5	DB	-1.8	35.1	1.7	0.6	-2.9	35.6	-3.9	35.9	-4.9	36.3	-6.1	36.7
			WB	-3.9	28.3	2.1	2.6	-5.4	30.2	-6.6	31.7	-7.8	33.2	-9.3	35.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	21.0	13.3	15.3	16.7	20.6	23.6	26.2	26.8	27.1	26.0	22.5	18.1	15.9
	DBStd	5.83	4.77	4.84	4.08	2.76	2.16	1.45	1.20	1.12	1.35	3.30	4.22	4.48
	HDD10.0	48	23	12	4	0	0	0	0	0	0	0	1	9
	HDD18.3	523	167	107	78	11	0	0	0	0	0	8	55	97
	CDD10.0	4075	124	159	213	319	422	486	522	529	479	389	243	192
	CDD18.3	1508	10	21	28	80	164	236	263	271	229	139	47	22
	CDH23.3	12032	30	79	131	386	1111	2081	2414	2568	2085	929	157	62
(13)	CDH26.7	3336	1	10	19	51	198	678	858	868	512	121	16	3
(14)	Wind	WSAvg	2.3	2.3	2.2	2.5	2.5	2.7	2.1	1.8	2.0	2.5	2.6	2.2
(15) Precipitation	PrecAvg	1310	71	73	95	62	73	177	145	164	211	117	59	63
	PrecMax	1696	194	225	231	203	183	278	263	293	402	281	156	249
	PrecMin	851	26	22	3	11	20	15	54	70	40	15	8	10
	PrecStd	228	44	53	63	49	48	64	56	59	107	72	37	62
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.1	28.3	29.0	30.1	32.4	34.1	33.9	33.9	32.3	30.7	28.5	27.1
		MCWB	22.4	21.8	20.3	22.2	24.0	26.5	26.7	26.0	26.7	24.3	23.3	21.8
	2%	DB	23.9	25.8	26.6	28.3	30.2	32.5	32.6	32.3	30.6	28.9	26.5	25.1
		MCWB	20.1	20.5	19.8	21.7	23.7	26.3	26.2	26.3	25.4	24.4	22.8	21.0
	5%	DB	22.0	23.7	24.6	26.7	28.5	31.0	31.5	31.3	29.8	28.0	25.1	23.4
		MCWB	18.7	20.3	19.7	21.8	23.9	26.0	26.3	26.4	25.4	23.9	22.2	20.2
(26) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	DB	20.3	21.8	22.9	25.6	27.5	30.1	30.4	30.4	29.1	27.1	23.9	21.9
		MCWB	18.0	19.0	18.9	21.3	23.3	25.8	26.3	26.4	25.2	23.3	20.6	19.4
	2%	WB	22.8	24.4	23.0	25.9	28.7	31.3	31.8	31.1	30.3	26.2	25.1	22.7
		MCDB	23.8	24.7	24.3	26.0	30.4	31.4	31.8	31.2	30.6	28.4	26.7	25.8
	5%	WB	20.6	21.7	21.4	23.9	25.7	29.0	29.6	29.3	27.9	25.4	24.0	21.7
		MCDB	22.7	24.1	24.4	26.3	27.5	29.3	29.7	29.4	28.2	27.9	26.0	24.1
(33) Mean Daily Temperature Range	5% DB	WB	19.6	20.7	20.6	22.9	24.6	26.9	27.2	27.3	26.7	24.8	22.7	20.8
		MCDB	21.7	22.9	23.4	25.2	26.9	29.2	29.3	29.4	28.3	27.2	24.4	22.5
	5% WB	WB	18.5	19.8	19.7	22.0	23.9	25.9	26.4	26.7	25.8	24.1	21.4	20.0
		MCWB	20.1	21.6	22.3	24.5	26.5	29.3	29.7	29.4	28.1	26.2	23.2	21.7
(35) Clear-Sky Solar Irradiance	taub	MDBR	9.3	9.1	9.4	8.6	7.5	8.0	7.8	7.2	6.2	7.4	7.8	8.9
		MCDBR	10.3	10.1	11.4	10.1	9.0	9.5	9.2	8.7	7.5	7.2	8.1	9.7
	Ebn at Noon	MCWBR	6.7	5.9	6.0	5.3	4.4	4.7	4.5	4.1	3.6	3.7	4.7	6.1
		MCDBR	9.3	8.9	9.5	8.6	7.6	8.6	8.3	7.6	6.3	6.5	6.1	8.7
(44) All-Sky Solar Radiation	RadAvg	3.19	3.85	5.01	6.11	6.43	5.97	5.91	5.57	4.83	4.27	3.44	2.91	
	RadStd	0.24	0.37	0.42	0.36	0.42	0.50	0.36	0.37	0.39	0.34	0.20	0.25	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (35 neighbors)	+0.44	N/A	N/A	N/A	N/A	N/A	N/A	-8	-58	+160	+117

Nomenclature: See separate page