

OYSTER LANDING, SC, USA

WMO: 998005

Lat: 33.3494N

Lon: 79.1889W

Elev: 4

StdP: 101.28

Time Zone: -5.00 (NAE)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -3.0	(c) -1.0	(d) -13.9	(e) 1.1	(f) -1.0	(g) -10.2	(h) 1.6	(i) 1.5	(j) 10.0	(k) 15.9	(l) 8.5	(m) 13.9	(n) 2.6	(o) 320	(p) 0.415

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 6.2	(c) 32.9	(d) 25.7	(e) 31.8	(f) 25.7	(g) 30.6	(h) 25.4	(i) 27.3	(j) 30.5	(k) 26.8	(l) 29.8	(m) 26.3	(n) 29.2	(o) 4.2	(p) 250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.5	22.0	29.1	25.9	21.2	28.6	25.5	20.7	28.2	86.0	30.5	83.6	29.9	81.6	29.2	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.1	8.0	7.2		-5.2	35.1	2.3	1.1	-6.9	35.9	-8.2	36.6	-9.5	37.2	-11.2	38.1
			DB	-7.0	28.3	2.1	0.6	-8.6	28.8	-9.8	29.2	-11.0	29.5	-12.5	30.0
			WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	18.3	8.4	10.5	12.8	17.9	22.2	26.0	26.9	26.4	24.1	19.1	13.3	11.7	(6)
(7)		DBStd	7.53	5.41	5.01	4.65	3.53	3.08	2.24	1.71	1.79	2.38	3.81	4.44	5.14	(7)
(8)		HDD10.0	232	96	51	26	1	0	0	0	0	1	18	41		(8)
(9)		HDD18.3	1171	308	222	178	49	7	0	0	1	37	158	213		(9)
(10)		CDD10.0	3273	48	64	114	239	380	479	524	509	422	283	118	93	(10)
(11)		CDD18.3	1169	1	3	7	37	128	229	266	251	173	62	8	7	(11)
(12)		CDH23.3	9771	1	5	24	107	702	2147	2748	2432	1309	273	13	9	(12)
(13)		CDH26.7	2554	0	0	3	6	139	625	842	674	241	25	0	0	(13)
(14)	Wind	WSAvg	3.4	3.0	3.4	3.7	3.9	3.9	3.5	3.5	3.0	3.2	3.2	3.1	2.9	(14)
(15)	Precipitation	PrecAvg	1410	106	89	108	68	102	149	178	178	150	109	70	91	(15)
(16)		PrecMax	1887	272	318	324	203	242	304	398	495	440	334	297	263	(16)
(17)		PrecMin	929	9	15	21	1	16	36	3	25	15	0	0	19	(17)
(18)		PrecStd	267	59	61	61	52	63	64	87	115	111	94	58	54	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.7	24.0	26.4	27.5	33.0	34.4	34.2	33.8	31.5	29.0	25.2	24.7	(19)
(20)			MCWB	18.9	18.8	17.1	20.1	23.3	25.5	25.8	26.2	25.0	23.6	20.9	21.2	(20)
(21)		2%	DB	20.0	21.8	23.3	25.8	29.9	32.6	32.6	32.2	30.0	27.1	23.0	22.9	(21)
(22)			MCWB	17.2	17.5	17.5	20.2	23.1	25.4	26.3	26.0	25.0	22.7	19.6	20.3	(22)
(23)		5%	DB	18.3	19.9	21.5	24.7	27.9	31.3	31.6	30.8	28.9	26.1	21.6	21.2	(23)
(24)			MCWB	16.1	16.9	17.2	19.9	22.6	25.3	26.2	25.7	24.5	22.3	19.3	19.6	(24)
(25)		10%	DB	16.4	18.2	19.8	23.4	26.6	30.0	30.4	29.7	28.0	24.9	20.2	19.6	(25)
(26)			MCWB	14.3	15.8	16.7	19.2	22.5	25.0	25.8	25.5	24.2	21.7	17.9	18.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.0	20.2	20.4	23.2	25.8	27.6	28.3	28.0	26.8	25.5	22.4	22.9	(27)
(28)			MADB	21.5	22.6	23.0	25.0	28.6	31.9	31.5	31.0	29.0	27.6	23.9	23.7	(28)
(29)		2%	WB	18.3	19.1	19.2	22.0	24.4	26.7	27.4	27.1	26.1	24.5	21.1	21.5	(29)
(30)			MADB	19.7	21.0	21.5	24.0	27.3	30.5	30.6	30.0	28.2	26.2	22.2	22.2	(30)
(31)		5%	WB	16.9	17.9	18.3	21.2	23.7	26.2	26.8	26.6	25.6	23.6	20.0	19.9	(31)
(32)			MADB	18.0	19.3	20.5	23.2	26.5	29.5	29.9	29.4	27.7	25.2	21.2	20.9	(32)
(33)		10%	WB	15.0	16.3	17.2	20.4	23.0	25.6	26.3	26.1	25.1	22.5	18.4	18.2	(33)
(34)			MADB	15.9	17.8	19.3	22.5	25.7	28.7	29.2	28.7	27.3	24.1	20.0	19.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.8	8.7	8.6	7.8	6.6	6.7	6.2	5.8	6.2	7.8	8.7	8.7	(35)
(36)			MCDBR	10.3	10.1	10.4	8.8	8.4	8.3	7.8	7.4	6.8	8.1	8.9	9.1	(36)
(37)			MCWBR	7.8	6.8	6.2	4.6	3.9	3.7	3.6	3.2	3.1	4.5	6.2	6.7	(37)
(38)		5% WB	MCDBR	8.8	9.1	8.7	7.0	6.9	7.6	7.2	6.5	5.5	6.5	7.8	8.4	(38)
(39)			MCWBR	8.2	7.1	6.3	4.5	3.6	3.8	3.6	3.2	2.9	4.5	6.6	6.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.330	0.338	0.367	0.401	0.467	0.485	0.531	0.506	0.433	0.393	0.351	0.332	(40)	
(41)		taud	2.524	2.503	2.442	2.325	2.196	2.193	2.080	2.145	2.344	2.427	2.503	2.549	(41)	
(42)		Ebn at Noon	886	916	910	888	829	811	771	785	832	841	853	863	(42)	
(43)		Edh at Noon	84	95	109	127	146	147	163	151	119	101	85	78	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.77	3.43	4.60	5.88	6.37	6.52	6.21	5.58	4.76	4.03	3.09	2.47	(44)	
(45)		RadStd	0.17	0.35	0.42	0.40	0.44	0.44	0.38	0.31	0.38	0.43	0.23	0.19	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A
(47) Regional (43 neighbors)		+0.55	N/A	N/A	N/A	N/A	N/A	N/A	+192	+136

Nomenclature: See separate page