

Nomenclature — Tables of Climate Design Conditions

CDD n	Cooling degree-days base $n^{\circ}\text{F}$, $^{\circ}\text{F}\text{-day}$
CDH n	Cooling degree-hours base $n^{\circ}\text{F}$, $^{\circ}\text{F}\text{-hour}$
DB	Dry bulb temperature, $^{\circ}\text{F}$
DBAvg	Average daily dry bulb temperature, $^{\circ}\text{F}$
DBStd	Standard deviation of daily average dry bulb temperature, $^{\circ}\text{F}$
DP	Dew point temperature, $^{\circ}\text{F}$
Ebn at Noon	Clear sky beam normal irradiance at solar noon, Btu/h/ft^2
Edh at Noon	Clear sky diffuse horizontal irradiance at solar noon, Btu/h/ft^2
Elev	Elevation, ft
Enth	Enthalpy, Btu/lb
HDD n	Heating degree-days base $n^{\circ}\text{F}$, $^{\circ}\text{F}\text{-day}$
HR	Humidity ratio, grains of moisture per lb of dry air
Lat	Latitude, $^{\circ}$
Long	Longitude, $^{\circ}$
MCDDB	Mean coincident dry bulb temperature, $^{\circ}\text{F}$
MCDBR	Mean coincident dry bulb temperature range, $^{\circ}\text{F}$
MCWB	Mean coincident wet bulb temperature, $^{\circ}\text{F}$
MCWBR	Mean coincident wet bulb temperature range, $^{\circ}\text{F}$
MCWS	Mean coincident wind speed, mph
MDBR	Mean dry bulb temperature range, $^{\circ}\text{F}$
PCWD	Prevailing coincident wind direction, $^{\circ}$, 0 = North, 90 = East
Period	Range of years used to calculate design conditions
PrecAvg	Average precipitation, in
PrecMax	Maximum precipitation, in
PrecMin	Minimum precipitation, in
PrecStd	Standard deviation of precipitation, in
RadAvg	Average daily all sky solar radiation, Btu/ft^2
RadStd	Standard deviation of average daily all sky solar radiation, Btu/ft^2
StdP	Standard pressure at station elevation, psi
taub	Clear sky optical depth for beam irradiance
taud	Clear sky optical depth for diffuse irradiance
Time Zone	Hours ahead or behind UTC, and time zone code
WB	Wet bulb temperature, $^{\circ}\text{F}$
WBAN	Weather Bureau Army Navy number
WMO	Station identifier derived from the World Meteorological Organization
WS	Wind speed, mph
WSAvg	Average wind speed, mph
WSF	Weather and shielding factor

Numbers (1) to (47) and letters (a) to (p) are row and column references to quickly point to an element in the table. For example, the 5% design wet bulb temperature for July can be found in row (31), column (k).