

EDGEØYA, Norway

WMO: 010060

Lat: 78.251N

Lon: 22.823E

Elev: 46

StdP: 14.67

Time Zone: 1.00 (EUC)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	-18.3	-14.2	-23.3	1.5	-18.2	-18.9	2.0	-13.9	45.9	17.5	40.3	5.4	3.9	20	1.053

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.1	48.6	45.1	46.6	43.6	44.8	42.2	45.5	48.0	43.9	46.2	42.5	44.5	17.4	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
43.4	41.5	46.6	41.9	39.2	44.9	40.5	37.2	43.5	17.9	48.1	17.1	46.3	16.4	44.7	50.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 36.5	32.0	28.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.5	13.6	12.5	7.9	12.6	24.6	33.4	38.7	38.4	35.0	28.2	20.3	15.6
	DBStd	13.90	12.95	14.38	11.60	9.59	6.54	3.64	4.24	3.79	4.45	6.11	9.59	11.23
	HDD50	9680	1129	1049	1305	1121	786	498	351	359	449	677	891	1065
	HDD65	15155	1594	1469	1770	1571	1251	948	816	824	899	1142	1341	1530
	CDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	12.9	14.2	13.6	13.2	10.5	11.8	10.1	10.3	11.5	12.9	15.1	15.7	15.9
Precipitation	PrecAvg	17.1	1.6	1.3	1.2	0.8	0.8	0.9	1.1	1.8	2.0	2.1	2.0	1.6
	PrecMax	26.1	3.0	3.3	2.5	2.0	1.5	1.8	2.5	3.6	3.7	4.5	3.8	4.3
	PrecMin	5.2	0.6	0.1	0.1	0.2	0.2	0.2	0.2	0.3	0.6	0.6	0.6	0.3
	PrecStd	4.9	0.7	0.8	0.6	0.4	0.4	0.5	0.6	0.8	0.7	0.9	0.9	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.1	36.4	36.0	36.8	37.5	46.2	51.6	51.2	47.1	42.5	38.9	37.3
		MCWB	35.3	34.4	34.0	34.6	34.9	43.2	46.6	47.7	44.9	40.2	36.9	35.7
	2%	DB	34.8	34.8	32.6	34.6	36.0	43.4	49.3	48.2	45.0	40.3	36.5	33.7
		MCWB	33.4	33.2	31.2	33.0	33.8	40.6	45.5	45.0	42.9	38.5	34.6	32.2
	5%	DB	31.0	32.3	29.8	31.6	34.9	40.9	47.4	46.0	43.3	37.5	34.3	31.2
		MCWB	29.8	31.1	29.2	30.9	33.0	38.5	44.0	43.2	41.3	36.1	33.0	30.5
	10%	DB	28.7	29.5	26.2	26.9	33.4	38.9	45.5	44.1	41.4	35.6	32.1	29.4
		MCWB	27.9	28.8	25.6	25.6	31.9	36.8	42.6	41.7	39.6	34.4	31.2	28.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	35.7	34.8	34.6	35.1	35.6	43.7	47.4	48.2	45.0	40.5	36.9	35.6
		MCDB	36.8	36.0	36.1	36.5	36.8	45.8	50.3	51.0	46.3	42.0	38.7	36.9
	2%	WB	33.6	33.3	31.4	33.0	34.3	40.9	45.8	45.3	43.4	38.6	35.0	32.4
		MCDB	34.9	34.7	32.6	34.4	35.6	43.3	48.7	47.7	44.8	39.9	36.2	33.2
	5%	WB	30.0	31.0	29.2	30.5	33.2	38.8	44.3	43.5	41.5	36.4	33.2	30.5
		MCDB	30.8	32.0	29.9	31.6	34.5	40.7	47.1	45.7	43.1	37.3	34.3	31.0
	10%	WB	28.0	29.0	25.6	25.5	32.1	36.9	42.7	42.1	39.8	34.5	31.3	28.9
		MCDB	28.7	29.5	26.2	26.7	33.4	38.7	45.2	43.9	41.2	35.3	32.1	29.4
Mean Daily Temperature Range	5% DB	MDBR	9.6	9.6	9.6	9.8	6.6	4.9	6.1	5.5	5.4	5.7	7.5	9.2
		MCDBR	10.3	10.6	11.3	10.3	7.0	7.6	9.6	8.0	8.1	6.5	8.2	9.6
		MCWBR	10.1	10.0	11.2	9.4	5.7	5.8	6.9	6.2	6.9	6.0	7.8	9.4
	5% WB	MCDBR	10.2	9.7	11.2	10.7	6.7	7.2	9.4	7.8	8.0	6.6	7.7	9.1
		MCWBR	10.1	9.2	11.1	10.0	5.6	5.6	6.9	6.2	7.2	6.2	7.5	8.9
Clear-Sky Solar Irradiance	taub	N/A	0.195	0.248	0.283	0.304	0.295	0.302	0.295	0.253	N/A	N/A	N/A	N/A
	taud	N/A	1.870	2.006	2.107	2.126	2.289	2.444	2.468	2.373	N/A	N/A	N/A	N/A
	Ebn at Noon	0	8	172	239	258	270	263	244	193	0	0	0	0
	Edh at Noon	0	1	17	28	34	30	25	20	12	0	0	0	0
All-Sky Solar Radiation	RadAvg	0	8	269	1035	1679	1872	1518	902	317	0	0	0	0
	RadStd	0	1	24	93	141	176	150	95	29	0	0	0	0

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)		+2.74	+8.33	+7.38	N/A	N/A	N/A	-994	-988	N/A	N/A

Nomenclature: See separate page