

ANDOYA, Norway

WMO: 010100

Lat: 69.293N

Lon: 16.144E

Elev: 43

StdP: 14.67

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	14.5	17.3	4.9	7.1	17.6	7.4	8.1	19.2	41.2	35.1	37.6	35.5	9.9	180	0.833

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.7	66.2	57.5	62.7	56.0	59.9	54.6	58.7	64.5	56.8	61.5	55.1	59.2	8.9	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
55.8	66.3	61.5	54.0	62.1	59.3	52.5	58.7	57.6	25.6	64.7	24.3	61.5	23.3	59.4	69.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 34.1	29.9	26.6	DB	10.2	71.9	2.2	4.1	8.6	74.8	7.3	77.2	6.1	79.4	4.5	82.4	(4)
(5)			WB	8.9	61.9	2.0	2.9	7.5	64.0	6.3	65.7	5.2	67.4	3.7	69.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	39.5	29.8	28.8	30.3	35.1	42.3	47.6	52.7	52.3	47.6	40.4	34.7	31.9
	DBStd	10.08	6.17	6.24	5.73	5.35	5.23	4.42	4.58	4.36	4.65	5.48	5.61	6.19
	HDD50	4083	628	592	611	448	246	98	19	23	98	300	459	561
	HDD65	9299	1093	1012	1076	897	703	521	384	394	521	763	909	1026
	CDD50	261	0	0	0	0	8	28	102	94	27	2	0	0
	CDD65	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDH74	4	0	0	0	0	0	1	3	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	12.9	15.5	15.5	14.9	12.2	11.9	11.6	10.0	10.1	11.2	13.0	13.7	15.3
Precipitation	PrecAvg	41.5	4.3	3.9	4.2	2.7	2.4	1.8	2.1	2.6	4.2	5.3	4.0	4.1
	PrecMax	53.5	8.6	7.2	8.0	5.4	5.8	4.8	5.3	9.2	8.1	10.0	8.7	9.0
	PrecMin	28.0	0.0	1.6	1.3	0.7	0.6	0.2	0.0	0.6	1.8	1.3	0.4	0.0
	PrecStd	5.8	2.0	1.4	1.8	1.0	1.3	1.0	1.5	1.7	1.8	2.1	2.4	2.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.8	44.3	44.1	53.8	63.9	67.6	71.9	69.9	61.8	55.0	49.5	46.4
		MCWB	42.0	41.3	40.0	45.1	51.8	55.0	61.5	60.3	54.4	49.4	46.4	43.7
	2%	DB	42.2	41.7	41.8	48.4	57.3	62.2	67.1	64.8	58.7	52.2	47.0	44.3
		MCWB	39.1	38.7	38.4	42.8	48.6	53.2	59.1	57.5	53.3	48.1	44.0	41.5
	5%	DB	39.8	39.5	39.8	45.0	53.4	57.4	63.1	61.8	56.3	50.2	44.8	42.0
		MCWB	36.8	36.7	36.4	40.9	46.5	51.3	57.0	56.2	52.0	46.7	41.5	38.8
	10%	DB	37.8	37.4	38.0	42.7	49.9	54.0	60.0	59.2	54.5	48.4	42.8	40.0
		MCWB	34.8	34.6	34.9	38.8	44.6	49.7	55.2	54.9	50.7	45.2	39.6	36.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.5	41.9	40.8	45.9	52.7	56.5	63.0	61.2	56.1	50.3	46.8	44.2
		MCDB	44.4	43.8	43.3	51.1	62.1	65.2	70.4	66.5	60.0	53.6	49.0	45.8
	2%	WB	39.4	38.9	38.7	43.4	49.5	53.8	59.7	58.3	54.1	48.8	44.4	41.4
		MCDB	41.5	41.5	41.3	47.6	56.5	60.2	66.0	63.6	57.5	51.7	46.6	43.9
	5%	WB	37.1	36.9	36.8	41.2	47.0	51.9	57.5	56.7	52.7	47.1	42.0	39.1
		MCDB	39.5	39.2	39.3	44.7	52.0	57.1	62.4	61.2	55.9	49.9	44.5	41.5
	10%	WB	35.2	34.9	35.2	39.1	45.1	50.2	55.5	55.1	51.3	45.4	39.8	37.1
		MCDB	37.5	37.1	37.6	42.3	49.1	53.9	59.7	58.9	54.3	48.2	42.3	39.5
Mean Daily Temperature Range	5% DB	MDBR	7.7	7.8	8.0	8.7	8.9	7.3	7.7	8.1	8.3	7.2	7.1	7.3
		MCDBR	7.7	8.1	7.7	11.6	14.8	13.7	14.7	13.4	10.8	8.0	8.0	7.7
		MCWBR	7.1	7.4	6.4	7.9	8.6	7.6	9.0	8.3	7.4	6.6	7.1	7.3
	5% WB	MCDBR	7.6	8.2	7.5	11.1	12.9	12.1	13.7	12.0	9.7	7.7	7.9	7.7
		MCWBR	7.2	7.9	6.6	8.0	8.0	7.5	8.9	7.9	7.1	6.8	7.4	7.7
Clear-Sky Solar Irradiance	taub	0.372	0.283	0.324	0.344	0.350	0.348	0.352	0.342	0.326	0.285	0.351	N/A	
	taud	2.545	2.125	2.236	2.347	2.437	2.485	2.505	2.518	2.502	2.224	2.542	N/A	
	Ebn at Noon	16	143	216	252	266	270	264	253	224	141	14	0	
	Edh at Noon	3	13	23	28	29	29	27	24	19	12	2	0	
All-Sky Solar Radiation	RadAvg	4	84	395	942	1436	1570	1392	992	525	165	16	0	
	RadStd	1	17	56	92	107	204	136	82	51	27	2	0	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.86	+1.13	+2.14	N/A	N/A	N/A	-268	-302	N/A	N/A
(47) Regional (21 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page