

AKSELOYA, Svalbard and Jan Mayen

WMO: 010170

Lat: 77.689N

Lon: 14.784E

Elev: 6

StdP: 101.25

Time Zone: 1.00 (EUC)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	-24.5	-21.6	N/A	N/A	N/A	N/A	N/A	N/A	18.9	-6.4	17.5	-5.3	4.7	60	1.001

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	2.7	9.7	N/A	8.8	N/A	8.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	5.9	190

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		Extreme Max WB	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)	(r)
16.6	14.6	12.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-2.2	-7.0	-7.7	-10.1	-7.6	-1.7	3.2	6.0	5.6	3.5	-0.5	-4.0	-6.2
	DBStd	7.04	6.45	7.16	6.39	5.03	2.92	1.59	1.36	1.72	2.35	3.58	4.44	5.12
	HDD10.0	4448	528	496	624	528	362	204	126	136	195	327	419	503
	HDD18.3	7490	786	729	883	778	621	454	384	394	445	585	669	762
	CDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	6.0	7.3	7.3	6.6	5.8	5.6	4.3	4.6	4.6	5.5	6.0	7.2	7.7
Precipitation	PrecAvg	520	59	49	48	31	23	17	30	40	57	51	59	57
	PrecMax	727	153	110	112	82	52	44	65	93	110	104	190	114
	PrecMin	323	10	10	15	10	7	4	4	15	16	19	16	15
	PrecStd	104	38	29	26	16	11	10	15	16	24	22	33	26
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.1	4.9	3.8	3.3	5.5	8.4	10.9	11.8	9.9	7.6	5.6	5.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	2.7	3.4	2.3	1.5	3.7	7.2	9.5	10.1	8.8	6.4	4.2	2.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	1.4	2.2	0.7	0.5	2.7	6.2	8.6	9.0	7.6	5.6	3.2	1.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	0.1	0.5	-1.4	-0.8	1.9	5.4	7.9	8.0	6.5	4.4	1.7	0.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	3.8	4.3	4.4	4.2	3.0	2.5	2.7	2.7	2.7	2.7	3.3	3.7
		MCDBR	4.9	5.1	5.6	4.5	3.5	3.6	3.9	3.8	4.2	4.0	4.3	4.6
	5% WB	MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	N/A	0.196	0.256	0.286	0.303	0.296	0.302	0.291	0.249	N/A	N/A	N/A	N/A
	taud	N/A	1.906	2.084	2.228	2.268	2.384	2.447	2.447	2.369	N/A	N/A	N/A	N/A
	Ebn at Noon	0	51	565	771	827	858	835	778	630	N/A	0	0	0
	Edh at Noon	0	6	52	80	93	88	79	65	40	N/A	0	0	0
All-Sky Solar Radiation	RadAvg	0.00	0.03	0.77	2.66	4.38	5.26	4.30	2.79	1.06	0.13	0.00	0.00	0.00
	RadStd	0.00	0.00	0.09	0.34	0.33	0.38	0.35	0.25	0.10	0.01	0.00	0.00	0.00

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (5 neighbors)	+1.52	+4.63	+4.10	N/A	N/A	N/A	-552	-549	N/A	N/A

Nomenclature: See separate page