

KARASJOK, Norway

WMO: 010650

Lat: 69.4636N

Lon: 25.5026E

Elev: 436

StdP: 14.47

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-34.1	-28.8	-40.4	0.5	-33.8	-34.5	0.8	-28.4	18.5	26.4	16.3	25.6	1.7	220	0.744

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 16.7	(c) 74.3	(d) 59.4	(e) 70.3	(f) 57.9	(g) 66.5	(h) 56.2	(i) 61.7	(j) 70.3	(k) 59.4	(l) 67.0	(m) 57.4	(n) 64.3	(o) 6.8	(p) 200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
58.0	72.9	64.6	55.7	67.1	62.3	53.9	62.8	60.8	27.8	70.4	26.2	66.9	24.9	64.5	
				</											

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 16.1	(b) 13.9	(c) 12.0	(e) -39.6	(f) 80.8	(g) 4.4	(h) 3.8	(i) -42.8	(j) 83.5	(k) -45.4	(l) 85.7	(m) -47.9	(n) 87.8	(o) -51.1	(p) 90.6		
(4) 16.1	(5) 13.9	(6) 12.0	(7) -39.6	(8) 80.8	(9) 4.4	(10) 3.8	(11) -42.8	(12) 83.5	(13) -45.4	(14) 85.7	(15) -47.9	(16) 87.8	(17) -51.1	(18) 90.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	29.4	4.3	5.2	15.8	28.8	40.1	49.1	55.0	51.6	44.0	30.4	16.6	10.8
	DBStd	20.95	16.96	16.77	12.48	8.65	6.94	6.61	6.13	6.17	6.23	9.33	13.19	15.70
	HDD50	7874	1417	1253	1060	635	316	95	19	56	197	609	1001	1216
	HDD65	12982	1882	1673	1525	1085	771	478	314	417	631	1074	1451	1681
	CDD50	373	0	0	0	0	11	68	173	105	16	0	0	0
	CDD65	6	0	0	0	0	0	1	4	1	0	0	0	0
	CDH74	114	0	0	0	0	2	14	71	27	0	0	0	0
	CDH80	10	0	0	0	0	0	1	6	3	0	0	0	0
Wind	WSAvg	5.1	4.1	4.4	5.6	6.0	6.7	6.4	5.6	4.6	4.8	4.4	3.9	4.3
Precipitation	PrecAvg	14.3	0.7	0.5	0.6	0.6	0.9	1.7	2.8	2.2	1.6	1.3	0.9	0.7
	PrecMax	20.2	1.7	1.2	1.3	1.2	3.1	3.7	5.6	4.1	3.8	3.7	1.9	1.4
	PrecMin	9.9	0.1	0.1	0.1	0.1	0.1	0.7	0.8	0.9	0.3	0.2	0.2	0.1
	PrecStd	2.7	0.4	0.3	0.3	0.3	0.7	0.7	1.2	0.8	0.8	0.8	0.4	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.8	38.5	42.2	51.9	71.7	75.5	80.5	77.6	65.3	51.8	40.0	40.4
		MCWB	33.9	35.3	35.9	42.0	54.6	57.5	62.9	62.5	55.3	47.6	37.2	36.6
	2%	DB	33.9	35.0	38.0	46.7	64.5	69.9	75.3	72.7	61.4	48.0	36.6	36.4
		MCWB	31.7	32.3	33.6	39.8	50.1	54.9	60.2	59.8	53.7	44.8	34.6	33.8
	5%	DB	30.8	31.8	35.5	43.2	57.8	65.2	71.1	68.2	58.0	44.7	34.9	33.9
		MCWB	29.2	29.6	31.7	37.1	47.0	53.8	58.9	57.8	51.6	42.3	33.3	31.8
	10%	DB	27.4	28.7	33.3	40.4	52.7	61.3	67.3	64.0	54.8	41.9	33.0	31.7
		MCWB	25.9	26.9	30.1	35.4	44.0	51.9	57.7	56.7	49.9	39.8	31.7	30.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	34.2	36.1	36.4	42.5	55.5	59.9	64.5	64.9	58.1	47.9	37.3	36.9
		MCDB	36.4	37.9	41.1	49.6	70.7	67.0	75.8	74.3	62.9	51.0	39.3	40.0
	2%	WB	31.6	32.2	34.0	39.7	50.4	57.0	62.3	61.5	54.4	45.1	35.1	34.1
		MCDB	33.5	34.9	37.4	46.1	62.4	62.9	71.8	69.4	59.3	47.8	36.4	36.1
	5%	WB	29.2	29.6	32.1	37.6	47.4	54.9	60.3	58.6	52.0	42.2	33.4	31.9
		MCDB	30.8	31.8	35.2	42.5	56.4	62.7	68.8	65.9	56.5	44.4	34.7	33.7
	10%	WB	25.9	27.0	30.1	35.8	44.9	52.4	58.3	56.8	50.0	39.9	31.7	29.9
		MCDB	27.3	28.7	33.1	39.6	51.8	60.1	65.5	63.5	53.7	41.8	32.9	31.6
Mean Daily Temperature Range	5% DB	MDBR	18.3	18.9	23.0	17.5	15.7	15.1	16.7	18.6	16.0	12.1	14.7	18.1
		MCDBR	17.1	17.0	16.5	17.3	26.4	22.1	24.7	26.8	21.6	13.3	11.8	14.2
		MCWBR	16.0	15.2	13.3	11.5	14.3	10.9	12.0	15.6	14.1	10.9	10.8	12.4
	5% WB	MCDBR	17.3	15.9	15.6	16.2	23.8	18.8	21.1	23.0	18.4	12.7	11.1	13.1
		MCWBR	16.1	14.2	12.7	11.0	13.5	10.6	11.2	13.8	12.5	10.7	10.3	12.0
Clear-Sky Solar Irradiance	taub	0.195	0.244	0.289	0.318	0.339	0.340	0.350	0.333	0.301	0.257	N/A	N/A	
	taud	1.909	2.048	2.135	2.180	2.342	2.465	2.459	2.487	2.537	2.232	N/A	N/A	
	Ebn at Noon	8	155	226	257	268	272	264	256	234	154	N/A	0	
	Edh at Noon	1	14	25	33	32	29	28	24	17	11	N/A	0	
All-Sky Solar Radiation	RadAvg	4	120	573	1205	1546	1532	1402	978	508	156	18	0	
	RadStd	0	11	31	53	142	127	146	90	45	19	2	0	

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (33 neighbors)		+0.81	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page