

KARASJOK, Norway

WMO: 010650

Lat: 69.4636N

Lon: 25.5026E

Elev: 133

StdP: 99.74

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-36.7	-33.8	-40.2	0.1	-36.6	-36.9	0.1	-33.6	8.3	-3.1	7.3	-3.5	0.8	220	0.744

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.3	23.5	15.2	21.3	14.4	19.2	13.5	16.5	21.3	15.2	19.5	14.1	18.0	3.0	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
14.4	10.4	18.1	13.2	9.6	16.9	12.2	9.0	16.0	46.8	21.3	43.0	19.4	40.0	18.1	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.2	6.2	5.4	-39.8	27.1	2.5	2.1	-41.6	28.6	-43.0	29.8	-44.4	31.0	-46.2	32.5		
			-39.8	18.1	2.5	1.5	-41.6	19.2	-43.1	20.1	-44.5	20.9	-46.4	22.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-1.4	-15.4	-14.9	-9.0	-1.8	4.5	9.5	12.8	10.9	6.7	-0.9	-8.5	-11.8	(6)
(7)		DBStd	11.64	9.42	9.31	6.93	4.81	3.86	3.67	3.41	3.43	3.46	5.18	7.33	8.72	(7)
(8)		HDD10.0	4374	787	696	589	353	176	53	11	31	109	338	556	676	(8)
(9)		HDD18.3	7212	1046	929	847	603	428	266	174	232	351	597	806	934	(9)
(10)		CDD10.0	207	0	0	0	0	6	38	96	58	9	0	0	0	(10)
(11)		CDD18.3	3	0	0	0	0	0	1	2	1	0	0	0	0	(11)
(12)		CDH23.3	63	0	0	0	0	1	8	39	15	0	0	0	0	(12)
(13)		CDH26.7	6	0	0	0	0	0	1	3	2	0	0	0	0	(13)
(14)	Wind	WSAvg	2.3	1.8	2.0	2.5	2.7	3.0	2.8	2.5	2.1	2.1	2.0	1.7	1.9	(14)
(15)	Precipitation	PrecAvg	362	18	12	14	15	23	42	71	57	40	32	22	17	(15)
(16)		PrecMax	512	42	30	33	30	78	95	141	105	96	95	49	36	(16)
(17)		PrecMin	251	3	3	2	3	2	17	20	24	7	4	6	3	(17)
(18)		PrecStd	69	9	7	8	8	17	18	31	21	21	20	10	9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.7	3.6	5.7	11.0	22.1	24.2	26.9	25.3	18.5	11.0	4.5	4.7	(19)
(20)		0.4%	MCWB	1.1	1.8	2.2	5.5	12.6	14.2	17.1	17.0	13.0	8.7	2.9	2.5	(20)
(21)		2%	DB	1.1	1.6	3.3	8.2	18.1	21.1	24.0	22.6	16.4	8.9	2.6	2.4	(21)
(22)		2%	MCWB	-0.2	0.2	0.9	4.3	10.1	12.7	15.7	15.4	12.0	7.1	1.4	1.0	(22)
(23)		5%	DB	-0.7	-0.1	1.9	6.2	14.3	18.4	21.7	20.1	14.4	7.1	1.6	1.1	(23)
(24)		5%	MCWB	-1.6	-1.3	-0.2	2.8	8.3	12.1	14.9	14.4	10.9	5.7	0.7	-0.1	(24)
(25)		10%	DB	-2.6	-1.9	0.7	4.7	11.5	16.3	19.6	17.8	12.7	5.5	0.6	-0.2	(25)
(26)		10%	MCWB	-3.4	-2.9	-1.0	1.9	6.7	11.1	14.3	13.7	9.9	4.3	-0.2	-1.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.2	2.3	2.4	5.8	13.0	15.5	18.1	18.3	14.5	8.8	2.9	2.7	(27)
(28)		0.4%	MCDWB	2.4	3.3	5.0	9.8	21.5	19.4	24.4	23.5	17.2	10.5	4.1	4.5	(28)
(29)		2%	WB	-0.2	0.1	1.1	4.3	10.2	13.9	16.8	16.4	12.5	7.3	1.7	1.2	(29)
(30)		2%	MCDWB	0.8	1.6	3.0	7.8	16.9	17.2	22.1	20.8	15.2	8.8	2.5	2.3	(30)
(31)		5%	WB	-1.5	-1.4	0.1	3.1	8.5	12.7	15.7	14.8	11.1	5.7	0.8	0.0	(31)
(32)		5%	MCDWB	-0.6	-0.1	1.8	5.8	13.5	17.1	20.5	18.8	13.6	6.9	1.5	0.9	(32)
(33)		10%	WB	-3.4	-2.8	-1.0	2.1	7.1	11.3	14.6	13.8	10.0	4.4	-0.2	-1.1	(33)
(34)		10%	MCDWB	-2.6	-1.8	0.6	4.2	11.0	15.6	18.6	17.5	12.0	5.4	0.5	-0.2	(34)
(35)	Mean Daily Temperature Range		MDBR	10.1	10.5	12.8	9.7	8.7	8.4	9.3	10.4	8.9	6.7	8.2	10.0	(35)
(36)		5% DB	MCDDBR	9.5	9.5	9.2	9.6	14.7	12.3	13.7	14.9	12.0	7.4	6.6	7.9	(36)
(37)			MCWBR	8.9	8.5	7.4	6.4	8.0	6.1	6.6	8.7	7.8	6.0	6.0	6.9	(37)
(38)			MCDDBR	9.6	8.8	8.7	9.0	13.2	10.4	11.7	12.8	10.2	7.1	6.2	7.3	(38)
(39)		5% WB	MCWBR	8.9	7.9	7.1	6.1	7.5	5.9	6.2	7.6	6.9	5.9	5.7	6.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.195	0.244	0.289	0.318	0.339	0.340	0.350	0.333	0.301	0.257	N/A	N/A	(40)	
(41)		taud	1.909	2.048	2.135	2.180	2.342	2.465	2.459	2.487	2.537	2.232	N/A	N/A	(41)	
(42)		Ebn at Noon	24	490	713	811	844	857	832	806	739	484	N/A	0	(42)	
(43)		Edh at Noon	4	43	78	103	100	92	89	77	55	35	N/A	0	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.01	0.38	1.80	3.80	4.88	4.83	4.42	3.08	1.60	0.49	0.06	0.00	(44)	
(45)		RadStd	0.00	0.03	0.10	0.17	0.45	0.40	0.46	0.28	0.14	0.06	0.01	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (33 neighbors)	+0.45	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page