

SLETTNES FYR, Norway

WMO: 010780

Lat: 71.089N

Lon: 28.217E

Elev: 33

StdP: 14.68

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	9.5	12.9	-8.6	3.5	15.1	3.7	6.7	12.5	50.0	29.4	45.1	28.9	16.4	210	0.943

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.4	65.0	57.0	60.3	54.4	56.7	52.2	57.6	63.8	54.9	59.6	52.7	56.1	12.3	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
54.4	62.9	61.0	52.0	57.7	57.3	50.3	54.1	54.5	24.9	64.0	23.2	59.8	21.8	56.2	67.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
40.4	35.3	31.6	5.3	72.7	4.3	4.5	2.1	75.9	-0.4	78.5	-2.9	81.0	-6.0	84.3
			3.6	62.3	3.8	3.0	0.9	64.4	-1.4	66.2	-3.5	67.9	-6.3	70.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	36.5	26.0	24.8	27.3	32.1	38.5	44.1	49.6	49.7	45.8	38.3	31.7	29.1
	DBStd	10.31	6.59	6.65	5.27	5.26	5.12	4.64	4.99	4.52	4.74	5.36	5.11	5.80
	HDD50	5070	745	707	703	538	359	189	66	59	142	365	549	648
	HDD65	10408	1210	1127	1168	988	821	627	477	474	575	829	999	1113
	CDD50	138	0	0	0	0	3	12	54	50	18	1	0	0
	CDD65	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDH74	10	0	0	0	0	0	0	9	1	0	0	0	0
	CDH80	2	0	0	0	0	0	0	2	0	0	0	0	0
Wind	WSAvg	15.4	17.7	17.8	18.1	15.6	14.3	13.5	12.3	12.2	14.2	15.5	15.9	18.2
Precipitation	PrecAvg	27.5	2.4	2.4	2.6	1.8	1.5	2.0	2.0	2.0	2.5	3.2	2.4	2.8
	PrecMax	41.0	4.4	6.2	6.0	3.4	3.2	4.0	5.3	6.1	3.8	6.0	5.9	4.9
	PrecMin	20.7	0.8	0.7	1.3	0.7	0.4	0.2	0.2	0.6	1.0	1.3	0.7	1.2
	PrecStd	5.2	1.1	1.3	1.2	0.7	0.6	0.9	1.5	1.2	0.8	1.0	1.1	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.7	40.1	41.4	48.1	58.5	66.5	73.3	69.8	62.7	53.6	45.9	43.6
		MCWB	39.3	37.4	37.9	42.0	48.2	55.3	60.9	59.6	55.1	48.9	43.3	41.1
	2%	DB	38.9	38.3	38.9	43.9	52.6	58.1	66.3	63.7	58.2	49.9	43.1	40.8
		MCWB	36.5	35.9	35.3	39.8	45.7	52.6	57.9	56.9	52.7	46.2	40.7	38.5
	5%	DB	36.9	36.3	36.6	40.9	48.5	52.6	60.4	59.3	55.0	47.4	40.4	38.7
		MCWB	34.4	34.0	33.8	37.6	43.5	48.0	55.1	54.0	50.9	44.6	38.0	36.2
	10%	DB	35.1	34.2	35.0	39.0	45.6	49.4	55.9	55.9	52.4	45.6	38.5	36.7
		MCWB	32.9	31.9	32.5	36.5	42.0	46.2	52.4	52.1	49.0	43.2	36.2	34.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	40.1	38.6	38.8	42.9	49.4	58.1	62.8	61.2	56.4	49.1	43.6	41.5
		MCDB	41.7	39.6	40.9	46.6	57.9	64.1	71.6	67.9	61.5	53.2	45.4	43.1
	2%	WB	37.0	36.2	36.2	40.2	46.5	52.8	58.3	57.2	53.2	46.5	40.8	39.1
		MCDB	38.7	38.0	38.2	43.4	52.2	58.3	65.0	62.8	57.2	49.1	42.9	40.8
	5%	WB	34.9	34.4	34.5	38.2	44.0	48.6	55.1	54.6	51.1	45.0	38.3	36.6
		MCDB	36.7	36.2	36.4	40.5	47.6	51.5	60.3	58.6	54.4	47.1	40.3	38.5
	10%	WB	33.0	32.2	32.8	36.8	42.3	46.6	52.5	52.5	49.4	43.3	36.5	34.6
		MCDB	35.0	34.0	34.6	38.8	45.2	49.0	55.7	55.4	52.0	45.5	38.4	36.5
Mean Daily Temperature Range	5% DB	MDBR	7.9	7.9	6.9	6.4	6.2	5.7	6.6	6.4	6.3	5.9	6.8	7.3
		MCDBR	8.2	8.4	7.6	7.5	11.8	13.1	16.6	13.8	10.3	6.6	6.7	7.8
		MCWBR	7.9	8.0	6.7	5.7	7.5	8.4	10.0	8.8	7.0	5.5	6.4	7.4
	5% WB	MCDBR	8.0	8.1	7.4	6.7	10.4	12.2	15.5	12.9	9.5	6.2	6.7	7.9
		MCWBR	8.0	8.0	6.9	5.6	7.2	8.4	9.8	8.8	6.9	5.6	6.5	7.8
Clear-Sky Solar Irradiance	taub	N/A	0.262	0.317	0.336	0.348	0.338	0.353	0.340	0.314	0.261	N/A	N/A	
	taud	N/A	2.060	2.193	2.306	2.402	2.498	2.492	2.506	2.506	2.138	N/A	N/A	
	Ebn at Noon	0	124	207	249	263	271	261	249	220	121	0	0	
	Edh at Noon	0	11	23	28	30	28	27	23	17	10	0	0	
All-Sky Solar Radiation	RadAvg	0	60	355	862	1274	1479	1307	896	467	116	0	0	
	RadStd	0	7	30	60	146	120	123	90	47	14	0	0	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only			+0.74	+2.43	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)			+0.83	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page