

SLETTNES FYR, Norway

WMO: 010780

Lat: 71.089N

Lon: 28.217E

Elev: 10

StdP: 101.20

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-12.5	-10.6	-22.6	0.5	-9.4	-15.7	1.0	-10.8	22.3	-1.4	20.1	-1.7	7.3	210	0.943

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.6	18.3	13.9	15.7	12.4	13.7	11.2	14.2	17.7	12.7	15.3	11.5	13.4	5.5	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.4	9.0	16.1	11.1	8.2	14.0	10.2	7.7	12.5	40.0	17.8	36.0	15.4	32.9	13.4	19.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.1	15.8	14.1	DB	-14.9	22.6	2.4	2.5	-16.6	24.4	-18.0	25.9	-19.4	27.2	-21.1	29.0	(4)
(5)			WB	-15.8	16.8	2.1	1.7	-17.3	18.0	-18.5	19.0	-19.7	19.9	-21.3	21.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	2.5	-3.3	-4.0	-2.6	0.0	3.6	6.7	9.8	9.8	7.7	3.5	-0.2	-1.6	(6)	
	DBStd	5.73	3.66	3.70	2.93	2.92	2.85	2.58	2.77	2.51	2.64	2.98	2.84	3.22	(7)	
	HDD10.0	2817	414	393	391	299	199	105	37	33	79	203	305	360	(8)	
	HDD18.3	5782	672	626	649	549	456	348	265	263	319	461	555	618	(9)	
	CDD10.0	77	0	0	0	0	2	7	30	28	10	1	0	0	(10)	
	CDD18.3	1	0	0	0	0	0	0	1	0	0	0	0	0	(11)	
	CDH23.3	6	0	0	0	0	0	0	5	1	0	0	0	0	(12)	
	CDH26.7	1	0	0	0	0	0	0	1	0	0	0	0	0	(13)	
(14) Wind	WSAvg	6.9	7.9	8.0	8.1	7.0	6.4	6.0	5.5	5.4	6.3	6.9	7.1	8.1	(14)	
(15) Precipitation	PrecAvg	698	60	62	66	46	39	51	51	50	64	82	61	70	(15)	
	PrecMax	1042	112	158	153	86	81	102	134	155	96	152	149	124	(16)	
	PrecMin	526	20	17	33	17	9	4	4	16	25	33	18	31	(17)	
	PrecStd	133	28	33	30	19	16	24	39	31	20	25	27	25	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.4	4.5	5.2	9.0	14.7	19.2	23.0	21.0	17.1	12.0	7.7	6.4	(19)	
		MCWB	4.0	3.0	3.3	5.5	9.0	13.0	16.1	15.3	12.9	9.4	6.3	5.1	(20)	
	2%	DB	3.8	3.5	3.8	6.6	11.5	14.5	19.0	17.6	14.6	10.0	6.2	4.9	(21)	
		MCWB	2.5	2.2	1.8	4.3	7.6	11.4	14.4	13.8	11.5	7.9	4.8	3.6	(22)	
	5%	DB	2.7	2.4	2.6	4.9	9.2	11.4	15.8	15.2	12.8	8.6	4.7	3.7	(23)	
		MCWB	1.4	1.1	1.0	3.1	6.4	8.9	12.8	12.2	10.5	7.0	3.3	2.4	(24)	
	10%	DB	1.7	1.2	1.7	3.9	7.6	9.6	13.3	13.3	11.3	7.5	3.6	2.6	(25)	
		MCWB	0.5	0.0	0.3	2.5	5.6	7.9	11.3	11.2	9.4	6.2	2.3	1.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.5	3.7	3.8	6.1	9.7	14.5	17.1	16.2	13.5	9.5	6.4	5.3	(27)	
		MCDB	5.4	4.2	4.9	8.1	14.4	17.8	22.0	19.9	16.4	11.8	7.5	6.2	(28)	
	2%	WB	2.8	2.4	2.3	4.6	8.0	11.6	14.6	14.0	11.8	8.1	4.9	3.9	(29)	
		MCDB	3.7	3.3	3.4	6.4	11.2	14.6	18.4	17.1	14.0	9.5	6.0	4.9	(30)	
	5%	WB	1.6	1.3	1.4	3.4	6.7	9.2	12.9	12.6	10.6	7.2	3.5	2.5	(31)	
		MCDB	2.6	2.3	2.4	4.7	8.7	10.9	15.7	14.8	12.5	8.4	4.6	3.6	(32)	
	10%	WB	0.6	0.1	0.4	2.7	5.7	8.1	11.4	11.4	9.6	6.3	2.5	1.4	(33)	
		MCDB	1.7	1.1	1.4	3.8	7.4	9.5	13.2	13.0	11.1	7.5	3.6	2.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.4	4.4	3.8	3.5	3.5	3.2	3.7	3.6	3.5	3.3	3.8	4.1	(35)	
		MCDBR	4.6	4.7	4.2	4.1	6.5	7.3	9.2	7.7	5.7	3.7	3.7	4.4	(36)	
	5% WB	MCWBR	4.4	4.4	3.7	3.2	4.2	4.7	5.6	4.9	3.9	3.0	3.6	4.1	(37)	
		MCWBR	4.5	4.5	4.1	3.7	5.8	6.8	8.6	7.2	5.3	3.4	3.7	4.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		N/A	0.262	0.317	0.336	0.348	0.338	0.353	0.340	0.314	0.261	N/A	N/A	(40)	
		taud	N/A	2.060	2.193	2.306	2.402	2.498	2.492	2.506	2.506	2.138	N/A	N/A	(41)	
	Ebn at Noon		0	391	653	785	828	853	822	786	694	383	0	0	(42)	
		Edh at Noon	0	36	71	89	93	87	85	74	54	31	0	0	(43)	
(44) All-Sky Solar Radiation	RadAvg	0.00	0.19	1.12	2.72	4.02	4.66	4.12	2.83	1.47	0.37	0.00	0.00	0.00	(44)	
	RadStd	0.00	0.02	0.10	0.19	0.46	0.38	0.39	0.28	0.15	0.04	0.00	0.00	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.41	+1.35	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)		+0.46	N/A	N/A	N/A	N/A	N/A	-131	N/A	N/A	N/A

Nomenclature: See separate page