

HEIMDAL OIL PLATFORM, Norway

WMO: 010875

Lat: 59.567N

Lon: 2.217E

Elev: 295

StdP: 14.54

Time Zone: 1.00 (EUC)

Period: 11-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	32.3	34.0	17.3	13.3	34.4	20.9	15.9	36.7	68.2	37.4	63.8	38.7	21.9	130	1.025

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.0	64.8	59.8	62.6	59.0	60.8	58.1	61.1	63.9	59.8	62.0	58.8	60.6	15.5	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.6	77.0	61.6	59.0	75.3	60.8	57.5	71.4	59.6	27.3	63.6	26.3	61.8	25.7	60.1	67.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 56.1	49.9	44.5	DB	29.8	69.6	3.5	4.1	27.3	72.6	25.3	75.0	23.3	77.3	20.8	80.3	(4)
(5)			WB	26.8	62.9	3.8	2.5	24.0	64.6	21.8	66.1	19.7	67.5	16.9	69.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.9	41.1	40.8	41.6	43.8	47.4	51.9	56.1	57.3	54.5	50.2	46.0	43.5		
	DBStd	6.62	3.24	3.26	3.43	3.42	4.04	2.91	3.77	2.58	2.82	2.93	3.12	3.36		
	HDD50	1453	276	257	262	188	100	12	0	0	2	31	123	202		
	HDD65	6244	741	677	727	636	545	392	278	239	314	458	571	666		
	CDD50	687	0	0	0	2	21	70	190	226	138	38	2	0		
	CDD65	3	0	0	0	0	0	0	3	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	21.9	28.4	26.7	22.4	19.7	19.0	17.2	16.6	17.6	20.7	23.2	24.1	27.9		
	PrecAvg	49.4	5.9	5.0	4.6	2.5	1.9	2.5	3.0	3.6	4.4	5.0	5.3	5.7		
(15) Precipitation	PrecMax	61.4	8.5	10.4	8.2	4.1	3.6	4.1	5.3	9.1	6.5	8.8	7.2	11.4		
	PrecMin	38.0	2.4	2.4	2.2	1.7	0.8	1.1	1.3	1.5	1.6	1.9	2.5	2.9		
	PrecStd	6.0	1.9	1.9	1.5	0.7	0.6	0.7	0.9	1.3	1.3	1.6	1.3	1.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.5	48.3	51.4	55.5	64.8	62.8	71.5	66.1	63.0	57.6	52.8	51.5		
		MCWB	47.4	46.8	45.8	48.4	56.7	56.9	64.3	58.4	58.4	53.2	50.7	49.3		
	2%	DB	48.0	46.7	48.0	51.9	58.9	58.8	66.7	63.7	60.6	56.3	52.0	50.0		
		MCWB	46.9	45.7	45.6	46.9	53.6	54.8	61.8	59.0	57.6	53.0	50.0	48.9		
	5%	DB	46.7	46.3	46.6	49.7	55.2	56.9	63.2	62.2	59.2	55.0	51.3	48.6		
		MCWB	45.4	45.3	44.9	46.1	50.3	53.7	60.1	58.9	57.0	52.2	49.5	47.5		
	10%	DB	46.1	44.9	45.9	48.0	52.0	55.4	61.0	60.7	58.0	53.7	50.3	48.1		
		MCWB	44.8	43.6	44.3	45.4	49.1	53.3	58.6	58.3	56.0	51.0	48.6	47.0		
	0.4%	WB	48.1	47.0	47.3	49.0	57.8	57.7	64.9	62.1	60.0	55.8	52.1	50.2		
		MCDB	48.1	47.1	48.3	52.4	64.3	61.2	69.1	63.5	61.5	56.7	52.3	50.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	46.7	45.8	46.1	47.7	53.7	55.6	62.3	60.3	58.9	54.2	51.0	49.0		
		MCDB	47.1	46.1	47.1	50.4	57.9	57.6	66.1	61.8	60.1	55.5	51.4	49.3		
	5%	WB	45.7	45.0	45.1	46.6	51.3	54.7	60.5	59.4	57.7	53.1	50.0	48.0		
		MCDB	46.3	45.5	45.9	48.3	53.9	56.4	63.3	61.1	58.9	54.4	50.6	48.4		
	10%	WB	44.5	44.0	44.3	45.7	49.8	53.8	59.1	58.7	56.7	52.0	49.0	46.9		
		MCDB	45.4	44.7	45.1	47.1	51.4	55.4	61.2	60.4	58.1	53.1	49.9	47.5		
	5% DB	MDBR	4.6	4.4	4.2	4.7	4.7	3.9	4.1	4.0	3.8	4.0	4.1	4.6		
		MCDBR	4.9	5.1	5.0	7.4	10.5	6.8	7.4	6.6	5.2	5.5	4.4	4.8		
		MCWBR	6.2	5.5	4.9	4.5	6.3	4.5	5.0	4.8	4.4	5.0	5.2	6.3		
		MCWBR	4.7	4.5	4.0	5.5	8.8	6.0	6.8	4.9	4.6	4.9	4.1	4.6		
(35) Mean Daily Temperature Range	5% WB	MCWBR	6.4	5.5	4.9	4.3	6.1	4.7	4.9	4.7	4.7	5.5	5.5	6.3		
(40) Clear-Sky Solar Irradiance	taub		0.331	0.348	0.363	0.378	0.366	0.363	0.378	0.374	0.363	0.347	0.323	0.434		
	taud		2.110	2.237	2.301	2.320	2.425	2.467	2.440	2.450	2.448	2.335	2.174	2.566		
	Ebn at Noon		133	203	242	260	274	276	268	260	243	203	136	98		
	Edh at Noon		16	23	29	34	33	32	32	30	25	21	14	11		
(44) All-Sky Solar Radiation	RadAvg		82	262	653	1212	1652	1670	1535	1215	765	365	122	52		
	RadStd		11	40	61	113	121	167	128	87	54	32	13	4		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (22 neighbors)		N/A	+1.17	N/A	N/A	N/A	N/A	-149	-212	N/A	N/A

Nomenclature: See separate page