

SNORRE A OIL PLATFORM, Norway

WMO: 010878

Lat: 61.450N

Lon: 2.133E

Elev: 90

StdP: 100.25

Time Zone: 1.00 (EUC)

Period: 11-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	0.1	1.1	-8.1	1.9	1.8	-6.2	2.3	2.5	29.7	5.9	27.0	6.1	11.3	0	1.166

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.5	17.9	15.4	16.2	14.3	15.8	14.0	15.6	17.5	14.9	16.3	14.2	15.5	8.6	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.9	10.7	16.4	14.1	10.1	15.7	13.2	9.6	14.8	43.9	17.6	41.9	16.0	40.2	15.3	19.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.7	23.6	21.3	DB	-2.0	20.9	1.4	2.0	-3.0	22.3	-3.8	23.5	-4.6	24.6	-5.7	26.0	(4)
(5)			WB	-3.3	16.7	1.5	1.4	-4.4	17.7	-5.3	18.5	-6.1	19.3	-7.1	20.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.7	5.5	5.4	5.5	6.5	8.3	10.6	13.0	13.6	12.1	9.8	7.7	6.4	(6)	
	DBStd	3.50	1.97	1.86	2.14	2.21	2.14	1.56	2.16	1.48	1.60	1.79	2.17	2.07	(7)	
	HDD10.0	795	140	128	140	106	59	11	1	0	3	24	73	111	(8)	
	HDD18.3	3509	398	361	398	355	310	232	167	146	188	264	320	369	(9)	
	CDD10.0	329	0	0	0	1	7	28	93	113	64	18	3	0	(10)	
	CDD18.3	1	0	0	0	0	0	0	1	0	0	0	0	0	(11)	
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	11.2	13.3	13.5	11.9	10.3	9.7	9.5	8.5	9.2	10.6	11.7	12.5	14.2	(14)	
(15) Precipitation	PrecAvg	1341	161	132	127	72	48	65	81	100	117	141	139	156	(15)	
	PrecMax	1652	252	257	237	123	83	132	153	162	190	216	220	240	(16)	
	PrecMin	954	76	58	46	26	22	26	40	66	48	58	43	65	(17)	
	PrecStd	165	48	53	46	23	16	24	22	25	34	41	39	42	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.0	9.2	10.0	12.2	16.0	15.8	21.2	18.9	16.1	14.0	12.2	10.9	(19)	
		MCWB	8.6	8.2	8.5	8.8	12.9	13.3	16.6	15.0	13.8	11.7	10.6	9.7	(20)	
	2%	DB	9.2	9.1	9.2	11.0	13.1	14.0	19.0	17.2	15.1	13.1	11.2	10.1	(21)	
		MCWB	8.2	8.2	8.1	8.4	10.4	12.1	16.0	14.7	13.3	11.0	9.8	9.3	(22)	
	5%	DB	9.0	8.8	9.0	9.9	11.9	13.1	17.1	16.2	14.8	12.2	11.1	9.9	(23)	
		MCWB	8.1	7.9	7.9	8.2	9.7	11.5	15.1	14.2	13.1	10.4	9.7	9.1	(24)	
	10%	DB	8.2	8.1	8.2	9.1	10.9	12.2	15.9	15.9	14.1	12.0	10.8	9.2	(25)	
		MCWB	7.1	7.0	6.9	7.9	9.2	10.9	14.3	14.0	12.8	10.3	9.5	8.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.1	8.7	9.0	9.7	12.9	13.4	17.2	15.7	14.6	12.6	11.4	10.1	(27)	
		MCDB	9.2	8.9	9.2	11.0	15.5	15.0	19.9	17.4	15.9	13.5	12.6	10.2	(28)	
	2%	WB	8.5	8.3	8.5	9.0	11.1	12.6	16.3	15.2	13.9	11.7	10.7	9.6	(29)	
		MCDB	8.9	8.6	8.9	9.7	12.7	13.9	18.8	16.7	14.9	12.7	11.4	9.8	(30)	
	5%	WB	8.0	7.6	8.0	8.5	10.2	12.0	15.3	14.8	13.5	11.2	10.2	9.0	(31)	
		MCDB	8.7	8.3	8.6	9.3	11.0	13.1	17.1	16.1	14.5	12.3	10.9	9.4	(32)	
	10%	WB	7.3	7.0	7.1	8.0	9.6	11.5	14.5	14.2	13.1	10.8	9.6	8.4	(33)	
		MCDB	8.2	7.9	7.9	9.0	10.4	12.6	15.8	15.5	14.2	11.8	10.4	9.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	2.6	2.6	2.6	2.5	2.6	2.1	2.6	2.5	2.2	2.2	2.4	2.8	(35)	
		MCDBR	2.6	2.5	2.8	3.2	4.1	3.4	4.5	3.8	2.6	2.3	2.4	3.0	(36)	
	5% WB	MCWBR	3.3	3.0	3.2	2.3	2.8	2.5	2.5	2.6	2.1	2.4	2.8	3.8	(37)	
		MCWBR	2.4	2.6	2.6	2.5	3.4	3.1	4.0	3.3	2.4	2.4	2.3	2.8	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.324	0.349	0.362	0.377	0.365	0.357	0.374	0.365	0.359	0.340	0.311	0.373	(40)	
		taud	2.062	2.196	2.282	2.314	2.422	2.481	2.451	2.475	2.443	2.319	2.126	2.293	(41)	
	Ebn at Noon		343	598	743	812	858	871	843	821	751	610	359	208	(42)	
		Edh at Noon	43	70	89	104	101	97	98	89	77	61	38	26	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.18	0.66	1.79	3.53	4.95	5.12	4.61	3.63	2.18	1.01	0.28	0.11	(44)	
	RadStd		0.02	0.09	0.24	0.34	0.34	0.58	0.38	0.32	0.18	0.14	0.04	0.01	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (18 neighbors)		N/A	+0.67	N/A	N/A	N/A	N/A	-109	-166	N/A	N/A	

Nomenclature: See separate page