

SLEIPNER A OIL PLATFORM, NorwayWMO: **010886**Lat: **58.367N**Lon: **1.900E**Elev: **30**StdP: **100.97**Time Zone: **1.00 (EUC)**Period: **10-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-0.1	1.2	-6.9	2.1	1.6	-5.1	2.5	2.9	30.4	5.1	29.0	4.8	13.4	110	1.224

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.7	17.2	15.7	16.9	15.5	16.1	14.8	16.4	17.5	15.7	16.5	15.2	16.1	11.0	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.0	11.4	16.9	15.2	10.8	16.2	14.9	10.6	15.9	45.9	17.1	44.1	17.0	42.5	15.7	19.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.6	25.0	22.7	DB	-0.6	18.4	2.3	1.5	-2.2	19.5	-3.6	20.4	-4.8	21.3	-6.5	22.4	(4)
(5)			WB	-2.3	16.8	2.4	1.3	-4.0	17.7	-5.4	18.5	-6.8	19.2	-8.5	20.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.4	5.8	5.5	5.7	6.8	9.1	11.6	14.0	14.6	13.1	10.7	8.5	6.9	(6)
(7)		DBStd	3.64	1.89	1.92	2.12	1.50	1.82	1.27	1.63	1.14	1.34	1.53	1.63	2.21	(7)
(8)		HDD10.0	689	131	126	134	97	41	2	0	0	0	11	49	98	(8)
(9)		HDD18.3	3276	389	359	392	347	288	202	136	117	156	237	296	356	(9)
(10)		CDD10.0	455	0	0	0	0	11	50	123	141	94	32	4	1	(10)
(11)		CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	12.0	14.9	13.8	12.6	11.2	10.6	9.6	9.4	9.9	11.6	13.0	13.4	14.7	(14)
(15)	Precipitation	PrecAvg	1255	150	126	116	64	47	64	76	92	112	128	135	145	(15)
(16)		PrecMax	1559	215	263	209	104	92	105	134	232	166	224	182	290	(16)
(17)		PrecMin	964	60	61	57	42	21	29	33	37	41	49	63	73	(17)
(18)		PrecStd	153	49	48	39	17	16	19	22	34	34	41	32	43	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.1	9.9	10.1	11.2	16.2	15.1	20.0	17.9	17.0	14.2	12.2	11.2	(19)
(20)			MCWB	9.5	9.1	8.5	8.4	13.9	13.2	17.6	16.5	15.9	13.0	11.1	10.1	(20)
(21)		2%	DB	9.2	9.0	9.1	10.1	14.1	14.2	18.1	17.1	16.1	13.9	11.9	10.8	(21)
(22)			MCWB	8.5	8.1	8.3	8.0	11.9	12.6	16.5	15.7	15.1	12.7	10.9	9.8	(22)
(23)		5%	DB	9.0	8.2	8.2	9.2	12.2	13.9	17.1	16.8	15.2	13.1	11.1	10.1	(23)
(24)			MCWB	8.3	7.4	7.4	7.9	10.5	12.5	15.7	15.4	14.0	11.6	10.2	9.2	(24)
(25)		10%	DB	8.2	8.0	8.0	8.9	11.2	13.2	16.2	16.1	15.0	12.8	10.9	9.8	(25)
(26)			MCWB	7.2	7.3	7.2	7.8	9.6	11.7	14.9	14.7	13.7	11.2	9.9	8.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.5	9.0	9.0	9.0	13.9	14.1	18.0	16.7	16.2	13.9	12.0	10.8	(27)
(28)			MCDWB	9.5	9.2	9.3	9.4	16.1	14.8	19.5	17.5	16.7	14.4	12.3	11.1	(28)
(29)		2%	WB	8.6	8.1	8.2	8.5	12.4	13.3	16.7	16.3	15.5	13.1	11.2	10.0	(29)
(30)			MCDWB	8.9	8.4	8.6	9.0	13.9	14.0	18.0	17.0	16.1	13.8	11.6	10.4	(30)
(31)		5%	WB	8.1	7.6	7.8	8.1	11.0	12.8	16.0	15.6	14.8	12.3	10.8	9.4	(31)
(32)			MCDWB	8.6	8.0	8.2	8.8	12.3	13.6	16.9	16.4	15.6	13.0	11.1	9.7	(32)
(33)		10%	WB	7.5	7.1	7.2	7.6	10.2	12.4	15.4	15.2	14.1	11.7	10.1	8.7	(33)
(34)			MCDWB	8.1	7.6	7.6	8.4	10.9	13.4	16.3	16.1	14.9	12.4	10.6	9.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	2.4	2.3	2.1	2.1	2.0	1.7	1.9	1.7	1.8	1.8	2.2	2.5	(35)
(36)			MCDBR	2.6	2.6	2.3	2.4	3.6	2.3	2.5	1.9	2.0	2.2	2.4	2.8	(36)
(37)			MCWBR	3.5	2.9	2.5	2.0	2.5	1.9	2.3	2.3	2.3	2.7	3.3	3.5	(37)
(38)		5% WB	MCDWB	2.5	2.5	2.1	2.2	3.4	2.1	2.2	1.7	1.9	2.2	2.2	2.6	(38)
(39)			MCWBR	3.5	2.9	2.6	2.3	2.8	2.0	2.2	2.5	2.6	3.0	3.3	3.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.336	0.353	0.369	0.387	0.372	0.373	0.384	0.382	0.369	0.352	0.332	0.309	(40)	
(41)		taud	2.145	2.243	2.297	2.295	2.413	2.443	2.426	2.433	2.443	2.346	2.208	2.112	(41)	
(42)		Ebn at Noon	459	656	767	817	861	865	844	818	768	655	465	363	(42)	
(43)		Edh at Noon	53	76	94	110	105	103	103	96	82	68	49	39	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.32	0.92	2.17	3.85	5.37	5.35	4.96	4.00	2.59	1.27	0.46	0.21	(44)	
(45)		RadStd	0.04	0.14	0.15	0.34	0.38	0.43	0.45	0.27	0.23	0.08	0.05	0.02	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page