

SKLINNA FYR, Norway

WMO: 011020

Lat: 65.202N

Lon: 10.996E

Elev: 16

StdP: 101.13

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-7.0	-5.1	-12.9	1.2	-6.0	-11.0	1.5	-4.2	23.9	1.9	22.5	1.9	8.5	140	0.950

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.9	19.4	15.3	17.7	14.6	16.5	13.9	15.9	18.5	15.0	17.3	14.2	16.1	6.2	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.6	10.4	17.3	13.8	9.8	16.3	13.1	9.4	15.4	44.5	18.6	42.1	17.4	39.9	16.3	19.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.4	19.4	17.4	DB	-8.0	21.6	2.8	1.9	-10.0	23.0	-11.7	24.0	-13.2	25.1	-15.3	26.4	(4)
(5)			WB	-9.3	16.7	2.4	1.6	-11.0	17.9	-12.4	18.8	-13.8	19.7	-15.5	20.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.6	1.9	1.1	2.0	4.5	7.5	10.1	12.8	13.4	11.3	7.7	4.5	2.7
	DBStd	5.02	2.81	3.38	2.70	2.25	2.54	2.44	2.48	2.26	2.16	2.53	2.86	3.18
	HDD10.0	1516	252	249	248	165	87	28	3	1	11	79	166	228
	HDD18.3	4271	510	482	507	415	337	248	173	154	211	331	416	486
	CDD10.0	289	0	0	0	0	8	30	89	106	50	6	0	0
	CDD18.3	2	0	0	0	0	0	0	1	1	0	0	0	0
	CDH23.3	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	8.7	11.2	10.5	9.6	7.6	6.9	6.6	6.1	6.3	8.0	9.6	10.5	11.1
Precipitation	PrecAvg	1600	171	152	145	99	80	89	94	111	152	163	149	194
	PrecMax	2059	318	335	280	181	142	165	189	203	311	280	295	302
	PrecMin	1236	31	28	53	33	37	33	42	32	44	53	29	76
	PrecStd	218	71	70	62	41	25	38	39	42	74	60	75	68
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.7	7.5	7.8	11.7	17.2	19.5	22.3	21.3	17.6	13.5	10.9	8.9
		MCWB	6.5	6.5	5.5	7.7	11.9	13.9	16.7	16.5	14.2	10.6	9.1	7.7
	2%	DB	7.1	6.7	6.9	9.6	14.6	16.7	19.7	19.3	16.1	12.5	9.8	8.2
		MCWB	6.1	5.8	5.6	6.7	10.5	12.9	15.8	15.5	13.2	10.2	8.4	7.1
	5%	DB	6.4	6.0	6.3	8.2	12.5	15.0	17.8	17.7	15.0	11.7	9.0	7.5
		MCWB	5.3	5.0	5.0	5.9	9.5	12.1	14.7	14.9	12.4	9.8	7.5	6.3
	10%	DB	5.7	5.3	5.7	7.3	10.9	13.5	16.2	16.6	14.1	10.9	8.2	6.7
		MCWB	4.5	4.0	4.4	5.5	8.5	11.4	13.9	14.3	12.1	9.2	6.6	5.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.0	6.8	6.7	8.1	12.3	14.6	17.3	17.2	15.1	11.6	9.8	8.2
		MCDB	7.4	7.2	7.0	10.9	16.4	17.9	21.3	20.3	16.8	12.4	10.5	8.6
	2%	WB	6.2	6.0	6.0	7.1	10.8	13.3	15.9	16.1	13.5	10.7	8.6	7.4
		MCDB	6.8	6.5	6.6	8.8	13.9	16.1	19.1	18.5	15.3	11.9	9.5	8.0
	5%	WB	5.5	5.2	5.2	6.5	9.7	12.4	14.9	15.3	12.9	10.1	7.8	6.5
		MCDB	6.3	6.0	6.1	7.8	12.2	14.6	17.4	17.3	14.4	11.3	8.9	7.3
	10%	WB	4.6	4.2	4.5	6.0	8.7	11.5	14.1	14.5	12.3	9.5	6.8	5.6
		MCDB	5.5	5.2	5.6	7.0	10.6	13.4	16.0	16.4	13.8	10.8	8.2	6.6
Mean Daily Temperature Range	5% DB	MDBR	2.8	2.9	2.8	3.0	3.4	3.0	3.1	2.9	2.6	2.4	2.6	2.8
		MCDBR	3.5	3.3	3.1	4.0	6.1	5.9	6.2	4.9	3.5	2.8	2.7	3.2
		MCWBR	3.7	3.5	2.9	2.6	3.3	3.0	3.2	2.6	2.4	2.6	2.8	3.5
	5% WB	MCDBR	3.4	3.2	3.0	3.3	5.6	5.2	5.5	4.3	3.3	2.6	2.8	3.3
		MCWBR	3.8	3.7	3.1	2.5	3.2	3.0	3.0	2.6	2.6	2.6	3.2	3.7
Clear-Sky Solar Irradiance	taub	0.367	0.314	0.337	0.358	0.354	0.352	0.359	0.348	0.338	0.314	0.345	0.363	
	taud	2.479	2.213	2.312	2.368	2.451	2.490	2.498	2.521	2.515	2.358	2.474	2.433	
	Ebn at Noon	239	558	733	811	854	863	844	821	744	566	238	67	
	Edh at Noon	23	56	79	94	95	93	90	80	66	48	21	11	
All-Sky Solar Radiation	RadAvg	0.09	0.49	1.63	3.35	4.71	5.10	4.70	3.62	2.02	0.82	0.16	0.03	
	RadStd	0.01	0.07	0.25	0.33	0.28	0.61	0.50	0.34	0.25	0.14	0.03	0.00	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (26 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page