

MYKEN, Norway

WMO: 011150

Lat: 66.763N

Lon: 12.486E

Elev: 43

StdP: 14.67

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	21.9	24.4	8.6	8.6	24.5	11.9	10.1	27.0	49.5	37.2	45.3	35.8	20.5	140	0.893

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.5	64.6	58.4	62.2	57.2	60.4	56.2	59.6	63.1	58.1	61.2	56.7	59.6	11.0	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.9	71.7	61.3	56.5	68.0	59.9	55.2	64.8	58.5	26.2	63.4	25.2	61.3	24.3	59.8	65.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 42.7	37.8	34.2	DB	20.1	70.6	2.9	3.6	18.0	73.2	16.4	75.3	14.8	77.4	12.7	80.0	(4)
(5)			WB	17.0	61.8	3.1	2.1	14.8	63.3	12.9	64.5	11.2	65.7	8.9	67.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	43.6	35.1	34.2	35.5	39.5	44.7	49.5	54.6	55.2	51.8	45.4	40.1	37.1
	DBStd	8.68	5.15	5.28	4.54	4.22	4.30	4.15	4.07	3.76	3.85	4.70	4.96	4.97
	HDD50	2787	462	443	450	316	176	59	4	2	25	153	298	399
	HDD65	7811	927	863	915	766	631	466	324	303	397	607	748	864
	CDD50	450	0	0	0	0	10	42	145	165	78	10	0	0
	CDD65	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	17.4	21.7	20.8	19.5	15.8	14.3	14.4	13.2	13.6	15.8	18.8	20.0	21.4
Precipitation	PrecAvg	35.3	3.5	2.8	3.0	2.4	1.9	1.7	2.0	2.6	3.7	4.0	3.7	4.0
	PrecMax	47.9	7.2	6.6	5.6	4.6	3.7	4.0	4.9	6.5	8.0	8.7	7.6	6.9
	PrecMin	25.7	0.0	0.6	1.3	0.4	0.4	0.3	0.2	0.9	1.5	1.1	0.7	0.3
	PrecStd	5.8	1.5	1.2	1.1	1.0	0.9	0.9	1.2	1.3	1.8	2.0	2.1	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.1	44.8	45.7	52.3	60.3	64.0	69.8	67.8	62.1	57.0	51.9	47.6
		MCWB	43.6	42.9	41.8	45.6	51.6	56.7	61.8	60.0	55.0	51.1	48.6	45.1
	2%	DB	44.6	43.7	44.2	48.9	55.6	60.7	65.2	64.4	59.9	54.8	49.7	46.3
		MCWB	42.0	41.6	41.6	43.6	49.4	55.1	59.2	58.5	54.2	49.6	46.5	44.2
	5%	DB	43.4	42.6	43.2	46.3	52.6	57.6	62.3	62.2	58.2	53.0	48.2	45.1
		MCWB	40.7	40.2	40.3	42.4	47.8	53.3	58.1	57.4	53.7	49.0	45.2	42.6
	10%	DB	42.0	41.3	41.9	44.6	49.9	55.3	60.1	60.5	56.7	51.3	46.9	43.9
		MCWB	39.3	38.8	39.0	41.7	46.0	52.0	56.8	56.7	53.1	47.8	43.8	41.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.7	43.9	43.8	46.4	52.2	57.6	62.8	61.6	57.6	52.2	49.5	46.5
		MCDB	45.5	44.3	44.4	50.7	58.9	61.8	67.2	66.2	59.5	55.1	50.5	47.0
	2%	WB	42.9	42.3	42.2	44.4	50.1	55.6	60.3	59.4	55.8	50.8	47.3	44.9
		MCDB	44.1	43.4	43.5	47.2	54.8	59.7	63.8	63.0	57.9	53.4	49.1	45.9
	5%	WB	41.3	40.7	40.7	43.2	48.3	53.7	58.5	58.3	54.7	49.6	45.8	43.2
		MCDB	42.9	42.3	42.5	45.5	52.1	57.2	61.4	61.5	57.0	52.2	48.0	44.8
	10%	WB	39.6	39.0	39.2	42.2	46.7	52.1	56.9	57.0	53.7	48.4	44.1	41.5
		MCDB	41.7	41.0	41.5	44.4	49.5	54.9	59.5	60.1	56.3	51.1	46.6	43.5
Mean Daily Temperature Range	5% DB	MDBR	4.9	4.9	4.7	4.7	5.1	4.5	4.7	4.5	4.4	4.2	4.7	4.8
		MCDBR	5.6	5.9	5.6	6.3	9.2	8.7	8.9	7.7	6.2	4.9	4.8	5.9
		MCWBR	5.7	6.1	5.7	4.1	4.8	4.8	4.9	4.0	3.6	4.0	5.0	6.2
	5% WB	MCDBR	5.6	6.1	5.8	5.5	8.4	7.8	7.8	6.7	5.3	4.7	4.9	5.9
		MCWBR	6.3	6.7	6.1	4.2	4.9	4.7	4.8	4.3	3.8	4.6	5.5	6.7
Clear-Sky Solar Irradiance	taub	0.369	0.306	0.331	0.352	0.351	0.347	0.355	0.343	0.333	0.308	0.350	N/A	
	taud	2.504	2.177	2.288	2.369	2.448	2.501	2.503	2.525	2.510	2.296	2.467	N/A	
	Ebn at Noon	53	164	227	256	269	273	267	259	232	164	48	0	
	Edh at Noon	6	16	24	29	30	29	28	25	20	14	5	0	
All-Sky Solar Radiation	RadAvg	16	122	483	1000	1446	1635	1461	1095	591	214	35	0	
	RadStd	2	21	67	100	100	214	150	109	69	43	4	0	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.70	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (18 neighbors)	+0.77	N/A	N/A	N/A	N/A	N/A	-167	-239	N/A	N/A

Nomenclature: See separate page