

MYKEN, Norway

WMO: 011150

Lat: 66.763N

Lon: 12.486E

Elev: 13

StdP: 101.17

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-5.6	-4.2	-13.0	1.2	-4.2	-11.2	1.4	-2.8	22.1	2.9	20.2	2.1	9.2	140	0.893

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.5	18.1	14.7	16.8	14.0	15.8	13.5	15.4	17.3	14.5	16.2	13.7	15.3	4.9	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.4	10.2	16.3	13.6	9.7	15.5	12.9	9.3	14.7	43.1	17.4	40.7	16.3	38.7	15.5	18.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.1	16.9	15.3	DB	-6.6	21.5	1.6	2.0	-7.8	22.9	-8.7	24.1	-9.6	25.2	-10.7	26.7	(4)
(5)			WB	-8.3	16.5	1.7	1.2	-9.6	17.4	-10.6	18.1	-11.6	18.7	-12.8	19.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	6.4	1.7	1.2	1.9	4.1	7.0	9.7	12.5	12.9	11.0	7.5	4.5	2.9		
	DBStd	4.82	2.86	2.93	2.52	2.34	2.39	2.31	2.26	2.09	2.14	2.61	2.76	2.76		
	HDD10.0	1548	257	246	250	176	98	33	2	1	14	85	166	222		
	HDD18.3	4339	515	479	508	426	351	259	180	168	221	337	416	480		
	CDD10.0	250	0	0	0	0	6	23	81	92	43	6	0	0		
	CDD18.3	1	0	0	0	0	0	0	1	0	0	0	0	0		
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	7.8	9.7	9.3	8.7	7.1	6.4	6.4	5.9	6.1	7.1	8.4	8.9	9.6		
(15) Precipitation	PrecAvg	896	88	72	75	60	48	42	52	67	94	101	94	102		
	PrecMax	1217	182	167	141	116	94	101	124	165	204	222	194	176		
	PrecMin	654	0	16	34	11	11	7	6	22	37	28	19	7		
	PrecStd	148	39	30	28	25	24	24	30	34	45	52	53	42		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.8	7.1	7.6	11.3	15.7	17.8	21.0	19.9	16.7	13.9	11.1	8.7		
		MCWB	6.4	6.1	5.4	7.5	10.9	13.7	16.5	15.6	12.8	10.6	9.2	7.3		
	2%	DB	7.0	6.5	6.8	9.4	13.1	16.0	18.4	18.0	15.5	12.7	9.8	7.9		
		MCWB	5.5	5.3	5.3	6.4	9.7	12.8	15.1	14.7	12.3	9.8	8.1	6.8		
	5%	DB	6.3	5.9	6.2	8.0	11.4	14.2	16.8	16.8	14.5	11.6	9.0	7.3		
		MCWB	4.8	4.5	4.6	5.8	8.8	11.8	14.5	14.1	12.1	9.4	7.4	5.9		
	10%	DB	5.6	5.2	5.5	7.0	10.0	12.9	15.6	15.8	13.7	10.7	8.3	6.6		
		MCWB	4.0	3.8	3.9	5.4	7.8	11.1	13.8	13.7	11.7	8.8	6.6	5.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.1	6.6	6.6	8.0	11.2	14.2	17.1	16.5	14.2	11.2	9.7	8.1		
		MCDB	7.5	6.8	6.9	10.4	14.9	16.6	19.6	19.0	15.3	12.8	10.3	8.4		
	2%	WB	6.1	5.7	5.7	6.9	10.0	13.1	15.7	15.2	13.2	10.5	8.5	7.2		
		MCDB	6.7	6.3	6.4	8.4	12.6	15.4	17.7	17.2	14.4	11.9	9.5	7.7		
	5%	WB	5.2	4.8	4.8	6.2	9.1	12.1	14.7	14.6	12.6	9.8	7.7	6.2		
		MCDB	6.0	5.7	5.9	7.5	11.2	14.0	16.3	16.4	13.9	11.2	8.9	7.1		
	10%	WB	4.2	3.9	4.0	5.7	8.2	11.2	13.8	13.9	12.1	9.1	6.7	5.3		
		MCDB	5.4	5.0	5.3	6.9	9.7	12.7	15.3	15.6	13.5	10.6	8.1	6.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	2.7	2.7	2.6	2.6	2.8	2.5	2.6	2.5	2.4	2.3	2.6	2.6		
		MCDBR	3.1	3.3	3.1	3.5	5.1	4.8	4.9	4.3	3.4	2.7	2.6	3.3		
	5% WB	MCWBR	3.2	3.4	3.2	2.3	2.6	2.7	2.7	2.2	2.0	2.2	2.8	3.4		
		MCWBR	3.1	3.4	3.2	3.1	4.7	4.3	4.3	3.7	3.0	2.6	2.7	3.3		
(40) Clear-Sky Solar Irradiance	taub		0.369	0.306	0.331	0.352	0.351	0.347	0.355	0.343	0.333	0.308	0.350	N/A		
		taud	2.504	2.177	2.288	2.369	2.448	2.501	2.503	2.525	2.510	2.296	2.467	N/A		
	Ebn at Noon		166	517	717	807	849	862	842	815	731	517	151	0		
		Edh at Noon	18	51	77	91	94	91	88	78	63	45	16	0		
(44) All-Sky Solar Radiation	RadAvg		0.05	0.39	1.52	3.15	4.56	5.15	4.61	3.45	1.86	0.68	0.11	0.00		
	RadStd		0.01	0.07	0.21	0.31	0.32	0.68	0.47	0.34	0.22	0.13	0.01	0.00		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.39	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (18 neighbors)		+0.43	N/A	N/A	N/A	N/A	N/A	-93	-133	N/A	N/A

Nomenclature: See separate page