

DRAG-AJLUOKTA, Norway

WMO: 011430

Lat: 68.047N

Lon: 16.084E

Elev: 62

StdP: 14.66

Time Zone: 1.00 (EUC)

Period: 07-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.4	9.7	-0.2	5.4	11.1	2.7	6.3	13.2	24.2	30.5	21.1	29.3	6.7	210	0.665

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.3	72.7	60.0	68.7	58.1	65.6	56.5	62.0	70.6	59.4	66.2	57.6	64.0	5.8	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.0	72.0	66.1	55.9	66.7	63.1	54.2	62.6	60.8	27.8	70.5	26.1	66.6	24.8	64.0	67.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.7	16.9	14.8	DB	0.3	78.8	3.1	5.7	-1.9	82.8	-3.7	86.2	-5.4	89.4	-7.6	93.5	(4)
(5)			WB	0.5	62.7	3.7	2.1	-2.1	64.2	-4.3	65.4	-6.4	66.5	-9.1	68.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	40.5	26.8	27.4	29.6	36.4	45.6	50.9	57.4	55.2	49.5	41.1	34.2	30.5	
	DBStd	12.43	8.08	7.82	7.13	5.42	6.60	5.71	5.83	4.66	4.93	6.03	6.93	7.67	
	HDD50	4054	718	633	632	410	171	53	1	7	68	283	474	604	
	HDD65	8979	1183	1053	1097	859	602	427	251	306	466	742	924	1069	
	CDD50	570	0	0	0	1	34	79	230	168	52	6	0	0	
	CDD65	18	0	0	0	0	0	2	14	2	0	0	0	0	
	CDH74	93	0	0	0	0	4	7	76	6	0	0	0	0	
	CDH80	16	0	0	0	0	1	0	15	0	0	0	0	0	
Wind	WSAvg	6.9	8.0	7.7	7.5	6.7	6.8	7.0	6.3	5.9	5.8	6.3	6.8	7.8	
Precipitation	PrecAvg	46.4	4.5	4.2	4.2	2.6	2.4	2.3	3.1	3.3	5.0	5.3	4.2	5.2	
	PrecMax	58.3	10.6	8.3	9.4	5.9	4.0	4.2	6.1	7.6	9.4	10.6	8.3	11.4	
	PrecMin	38.3	0.4	0.9	0.9	0.4	0.6	0.5	0.8	1.7	1.4	1.2	0.3	0.3	
	PrecStd	5.9	2.5	1.8	2.3	1.3	1.0	0.9	1.6	1.3	2.3	2.2	2.4	2.8	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.8	43.5	46.4	55.8	70.6	74.1	81.7	73.6	65.4	59.7	50.2	46.2	
		MCWB	39.5	38.5	38.5	45.2	53.8	57.7	63.6	60.7	54.0	49.7	45.9	42.0	
	2%	DB	41.6	41.8	43.4	49.8	64.7	67.5	74.8	69.3	61.9	55.4	46.9	44.0	
		MCWB	37.3	37.5	37.5	42.2	51.9	54.8	62.5	58.2	52.4	47.7	41.9	40.5	
	5%	DB	39.4	40.1	41.4	46.5	60.2	63.5	70.3	66.2	59.6	51.9	45.2	42.4	
		MCWB	36.1	36.4	36.6	39.8	50.0	53.1	60.0	57.2	51.7	46.6	40.8	38.8	
	10%	DB	37.5	38.3	39.5	44.1	55.8	60.0	67.0	63.5	57.3	49.4	43.5	40.6	
		MCWB	33.9	34.7	35.5	38.5	47.0	52.1	58.5	56.1	50.8	45.3	39.4	36.7	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	40.5	41.0	40.4	45.9	55.1	59.1	65.5	63.2	55.9	51.0	46.5	43.7
			MCDB	42.6	43.0	43.3	54.6	67.1	68.8	76.7	69.5	61.7	57.4	49.3	44.8
2%		WB	38.2	38.6	38.8	42.4	52.7	56.7	63.5	60.1	54.0	49.2	43.6	41.9	
		MCDB	40.4	40.6	42.0	47.3	63.1	65.0	74.1	66.6	58.8	53.3	45.8	43.5	
5%		WB	36.5	37.1	37.5	40.8	50.4	54.7	61.1	58.2	52.9	47.5	41.7	39.2	
		MCDB	39.1	39.6	40.6	45.1	59.3	61.5	68.8	64.5	57.4	50.8	44.1	41.9	
10%		WB	34.3	35.1	35.7	39.6	47.9	52.9	59.1	56.7	51.8	45.7	39.6	37.1	
		MCDB	37.1	37.9	39.1	43.3	55.2	59.0	65.5	62.3	56.1	48.9	42.7	39.8	
Mean Daily Temperature Range		5% DB	MDBR	10.0	10.0	11.7	11.3	12.1	10.6	11.3	11.4	10.1	8.5	8.7	9.4
			MCDBR	7.8	8.0	10.3	13.3	18.6	15.9	16.9	15.5	11.9	9.3	8.1	8.8
	MCWBR		6.5	6.6	7.0	7.8	8.9	7.5	7.0	7.6	6.5	6.0	6.0	7.0	
	5% WB	MCDBR	7.8	8.2	9.9	11.1	17.5	13.1	15.8	13.7	10.4	8.0	7.7	8.4	
		MCWBR	7.0	7.1	7.5	7.5	8.8	7.4	7.1	7.6	6.5	6.3	6.3	7.3	
Clear-Sky Solar Irradiance	taub	N/A	0.266	0.305	0.327	0.337	0.340	0.346	0.335	0.315	0.279	0.355	N/A		
	taud	N/A	2.110	2.182	2.271	2.380	2.486	2.502	2.520	2.546	2.279	2.647	N/A		
	Ebn at Noon	N/A	165	228	260	271	274	268	259	235	163	39	0		
	Edh at Noon	N/A	15	25	31	31	29	28	24	18	12	4	0		
All-Sky Solar Radiation	RadAvg	10	111	474	1045	1477	1546	1408	1031	544	185	27	0		
	RadStd	1	24	74	88	122	202	155	108	58	35	3	0		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (26 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page