

DRAG-AJLUOKTA, Norway

WMO: 011430

Lat: 68.047N

Lon: 16.084E

Elev: 19

StdP: 101.10

Time Zone: 1.00 (EUC)

Period: 07-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.2	-12.4	-17.9	0.8	-11.6	-16.3	0.9	-10.5	10.8	-0.8	9.4	-1.5	3.0	210	0.665

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.3	22.6	15.6	20.4	14.5	18.7	13.6	16.7	21.5	15.2	19.0	14.2	17.8	2.6	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.4	10.3	19.0	13.3	9.5	17.3	12.3	8.9	16.0	46.7	21.4	42.8	19.2	39.9	17.8	19.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.8	7.6	6.6	-17.6	26.0	1.7	3.2	-18.8	28.2	-19.8	30.1	-20.8	31.9	-22.0	34.2		
(5)			-17.5	17.1	2.1	1.1	-19.0	17.9	-20.2	18.5	-21.3	19.2	-22.8	20.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	4.7	-2.9	-2.6	-1.3	2.4	7.5	10.5	14.1	12.9	9.7	5.0	1.2	-0.8	(6)
(7)		DBStd	6.91	4.49	4.35	3.96	3.01	3.67	3.17	3.24	2.59	2.74	3.35	3.85	4.26	(7)
(8)		HDD10.0	2252	399	352	351	228	95	29	1	4	38	157	263	336	(8)
(9)		HDD18.3	4988	657	585	609	477	334	237	139	170	259	412	513	594	(9)
(10)		CDD10.0	317	0	0	0	1	19	44	128	93	29	3	0	0	(10)
(11)		CDD18.3	10	0	0	0	0	0	1	8	1	0	0	0	0	(11)
(12)		CDH23.3	52	0	0	0	0	2	4	42	3	0	0	0	0	(12)
(13)		CDH26.7	9	0	0	0	0	1	0	8	0	0	0	0	0	(13)
(14)	Wind	WSAvg	3.1	3.6	3.4	3.3	3.0	3.0	3.1	2.8	2.6	2.6	2.8	3.0	3.5	(14)
(15)	Precipitation	PrecAvg	1178	115	107	107	65	62	59	79	85	127	135	106	132	(15)
(16)		PrecMax	1481	268	210	239	151	102	106	154	194	240	269	211	290	(16)
(17)		PrecMin	974	11	24	22	11	15	13	21	43	36	31	8	7	(17)
(18)		PrecStd	150	64	45	59	33	26	23	41	34	58	56	61	71	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.6	6.4	8.0	13.2	21.5	23.4	27.6	23.1	18.6	15.4	10.1	7.9	(19)
(20)			MCWB	4.2	3.6	3.6	7.3	12.1	14.3	17.6	15.9	12.2	9.8	7.7	5.6	(20)
(21)		2%	DB	5.4	5.5	6.3	9.9	18.1	19.7	23.8	20.7	16.6	13.0	8.3	6.7	(21)
(22)			MCWB	3.0	3.1	3.1	5.7	11.1	12.7	16.9	14.6	11.3	8.7	5.5	4.7	(22)
(23)		5%	DB	4.1	4.5	5.2	8.1	15.7	17.5	21.3	19.0	15.3	11.0	7.3	5.8	(23)
(24)			MCWB	2.3	2.4	2.5	4.3	10.0	11.7	15.6	14.0	11.0	8.1	4.9	3.8	(24)
(25)		10%	DB	3.0	3.5	4.2	6.7	13.2	15.6	19.4	17.5	14.0	9.7	6.4	4.8	(25)
(26)			MCWB	1.1	1.5	1.9	3.6	8.4	11.2	14.7	13.4	10.5	7.4	4.1	2.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.7	5.0	4.7	7.7	12.9	15.0	18.6	17.3	13.3	10.5	8.1	6.5	(27)
(28)			MCDWB	5.9	6.1	6.3	12.5	19.5	20.5	24.8	20.8	16.5	14.1	9.6	7.1	(28)
(29)		2%	WB	3.5	3.7	3.8	5.8	11.5	13.7	17.5	15.6	12.2	9.6	6.5	5.5	(29)
(30)			MCDWB	4.6	4.8	5.6	8.5	17.3	18.4	23.4	19.2	14.9	11.8	7.7	6.4	(30)
(31)		5%	WB	2.5	2.8	3.0	4.9	10.2	12.6	16.2	14.6	11.6	8.6	5.4	4.0	(31)
(32)			MCDWB	3.9	4.2	4.8	7.3	15.2	16.4	20.4	18.1	14.1	10.4	6.7	5.5	(32)
(33)		10%	WB	1.3	1.7	2.0	4.2	8.8	11.6	15.0	13.7	11.0	7.6	4.2	2.8	(33)
(34)			MCDWB	2.8	3.3	3.9	6.3	12.9	15.0	18.6	16.8	13.4	9.4	5.9	4.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.5	5.6	6.5	6.3	6.7	5.9	6.3	6.3	5.6	4.7	4.8	5.2	(35)
(36)			MCDBR	4.3	4.5	5.7	7.4	10.3	8.8	9.4	8.6	6.6	5.2	4.5	4.9	(36)
(37)			MCWBR	3.6	3.7	3.9	4.3	4.9	4.2	3.9	4.2	3.6	3.4	3.3	3.9	(37)
(38)		5% WB	MCDWB	4.4	4.5	5.5	6.2	9.7	7.3	8.8	7.6	5.8	4.5	4.3	4.6	(38)
(39)			MCWBR	3.9	3.9	4.2	4.2	4.9	4.1	3.9	4.2	3.6	3.5	3.5	4.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	N/A	0.266	0.305	0.327	0.337	0.340	0.346	0.335	0.315	0.279	0.355	N/A	(40)	
(41)		taud	N/A	2.110	2.182	2.271	2.380	2.486	2.502	2.520	2.546	2.279	2.647	N/A	(41)	
(42)		Ebn at Noon	N/A	521	720	819	855	864	845	815	742	513	122	0	(42)	
(43)		Edh at Noon	N/A	47	80	97	98	91	87	77	58	39	12	0	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.03	0.35	1.49	3.29	4.66	4.88	4.44	3.25	1.72	0.58	0.08	0.00	(44)	
(45)		RadStd	0.00	0.07	0.23	0.28	0.39	0.64	0.49	0.34	0.18	0.11	0.01	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (26 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Nomenclature: See separate page