

SKROVA FYR, Norway

WMO: 011600

Lat: 68.153N

Lon: 14.649E

Elev: 36

StdP: 14.68

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	19.7	21.9	8.3	8.4	22.6	11.1	9.7	24.3	43.3	37.9	39.5	37.6	14.8	50	0.816

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.1	70.5	58.9	67.2	57.3	64.2	55.9	60.6	67.9	58.7	64.5	57.1	62.5	10.8	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
57.3	70.2	62.7	55.8	66.4	61.3	54.4	63.0	59.7	26.8	68.1	25.5	64.7	24.5	62.6	68.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 37.3	32.9	28.8	17.8	74.8	3.3	4.7	15.4	78.2	13.5	80.9	11.6	83.6	9.2	87.0		
(5)			15.6	62.5	3.0	2.6	13.5	64.4	11.8	65.9	10.1	67.4	8.0	69.3	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	42.6	32.7	31.7	33.1	37.5	44.3	50.7	56.3	55.8	50.8	43.6	38.4	35.3		
	DBStd	10.08	5.41	5.32	4.50	4.60	5.53	5.75	5.31	4.58	4.64	5.04	5.01	5.46		
	HDD50	3263	538	514	524	376	196	56	3	45	205	347	456			
	HDD65	8195	1003	934	989	825	642	431	277	287	425	664	797	921		
	CDD50	556	0	0	0	1	19	77	199	184	70	6	0	0		
	CDD65	12	0	0	0	0	0	2	7	3	0	0	0	0		
	CDH74	27	0	0	0	0	0	3	22	2	0	0	0	0		
	CDH80	2	0	0	0	0	0	0	2	0	0	0	0	0		
	WSAvg	13.9	15.4	15.8	14.4	13.2	12.5	12.2	11.1	12.0	13.6	14.9	15.2	16.5		
	PrecAvg	66.7	7.5	6.3	6.1	4.2	3.4	2.9	3.5	4.0	6.5	7.2	6.9	7.4		
(15) Precipitation	PrecMax	84.6	14.0	10.3	8.6	7.1	6.3	7.7	7.5	9.7	10.1	13.9	17.6	14.3		
	PrecMin	52.1	0.1	2.9	2.1	1.0	1.1	0.5	1.0	2.0	3.1	3.2	1.4	0.9		
	PrecStd	8.5	3.2	2.0	2.0	1.5	1.4	1.9	1.8	1.8	2.1	3.0	4.1	3.4		
	PrecStd	8.5	3.2	2.0	2.0	1.5	1.4	1.9	1.8	1.8	2.1	3.0	4.1	3.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	44.2	42.7	43.5	53.9	66.2	72.2	76.8	72.5	64.2	56.6	50.5	46.7			
	0.4% MCWB	41.5	40.4	39.0	44.3	51.8	57.4	63.5	60.7	55.1	49.6	46.7	43.9			
	2% DB	42.9	41.4	41.7	49.5	60.3	67.5	71.7	68.8	61.2	53.7	48.7	45.0			
	2% MCWB	40.4	39.0	38.6	42.1	49.5	55.2	59.8	58.5	53.4	48.5	45.3	42.4			
	5% DB	41.6	40.3	40.6	45.7	55.7	63.6	68.0	65.7	59.0	51.6	47.3	43.9			
	5% MCWB	39.1	37.9	38.0	39.8	47.2	53.5	58.8	57.3	52.3	47.7	44.0	41.1			
	10% DB	40.1	38.9	39.4	43.0	52.0	59.6	64.7	62.8	56.8	50.0	45.6	42.7			
	10% MCWB	37.7	36.6	37.0	39.1	45.2	51.9	56.8	56.0	51.7	46.5	42.3	39.6			
	0.4% WB	43.0	41.7	40.7	45.0	53.6	59.3	64.4	62.5	57.0	51.1	47.9	45.3			
	0.4% MCDB	43.7	42.2	41.7	53.0	64.3	68.8	75.0	69.7	61.5	54.4	49.4	45.9			
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	41.3	39.9	39.5	42.8	50.2	56.5	61.5	60.2	54.9	49.7	46.3	43.4			
	2% MCDB	42.5	40.9	40.9	47.3	58.7	65.0	69.9	66.5	58.4	52.6	48.3	44.8			
	5% WB	39.8	38.3	38.6	41.2	48.0	54.4	59.6	58.4	53.6	48.5	44.6	41.6			
	5% MCDB	41.2	39.7	40.3	44.1	55.2	61.7	66.1	63.7	57.0	51.1	46.7	43.4			
	10% WB	38.1	36.8	37.4	40.1	45.9	52.5	57.8	56.9	52.6	47.2	42.8	39.9			
	10% MCDB	40.1	38.5	39.4	42.5	50.6	58.8	63.2	61.7	56.1	49.8	45.2	42.2			
(35) Mean Daily Temperature Range	MDBR	5.0	4.9	4.5	5.2	6.2	6.5	7.1	6.0	4.7	4.3	4.6	4.9			
	5% DB	5.8	6.5	5.3	7.7	10.9	11.3	13.0	10.2	7.1	4.8	5.5	6.4			
	5% WB	5.6	6.5	4.8	4.6	5.3	5.6	6.0	4.7	3.8	4.1	5.4	6.6			
	5% DB	5.4	6.3	5.1	6.1	10.3	10.1	11.6	8.5	5.9	4.8	5.6	6.5			
	5% WB	5.9	6.6	5.0	4.4	5.6	5.9	6.2	4.8	4.2	4.9	6.0	7.0			
	5% WB	5.9	6.6	5.0	4.4	5.6	5.9	6.2	4.8	4.2	4.9	6.0	7.0			
(40) Clear-Sky Solar Irradiance	taub	0.367	0.291	0.323	0.341	0.345	0.343	0.349	0.340	0.326	0.295	0.349	N/A			
	taud	2.552	2.159	2.276	2.389	2.460	2.509	2.522	2.531	2.528	2.276	2.520	N/A			
	Ebn at Noon	34	155	224	257	269	273	267	257	230	154	29	0			
	Edh at Noon	4	15	23	28	29	28	27	24	19	13	3	0			
(44) All-Sky Solar Radiation	RadAvg	9	103	452	983	1396	1540	1415	1035	546	187	24	0			
	RadStd	1	23	68	91	108	219	157	108	56	36	3	0			

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+1.04	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (21 neighbors)	+0.68	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page