

SIHCCAJAVRI, Norway

WMO: 011990

Lat: 68.755N

Lon: 23.539E

Elev: 382

StdP: 96.82

Time Zone: 1.00 (EUC)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-32.7	-30.2	-35.8	0.1	-32.7	-33.1	0.2	-30.2	13.4	-6.2	12.1	-6.9	0.6	70	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.2	23.0	14.7	20.6	13.9	18.3	13.1	15.9	20.8	14.7	18.9	13.7	17.4	4.2	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.0	10.4	17.0	12.9	9.7	16.1	11.9	9.1	15.2	45.7	20.8	42.4	18.9	39.7	17.3	19.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.0	9.7	8.5	-37.8	25.2	2.2	2.5	-39.3	27.0	-40.6	28.4	-41.9	29.8	-43.4	31.6		
(5)			-37.9	17.2	2.2	1.7	-39.4	18.4	-40.7	19.3	-42.0	20.3	-43.5	21.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-1.8	-14.4	-13.9	-11.2	-3.9	2.9	8.7	13.0	10.4	6.5	-1.3	-8.4	-11.3		
	DBStd	11.07	7.18	8.46	6.54	4.82	4.78	3.87	3.76	3.16	3.48	4.67	6.25	7.10		
	HDD10.0	4517	757	668	657	416	227	71	12	34	112	351	552	659		
	HDD18.3	7368	1015	902	916	666	480	289	170	246	356	609	802	918		
	CDD10.0	195	0	0	0	0	6	31	104	47	7	0	0	0		
	CDD18.3	6	0	0	0	0	1	0	4	1	0	0	0	0		
	CDH23.3	45	0	0	0	0	3	2	37	3	0	0	0	0		
	CDH26.7	3	0	0	0	0	0	0	3	0	0	0	0	0		
	WSAvg	3.9	3.7	4.1	4.0	3.6	4.2	4.5	4.1	3.8	3.9	3.6	3.3	3.9		
	PrecAvg	428	21	20	17	19	31	55	71	67	44	39	30	24		
(15) Precipitation	PrecMax	640	55	38	32	42	74	95	150	138	100	122	65	55		
	PrecMin	281	4	5	6	4	5	1	21	32	10	10	8	5		
	PrecStd	77	9	8	7	10	20	25	32	29	21	24	16	13		
	PrecStd	77	9	8	7	10	20	25	32	29	21	24	16	13		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	1.5	3.6	2.0	8.2	22.5	22.4	26.8	22.6	16.7	9.3	4.1	2.2		
		MCWB	0.1	1.9	-0.2	4.7	11.9	14.5	16.7	13.5	11.2	7.2	3.7	1.2		
	2%	DB	-1.1	0.6	0.6	5.0	16.2	19.6	24.2	19.8	14.5	7.4	1.3	0.4		
		MCWB	-1.8	-0.6	-0.8	2.1	9.0	12.4	15.0	13.8	10.9	6.0	0.6	-0.3		
	5%	DB	-3.1	-1.3	-0.6	3.8	13.4	17.1	22.3	17.5	13.0	6.0	0.1	-0.8		
		MCWB	-3.6	-1.9	-1.8	1.3	7.8	11.4	14.5	12.8	9.9	4.9	-0.3	-1.5		
	10%	DB	-4.7	-2.6	-1.9	2.6	10.1	15.1	19.9	15.9	11.6	4.4	-0.7	-1.9		
		MCWB	-5.2	-3.1	-2.9	0.5	6.1	10.5	14.3	12.2	9.4	3.5	-1.1	-2.3		
	0.4%	WB	0.4	2.0	0.2	4.5	12.2	16.1	17.8	16.5	13.2	7.5	3.7	1.3		
		MCDB	1.2	3.7	1.5	8.1	20.7	21.1	21.6	18.5	15.4	8.5	4.0	2.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	-1.6	-0.5	-0.8	2.4	10.0	13.9	16.5	14.5	11.6	6.2	0.7	-0.2		
		MCDB	-0.9	0.6	0.4	4.7	15.0	17.3	21.8	17.7	13.5	7.3	1.1	0.2		
	5%	WB	-3.5	-1.8	-1.7	1.5	7.8	12.8	15.5	13.5	10.5	4.8	-0.2	-1.3		
		MCDB	-3.2	-1.4	-0.7	3.3	12.5	16.3	20.5	16.6	12.4	5.7	0.0	-0.8		
	10%	WB	-5.2	-3.1	-2.9	0.7	6.4	11.0	14.6	12.6	9.6	3.6	-1.1	-2.3		
		MCDB	-4.7	-2.6	-2.0	2.2	9.8	14.6	19.0	15.3	11.3	4.4	-0.7	-1.8		
	5% DB	MDBR	8.5	8.4	11.4	9.5	7.8	7.7	8.2	8.0	6.5	5.3	7.1	8.1		
		MCDBR	6.9	7.4	7.4	9.1	12.6	11.0	11.9	10.6	8.7	5.8	4.7	5.6		
		MCWBR	6.7	6.9	6.5	6.6	6.9	5.5	4.8	5.5	5.4	4.7	4.5	5.2		
		MCWBR	7.3	7.1	7.0	8.0	11.9	9.3	9.8	9.2	7.1	5.4	4.6	5.4		
(35) Mean Daily Temperature Range	5% WB	MCWBR	7.1	6.6	6.2	5.9	6.7	5.1	4.7	5.1	4.8	4.5	4.5	5.1		
		taub	0.179	0.234	0.275	0.303	0.323	0.327	0.334	0.320	0.288	0.248	0.180	N/A		
		taud	1.916	2.086	2.190	2.221	2.389	2.494	2.488	2.509	2.559	2.278	1.965	N/A		
		Ebn at Noon	68	544	753	839	868	875	854	828	769	537	57	0		
(42) Clear-Sky Solar Irradiance	Edh at Noon		6	44	76	100	96	90	87	76	55	36	5	0		
(44) All-Sky Solar Radiation	RadAvg		0.02	0.44	1.93	3.94	5.06	4.91	4.59	3.24	1.73	0.55	0.07	0.00		
		RadStd	0.00	0.04	0.08	0.18	0.48	0.36	0.44	0.23	0.17	0.08	0.01	0.00		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (35 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page