

SVINOY FYR, Norway

WMO: 012050

Lat: 62.329N

Lon: 5.268E

Elev: 122

StdP: 14.63

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	28.0	29.9	14.6	11.6	31.8	17.9	13.6	32.7	55.5	44.0	50.6	42.0	13.1	120	0.878

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.7	66.7	59.9	64.4	58.9	62.5	58.1	61.9	64.9	60.2	63.2	58.9	61.6	11.4	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.4	78.9	63.6	58.8	74.2	61.9	57.4	70.6	60.7	27.8	65.1	26.6	63.4	25.7	61.8	69.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 49.2	43.7	38.6	25.3	71.5	3.1	3.5	23.1	74.0	21.3	76.1	19.6	78.0	17.4	80.6		
(5)			22.8	63.4	2.7	2.8	20.9	65.4	19.4	67.0	17.9	68.6	15.9	70.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.6	39.4	38.2	38.9	42.3	46.6	51.0	56.0	57.6	54.7	49.1	44.0	40.7		
	DBStd	7.97	4.20	4.47	4.10	4.26	4.33	3.81	3.99	3.77	3.96	4.69	4.83	4.94		
	HDD50	1943	329	329	343	234	125	30	1	0	7	72	185	288		
	HDD65	6722	794	749	808	681	572	420	281	230	310	494	630	753		
	CDD50	700	0	0	0	3	18	60	187	237	147	43	5	0		
	CDD65	3	0	0	0	0	0	0	1	2	0	0	0	0		
	CDH74	2	0	0	0	0	0	0	1	1	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	17.8	19.9	19.0	19.1	16.7	15.8	16.6	14.9	14.9	18.5	18.9	19.2	20.7		
	PrecAvg	47.3	4.6	4.2	3.9	2.5	2.6	3.0	3.0	4.4	4.7	5.1	4.5	5.1		
(15) Precipitation	PrecMax	55.5	6.9	6.0	8.2	4.7	5.4	5.3	5.0	9.2	7.8	8.2	8.4	8.3		
	PrecMin	35.4	0.8	1.2	1.7	0.9	1.0	1.8	1.3	1.1	2.2	2.2	1.2	1.3		
	PrecStd	5.4	1.9	1.3	1.6	1.0	1.1	1.1	1.1	1.9	2.1	1.6	2.1	1.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.1	49.3	49.1	58.1	63.1	66.5	69.9	70.7	66.8	63.1	55.8	51.5		
		MCWB	44.1	43.9	43.4	49.8	52.7	57.3	61.5	62.3	57.9	54.5	50.1	47.3		
	2%	DB	47.5	46.7	46.7	52.6	57.9	61.3	65.8	67.2	63.7	59.2	53.3	50.0		
		MCWB	43.6	43.3	42.9	46.4	51.3	56.8	60.5	61.1	57.1	53.1	48.4	46.2		
	5%	DB	46.4	45.3	45.4	50.0	54.5	58.0	63.5	64.7	61.8	56.8	51.9	48.8		
		MCWB	43.1	42.5	42.3	45.3	50.2	54.7	59.7	59.8	56.3	52.0	47.6	45.7		
	10%	DB	45.2	44.1	44.2	47.6	52.0	55.7	61.5	62.7	60.0	55.1	50.3	47.5		
		MCWB	42.2	41.6	41.5	44.6	48.7	53.2	58.5	58.7	55.5	50.7	46.6	44.7		
	0.4%	WB	46.4	45.9	46.0	50.4	54.8	59.7	63.1	65.6	60.3	56.1	52.1	49.2		
		MCDB	47.7	47.3	47.0	55.8	60.6	63.8	66.5	68.0	63.9	59.2	54.2	50.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	45.1	44.5	44.5	47.7	52.4	57.1	61.6	62.8	58.8	54.5	50.0	47.7		
		MCDB	46.5	45.8	45.6	51.2	55.9	60.6	64.7	65.8	61.8	57.9	52.1	49.0		
	5%	WB	43.9	43.4	43.2	46.1	50.6	54.9	60.2	60.7	57.4	52.9	48.5	46.5		
		MCDB	45.6	44.7	44.5	48.7	53.7	57.4	63.1	63.5	60.5	56.0	50.7	48.1		
	10%	WB	42.7	42.0	42.0	44.9	49.1	53.5	58.8	59.2	56.2	51.5	47.2	44.8		
		MCDB	44.7	43.6	43.7	47.2	51.8	55.6	61.4	61.8	59.1	54.7	49.9	47.1		
	5% DB	MDBR	4.7	4.6	4.8	5.2	5.0	4.3	4.6	4.7	4.7	4.8	4.7	4.7		
		MCDBR	5.8	5.9	5.9	8.5	9.0	7.7	8.0	7.6	6.8	7.1	6.0	5.7		
		MCWBR	5.0	5.2	4.6	4.9	5.0	5.0	4.7	5.0	4.3	5.4	5.0	5.6		
		MCWBR	5.5	5.6	5.3	7.2	7.9	6.8	6.8	6.3	5.9	6.8	5.5	5.6		
(35) Mean Daily Temperature Range	5% WB	MCWBR	5.3	5.5	5.0	4.8	5.0	4.9	4.6	5.0	4.5	5.8	5.9	6.1		
	taub		0.282	0.327	0.347	0.368	0.360	0.357	0.369	0.363	0.351	0.325	0.283	0.365		
		taud	2.086	2.236	2.315	2.336	2.429	2.477	2.466	2.483	2.484	2.384	2.150	2.406		
(42) Clear-Sky Solar Irradiance	Ebn at Noon		115	195	239	259	272	276	268	260	240	197	115	63		
		Edh at Noon	11	20	27	32	32	31	30	28	23	17	10	7		
	RadAvg		49	193	539	1075	1543	1615	1446	1096	650	292	77	28		
(45) All-Sky Solar Radiation	RadStd		7	34	88	113	100	173	119	111	86	46	16	3		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (21 neighbors)	N/A	+1.13	N/A	N/A	N/A	N/A	-234	N/A	N/A	N/A
		N/A	+1.26	N/A	N/A	N/A	N/A	-234	N/A	N/A	N/A

Nomenclature: See separate page