

VIGRA ALESUND, Norway

WMO: 012100

Lat: 62.560N

Lon: 6.110E

Elev: 69

StdP: 14.66

Time Zone: 1.00 (EUC)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	24.1	26.5	11.1	9.7	29.7	13.9	11.2	30.0	33.5	42.2	30.4	42.5	11.0	140	0.716

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.1	70.1	60.2	66.7	58.3	64.3	57.6	62.0	67.5	60.3	64.6	58.9	63.0	7.8	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.5	76.2	64.3	58.2	72.6	62.6	56.9	69.2	61.3	27.8	67.7	26.6	64.7	25.7	63.1	70.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 31.2	26.8	23.4	DB	20.2	77.5	4.2	3.9	17.1	80.4	14.7	82.6	12.3	84.8	9.2	87.7	(4)
(5)			WB	18.4	64.7	3.9	3.1	15.6	66.9	13.3	68.7	11.2	70.4	8.4	72.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	46.4	37.6	37.3	38.4	43.0	47.9	52.5	57.5	57.8	54.0	48.2	42.3	39.6
	DBStd	8.89	5.06	5.32	5.14	5.10	5.19	4.10	4.46	3.50	4.22	5.30	5.80	5.68
	HDD50	2109	385	357	360	218	101	17	1	0	11	98	237	324
	HDD65	6799	850	777	825	660	529	374	239	225	329	521	681	789
	CDD50	796	0	0	0	9	38	93	233	242	132	42	6	1
	CDD65	8	0	0	0	0	0	1	6	1	0	0	0	0
	CDH74	36	0	0	0	0	0	0	32	4	0	0	0	0
	CDH80	2	0	0	0	0	0	0	2	0	0	0	0	0
Wind	WSAvg	11.7	13.8	12.5	12.8	11.1	10.3	10.5	9.6	9.3	11.4	11.9	12.9	14.3
Precipitation	PrecAvg	61.5	6.0	5.6	5.4	3.3	3.0	3.5	3.5	4.9	6.0	6.7	6.1	7.2
	PrecMax	77.1	11.3	10.5	13.9	7.1	5.3	7.9	6.1	9.2	11.2	10.7	11.8	12.4
	PrecMin	40.4	0.2	0.7	1.8	0.9	1.0	0.9	1.4	0.9	2.0	2.4	0.6	1.6
	PrecStd	8.5	3.1	2.6	2.8	1.7	1.1	1.7	1.2	1.9	2.8	2.5	3.3	2.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.7	51.9	51.5	64.1	68.5	70.0	78.5	73.0	68.6	66.3	56.7	53.7
		MCWB	42.7	44.5	42.7	51.4	55.5	59.4	64.9	61.0	57.4	54.2	49.3	47.9
	2%	DB	47.8	47.9	48.5	57.0	63.2	64.9	71.9	67.9	65.2	61.1	54.0	50.8
		MCWB	42.1	42.5	42.4	47.9	53.7	56.7	62.7	59.4	56.3	52.6	47.6	45.6
	5%	DB	46.3	45.9	47.1	53.2	59.1	61.1	67.2	65.1	62.7	57.5	52.0	49.1
		MCWB	41.9	41.3	42.0	45.6	51.7	55.2	60.3	58.5	55.4	50.7	46.5	44.6
	10%	DB	44.7	44.4	45.7	50.3	55.6	58.3	64.0	63.2	60.6	55.5	50.3	47.4
		MCWB	40.6	40.2	41.2	44.5	49.8	53.5	58.9	57.9	54.7	49.4	45.5	43.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.2	45.9	46.1	52.4	58.4	60.4	66.5	62.6	60.2	55.9	51.3	49.2
		MCDB	48.0	49.2	48.2	61.4	66.4	67.9	75.5	69.3	64.7	61.0	54.4	51.6
	2%	WB	44.3	44.1	44.7	49.0	54.6	57.6	63.6	60.9	58.3	53.9	49.7	47.4
		MCDB	46.2	46.4	47.0	55.5	60.7	63.3	70.0	65.2	62.4	59.4	52.7	49.8
	5%	WB	42.6	42.3	42.9	46.9	52.4	55.6	61.3	59.7	56.8	52.0	47.6	45.7
		MCDB	45.5	45.0	46.0	51.3	57.8	59.9	65.8	63.6	60.6	56.7	50.9	48.4
	10%	WB	40.9	40.7	41.4	45.3	50.4	54.1	59.6	58.7	55.6	50.3	45.9	43.4
		MCDB	43.9	43.8	44.8	49.1	54.8	57.6	63.4	62.3	59.6	54.6	49.8	46.8
Mean Daily Temperature Range	5% DB	MDBR	6.3	6.5	7.7	9.7	9.4	8.2	8.6	8.1	8.4	8.0	6.6	6.5
		MCDBR	7.9	7.7	9.0	15.4	15.6	12.6	14.7	11.9	11.8	11.2	7.9	8.6
		MCWBR	6.0	5.8	6.0	8.2	8.3	7.0	7.4	6.6	6.6	6.3	5.7	7.0
	5% WB	MCDBR	7.2	7.3	7.9	13.2	14.8	11.1	13.8	9.9	10.9	10.0	7.6	8.3
		MCWBR	6.4	6.3	6.4	7.7	8.4	6.5	7.6	6.0	6.8	6.5	6.6	7.6
Clear-Sky Solar Irradiance	taub	0.271	0.320	0.344	0.367	0.362	0.360	0.371	0.365	0.348	0.322	N/A	0.364	
	taud	2.078	2.229	2.293	2.329	2.417	2.462	2.457	2.475	2.494	2.398	N/A	2.439	
	Ebn at Noon	116	196	239	259	272	274	267	259	240	198	N/A	63	
	Edh at Noon	11	20	27	32	32	31	31	28	23	17	N/A	7	
All-Sky Solar Radiation	RadAvg	47	193	539	1057	1469	1558	1439	1100	648	292	76	27	
	RadStd	8	38	88	115	95	158	118	108	89	46	19	3	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (25 neighbors)		N/A	+1.24	N/A	N/A	N/A	N/A	-234	N/A	N/A	N/A

Nomenclature: See separate page