

REKDAL, Norway

WMO: 012140

Lat: 62.6511N

Lon: 6.7550E

Elev: 141

StdP: 14.62

Time Zone: 1.00 (EUC)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.9	23.5	5.6	7.4	27.0	9.7	9.1	27.9	30.7	43.3	27.7	43.6	7.7	120	0.643

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.9	70.7	59.0	67.5	57.0	64.7	55.9	60.5	68.5	58.8	65.0	57.5	63.1	6.4	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.7	69.0	63.6	55.5	66.0	62.2	54.3	63.0	60.8	26.8	68.5	25.7	65.1	24.8	63.3	66.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
27.3	23.3	19.9	20.2	77.9	3.6	4.4	17.6	81.0	15.5	83.5	13.5	86.0	10.9	89.2		
			17.3	63.7	3.4	2.0	14.9	65.2	12.9	66.3	11.0	67.5	8.6	68.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	45.7	35.6	36.2	38.2	42.9	48.4	52.8	57.5	57.8	53.6	46.5	40.8	37.9	
	DBStd	9.64	6.01	6.59	5.55	5.47	5.77	4.31	4.78	3.99	4.41	5.56	6.45	6.74	
	HDD50	2350	447	387	367	223	100	18	1	1	15	135	280	376	
	HDD65	7039	912	806	832	663	516	367	239	227	341	572	725	839	
	CDD50	796	0	1	0	10	49	101	235	241	124	28	5	2	
	CDD65	11	0	0	0	0	0	1	7	3	0	0	0	0	
	CDH74	41	0	0	0	0	0	1	34	6	0	0	0	0	
	CDH80	3	0	0	0	0	0	0	3	0	0	0	0	0	
Wind	WSAvg	8.4	9.5	9.4	10.6	8.2	7.2	6.8	6.4	6.2	8.1	8.3	9.4	10.5	
Precipitation	PrecAvg	57.5	5.3	4.9	5.1	3.2	3.0	3.7	3.7	4.2	6.0	6.4	5.2	6.6	
	PrecMax	73.9	10.9	10.0	15.6	7.4	5.7	9.1	6.2	10.2	13.9	10.9	10.3	11.5	
	PrecMin	33.9	0.0	0.0	0.9	0.6	1.0	0.7	1.0	0.3	2.2	1.3	0.0	1.5	
	PrecStd	9.3	3.5	2.8	3.4	1.9	1.2	1.9	1.4	2.1	3.2	2.7	3.3	2.7	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.4	58.4	53.4	64.2	69.9	71.4	78.4	73.8	68.4	65.6	58.3	57.7	
		MCWB	44.8	45.2	43.6	49.7	56.6	59.5	62.8	59.9	57.2	52.5	48.6	48.9	
	2%	DB	48.4	50.6	50.8	58.4	65.2	65.8	72.0	69.4	64.4	59.3	54.5	53.1	
		MCWB	41.8	42.6	43.3	47.8	53.8	56.3	60.6	58.1	54.9	50.2	46.9	44.9	
	5%	DB	45.9	47.8	48.6	54.1	60.8	61.9	67.6	66.3	62.0	56.0	51.8	49.9	
		MCWB	40.5	40.4	41.6	45.2	51.6	53.7	58.1	57.1	54.0	48.6	45.2	43.0	
	10%	DB	43.9	45.2	46.1	50.8	57.0	59.2	64.4	63.7	59.8	53.6	49.3	46.9	
		MCWB	38.7	38.8	40.1	43.4	49.2	52.1	56.9	56.2	53.2	46.9	43.3	40.7	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.2	46.4	46.7	51.2	57.5	60.1	63.7	61.7	59.0	54.7	50.1	50.1
			MCDB	50.4	53.6	51.3	62.2	67.7	68.8	75.3	70.2	65.5	61.4	55.7	56.8
2%		WB	43.1	43.7	44.8	48.4	54.6	57.2	61.3	59.8	56.9	52.1	48.1	46.2	
		MCDB	47.6	50.6	49.8	57.4	62.7	62.9	70.5	66.7	62.0	57.5	53.4	51.9	
5%		WB	40.9	41.4	42.4	46.3	52.3	54.8	59.5	58.4	55.5	49.4	45.8	43.6	
		MCDB	45.3	46.8	47.0	52.6	59.4	60.0	66.1	64.1	60.0	55.6	51.0	48.8	
10%		WB	39.2	39.4	40.3	44.4	50.2	53.0	57.7	57.2	54.0	47.5	43.8	40.9	
		MCDB	43.6	44.4	44.9	49.5	56.1	57.9	63.2	62.7	58.8	52.8	48.7	45.9	
Mean Daily Temperature Range		5% DB	MDBR	6.6	7.1	8.5	10.7	11.2	10.0	9.9	9.9	9.0	7.7	6.8	7.4
			MCDBR	9.5	10.8	11.3	16.0	17.0	14.2	15.4	13.9	12.0	11.4	10.4	12.0
	MCWBR		6.6	6.7	6.9	8.1	8.9	8.2	8.1	7.5	6.9	6.7	6.7	8.3	
	5% WB	MCDBR	9.4	10.4	10.5	14.6	15.8	12.9	14.4	11.9	10.7	11.0	10.1	12.2	
		MCWBR	6.8	7.2	7.4	7.9	8.6	7.6	7.8	6.8	6.5	6.9	6.9	9.0	
Clear-Sky Solar Irradiance	taub	0.255	0.308	0.335	0.358	0.356	0.356	0.366	0.359	0.340	0.315	0.263	0.361		
	taud	2.078	2.242	2.304	2.353	2.423	2.463	2.466	2.486	2.520	2.432	2.153	2.518		
	Ebn at Noon	122	201	242	262	273	275	269	261	244	202	120	69		
	Edh at Noon	10	20	27	31	32	31	30	27	22	16	10	6		
All-Sky Solar Radiation	RadAvg	47	194	538	1047	1432	1536	1443	1108	647	294	76	26		
	RadStd	9	42	87	115	91	153	121	108	92	46	20	3		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (29 neighbors)	+0.90	+1.22	N/A	N/A	N/A	N/A	-270	-394	+113	N/A

Nomenclature: See separate page