

REKDAL, Norway

WMO: 012140

Lat: 62.6511N

Lon: 6.7550E

Elev: 43

StdP: 100.81

Time Zone: 1.00 (EUC)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.2	-4.7	-14.7	1.1	-2.8	-12.4	1.3	-2.3	13.7	6.3	12.4	6.4	3.5	120	0.643

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.5	21.5	15.0	19.7	13.9	18.2	13.3	15.8	20.3	14.9	18.3	14.1	17.3	2.9	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.7	9.9	17.5	13.1	9.4	16.8	12.4	9.0	16.0	44.4	20.3	41.8	18.4	39.7	17.4	19.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.2	10.4	8.9	DB	-6.6	25.5	2.0	2.4	-8.0	27.2	-9.2	28.6	-10.3	30.0	-11.7	31.8	(4)
(5)			WB	-8.1	17.6	1.9	1.1	-9.5	18.4	-10.6	19.1	-11.7	19.7	-13.0	20.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.6	2.0	2.3	3.4	6.1	9.1	11.5	14.2	14.3	12.0	8.1	4.9	3.3
	DBStd	5.36	3.34	3.66	3.08	3.04	3.21	2.39	2.65	2.21	2.45	3.09	3.59	3.74
	HDD10.0	1306	248	215	204	124	56	10	1	1	8	75	156	209
	HDD18.3	3911	507	448	462	368	287	204	133	126	189	318	403	466
	CDD10.0	442	0	1	0	6	27	56	131	134	69	16	3	1
	CDD18.3	6	0	0	0	0	0	1	4	2	0	0	0	0
	CDH23.3	23	0	0	0	0	0	1	19	3	0	0	0	0
	CDH26.7	2	0	0	0	0	0	0	2	0	0	0	0	0
Wind	WSAvg	3.7	4.2	4.2	4.7	3.7	3.2	3.1	2.9	2.8	3.6	3.7	4.2	4.7
Precipitation	PrecAvg	1460	134	124	130	82	75	93	93	107	152	162	131	168
	PrecMax	1876	277	255	395	187	145	231	158	258	352	277	261	291
	PrecMin	861	0	0	22	16	26	17	26	7	55	33	1	37
	PrecStd	235	88	71	86	47	31	49	36	53	81	68	85	68
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.4	14.7	11.9	17.9	21.1	21.9	25.8	23.2	20.2	18.7	14.6	14.3
		MCWB	7.1	7.3	6.5	9.8	13.7	15.3	17.1	15.5	14.0	11.4	9.2	9.4
	2%	DB	9.1	10.3	10.4	14.7	18.4	18.8	22.2	20.8	18.0	15.2	12.5	11.7
		MCWB	5.4	5.9	6.3	8.8	12.1	13.5	15.9	14.5	12.7	10.1	8.3	7.2
	5%	DB	7.7	8.8	9.2	12.3	16.0	16.6	19.8	19.0	16.7	13.3	11.0	9.9
		MCWB	4.7	4.7	5.3	7.3	10.9	12.1	14.5	14.0	12.2	9.2	7.4	6.1
	10%	DB	6.6	7.3	7.8	10.5	13.9	15.1	18.0	17.6	15.4	12.0	9.6	8.3
		MCWB	3.7	3.8	4.5	6.3	9.6	11.1	13.8	13.4	11.8	8.3	6.3	4.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.4	8.0	8.2	10.7	14.2	15.6	17.6	16.5	15.0	12.6	10.1	10.1
		MCDB	10.2	12.0	10.7	16.8	19.8	20.5	24.0	21.2	18.6	16.3	13.2	13.8
	2%	WB	6.2	6.5	7.1	9.1	12.6	14.0	16.3	15.5	13.8	11.2	8.9	7.9
		MCDB	8.7	10.3	9.9	14.1	17.1	17.2	21.4	19.3	16.7	14.2	11.9	11.1
	5%	WB	4.9	5.2	5.8	8.0	11.3	12.7	15.3	14.7	13.1	9.7	7.7	6.4
		MCDB	7.4	8.2	8.3	11.5	15.2	15.6	18.9	17.8	15.6	13.1	10.6	9.3
	10%	WB	4.0	4.1	4.6	6.9	10.1	11.7	14.3	14.0	12.2	8.6	6.6	5.0
		MCDB	6.5	6.9	7.2	9.7	13.4	14.4	17.3	17.1	14.9	11.6	9.3	7.7
Mean Daily Temperature Range	5% DB	MDBR	3.7	3.9	4.7	6.0	6.2	5.5	5.5	5.5	5.0	4.3	3.8	4.1
		MCDBR	5.3	6.0	6.3	8.9	9.5	7.9	8.6	7.7	6.7	6.3	5.8	6.7
		MCWBR	3.7	3.7	3.8	4.5	4.9	4.6	4.5	4.1	3.8	3.7	3.7	4.6
	5% WB	MCDBR	5.2	5.8	5.8	8.1	8.8	7.1	8.0	6.6	6.0	6.1	5.6	6.8
		MCWBR	3.8	4.0	4.1	4.4	4.8	4.2	4.3	3.8	3.6	3.9	3.8	5.0
Clear-Sky Solar Irradiance	taub	0.255	0.308	0.335	0.358	0.356	0.356	0.366	0.359	0.340	0.315	0.263	0.361	
	taud	2.078	2.242	2.304	2.353	2.423	2.463	2.466	2.486	2.520	2.432	2.153	2.518	
	Ebn at Noon	386	634	764	827	862	867	847	822	769	637	377	216	
	Edh at Noon	33	62	84	99	100	98	96	86	69	52	30	20	
All-Sky Solar Radiation	RadAvg	0.15	0.61	1.70	3.30	4.51	4.84	4.55	3.49	2.04	0.93	0.24	0.08	
	RadStd	0.03	0.13	0.27	0.36	0.29	0.48	0.38	0.34	0.29	0.15	0.06	0.01	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (29 neighbors)		+0.50	+0.68	N/A	N/A	N/A	N/A	-150	-219	+63	N/A

Nomenclature: See separate page