

DOMBAAS, Norway

WMO: 012330

Lat: 62.072N

Lon: 9.116E

Elev: 2093

StdP: 13.62

Time Zone: 1.00 (EUC)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.0	-2.5	-11.4	3.2	-5.9	-7.0	4.1	-1.6	27.9	23.3	24.5	24.2	1.4	250	0.703

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.1	74.1	57.1	70.1	56.2	66.3	54.5	60.0	68.4	58.1	66.1	56.3	64.1	6.9	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
56.5	73.6	63.4	54.7	68.7	61.3	52.8	64.1	59.1	27.3	68.7	26.0	66.1	24.8	64.3	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 21.0	(b) 17.7	(c) 14.9	(e) -9.8	(f) 78.5	(g) 5.3	(h) 4.0	(i) -13.6	(j) 81.4	(k) -16.7	(l) 83.7	(m) -19.6	(n) 85.9	(o) -23.5	(p) 88.8		
(4) 21.0	(5) 17.7	(6) 14.9	(7) -9.8	(8) 78.5	(9) 5.3	(10) 4.0	(11) -13.6	(12) 81.4	(13) -16.7	(14) 83.7	(15) -19.6	(16) 85.9	(17) -23.5	(18) 88.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	36.9	18.8	21.5	28.1	36.0	44.8	51.2	56.6	53.3	46.8	36.2	26.7	21.5
	DBStd	15.12	10.34	10.16	7.93	6.78	7.58	5.69	5.82	4.61	5.49	6.54	8.61	11.02
	HDD50	5281	967	799	680	421	201	51	9	18	125	429	698	883
	HDD65	10269	1432	1219	1145	871	626	414	267	361	546	892	1148	1348
	CDD50	496	0	0	0	1	40	87	214	122	30	2	0	0
	CDD65	7	0	0	0	0	0	0	7	0	0	0	0	0
	CDH74	103	0	0	0	0	4	16	83	0	0	0	0	0
	CDH80	4	0	0	0	0	0	0	4	0	0	0	0	0
	WSAvg	5.8	5.8	6.1	6.6	6.0	6.1	5.7	5.5	5.3	5.8	5.7	5.1	5.5
	PrecAvg	17.0	1.3	1.0	0.9	0.7	1.2	1.9	2.6	2.5	1.2	1.3	1.3	1.3
(15) Precipitation	PrecMax	23.6	3.0	2.1	2.2	1.5	4.1	4.7	4.8	4.6	2.7	3.4	3.5	2.8
	PrecMin	13.2	0.1	0.1	0.1	0.1	0.3	0.2	1.1	0.9	0.2	0.1	0.2	0.4
	PrecStd	2.2	0.7	0.5	0.5	0.4	0.8	1.0	1.0	0.9	0.6	0.7	0.8	0.6
	PrecStd	2.2	0.7	0.5	0.5	0.4	0.8	1.0	1.0	0.9	0.6	0.7	0.8	0.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.2	45.2	49.3	58.5	73.4	76.5	80.3	71.9	65.3	57.8	49.1	44.1
		MCWB	37.1	39.0	40.1	46.3	55.3	55.7	60.1	57.4	54.7	51.7	43.2	39.0
	2%	DB	38.3	40.3	45.0	54.4	67.3	71.8	76.3	67.9	61.7	51.5	43.7	40.7
		MCWB	34.8	35.2	39.0	43.7	52.0	54.6	59.1	56.5	52.5	45.4	40.5	36.6
	5%	DB	35.1	37.2	41.6	50.7	63.1	66.3	72.2	64.8	58.5	48.2	40.1	37.9
		MCWB	32.3	33.3	36.1	41.7	50.3	52.8	57.9	55.9	51.2	43.6	37.3	34.4
	10%	DB	32.1	34.1	38.6	47.3	58.4	62.2	67.9	61.8	55.8	45.3	37.0	34.9
		MCWB	30.1	30.8	33.8	39.9	48.5	51.0	56.4	54.2	49.6	41.2	34.6	32.0
	0.4%	WB	37.7	39.1	42.1	47.7	56.7	58.3	63.9	60.7	56.6	53.2	43.6	39.4
		MCDB	41.5	44.6	46.9	57.4	69.3	67.5	76.2	66.8	62.7	56.9	48.0	43.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	35.1	35.6	38.8	44.8	54.1	56.4	61.2	58.8	54.0	46.6	40.6	36.8
		MCDB	38.0	39.1	44.2	52.7	63.7	66.9	71.2	64.6	59.6	50.4	43.8	40.1
	5%	WB	32.5	33.4	36.6	42.4	51.4	54.6	59.3	56.9	52.2	43.9	37.6	34.5
		MCDB	34.7	37.0	41.3	49.6	60.6	64.0	68.4	62.8	57.4	47.6	39.9	37.4
	10%	WB	30.1	31.0	34.1	40.1	49.0	52.3	57.5	55.1	50.1	41.5	34.7	32.1
		MCDB	32.1	33.9	38.2	46.8	57.7	60.4	66.0	60.6	55.1	45.1	36.7	34.6
(35) Mean Daily Temperature Range	5% DB	MDBR	9.7	10.7	13.3	14.8	16.1	16.7	16.1	14.4	13.6	10.4	8.8	9.7
		MCDBR	11.4	12.1	15.2	20.1	23.1	25.0	23.1	18.4	17.7	13.3	11.2	12.4
	5% WB	MCWBR	9.0	9.2	10.4	11.6	11.7	11.9	10.2	9.7	10.7	9.6	8.8	9.8
		MCDWR	11.2	11.7	14.4	17.6	20.1	19.7	19.6	16.0	15.9	12.1	11.1	12.3
	5% WB	MCWBR	9.0	9.1	9.9	10.5	11.0	10.4	9.5	9.3	10.2	9.5	9.1	10.0
		MCDWR	11.2	11.7	14.4	17.6	20.1	19.7	19.6	16.0	15.9	12.1	11.1	12.3
(40) Clear-Sky Solar Irradiance	taub		0.199	0.250	0.284	0.315	0.325	0.325	0.337	0.327	0.295	0.275	0.208	0.169
	taud		2.076	2.236	2.217	2.209	2.339	2.459	2.449	2.470	2.540	2.430	2.110	1.955
	Ebn at Noon		166	233	263	276	284	286	279	272	263	224	156	112
	Edh at Noon		10	19	29	36	34	31	31	28	21	16	10	6
(44) All-Sky Solar Radiation	RadAvg		79	286	757	1368	1654	1610	1481	1153	730	330	104	43
	RadStd		13	46	84	106	131	130	147	93	69	40	16	3

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (51 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	-216	-259	N/A	N/A

Nomenclature: See separate page