

FOKSTUA II, Norway

WMO: 012380

Lat: 62.1131N

Lon: 9.2861E

Elev: 3196

StdP: 13.08

Time Zone: 1.00 (EUC)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.1	0.2	-10.4	3.5	-2.6	-6.6	4.3	1.2	45.3	14.5	40.6	17.5	3.4	50	0.814

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.3	69.0	54.3	65.3	52.9	61.9	51.5	56.1	64.6	54.5	62.2	52.7	59.7	8.6	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
52.3	65.6	58.9	50.5	61.3	57.4	48.9	57.7	55.9	25.1	64.8	24.0	62.1	22.9	59.8	60.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
32.8	27.7	23.1	DB	-8.5	72.6	4.9	3.8	-12.1	75.3	-14.9	77.5	-17.7	79.6	-21.3	82.3	
			WB	-9.4	58.2	4.6	1.3	-12.7	59.2	-15.4	60.0	-18.0	60.7	-21.3	61.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	33.5	18.9	19.6	22.9	31.1	39.4	46.2	51.8	49.7	43.4	33.1	24.8	20.4	(6)
	DBStd	13.89	8.57	9.02	7.89	6.85	7.29	6.09	5.57	5.27	5.79	6.84	8.42	9.34	(7)
	HDD50	6226	965	852	839	566	339	145	44	72	209	523	755	917	(8)
	HDD65	11486	1430	1272	1304	1016	794	564	409	474	648	988	1205	1382	(9)
	CDD50	216	0	0	0	0	10	32	100	63	11	0	0	0	(10)
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
	CDH74	8	0	0	0	0	0	0	7	1	0	0	0	0	(12)
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14) Wind	WSAvg	8.9	10.3	9.7	9.9	9.2	8.9	8.4	7.8	7.8	8.9	8.4	8.6	9.5	(14)
(15) Precipitation	PrecAvg	17.3	1.1	0.9	0.8	0.7	1.3	2.0	2.8	2.7	1.3	1.3	1.2	1.2	(15)
	PrecMax	24.2	2.6	1.7	2.0	1.3	4.0	4.8	5.2	5.1	2.8	3.3	3.3	2.4	(16)
	PrecMin	13.5	0.1	0.1	0.1	0.2	0.2	0.2	1.1	0.8	0.2	0.2	0.2	0.4	(17)
	PrecStd	2.2	0.6	0.4	0.5	0.3	0.9	1.0	1.0	1.0	0.6	0.7	0.7	0.5	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.2	40.2	42.8	52.5	67.4	71.0	74.7	70.1	63.4	54.1	44.5	41.1	(19)
		MCWB	34.5	36.5	36.0	41.7	51.2	51.8	56.9	55.6	51.8	45.8	40.6	37.5	(20)
	2%	DB	35.3	36.7	39.2	47.8	60.9	65.9	70.4	65.6	58.9	48.2	41.4	38.3	(21)
		MCWB	32.3	33.7	34.8	39.1	47.0	50.9	55.5	54.2	50.1	42.6	38.0	35.2	(22)
	5%	DB	33.0	34.0	36.7	44.2	56.6	61.5	66.9	62.4	55.4	45.4	38.3	35.6	(23)
		MCWB	30.5	31.1	32.6	37.3	45.4	49.1	54.2	52.9	48.7	41.1	35.7	32.7	(24)
	10%	DB	30.4	31.3	34.0	41.2	51.8	57.4	62.7	59.1	52.4	42.7	35.6	32.6	(25)
		MCWB	28.4	28.9	30.5	36.1	43.3	47.5	52.4	51.7	47.1	39.1	33.1	30.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	35.2	36.6	38.0	43.5	51.1	54.6	58.5	57.5	53.9	46.6	41.5	38.0	(27)
		MCDB	37.8	38.6	41.4	50.8	62.0	62.8	69.4	66.1	60.6	50.3	44.1	40.5	(28)
	2%	WB	32.6	33.3	34.9	40.2	48.1	52.5	56.5	56.0	51.4	43.5	38.5	35.5	(29)
		MCDB	35.0	35.4	38.6	45.7	56.6	61.9	65.8	63.8	57.0	46.7	41.2	38.3	(30)
	5%	WB	30.7	31.1	33.0	38.0	45.8	50.7	55.1	54.2	49.7	41.5	36.0	32.9	(31)
		MCDB	32.7	33.2	36.5	43.1	53.7	59.6	63.5	61.0	54.5	44.7	38.5	35.2	(32)
	10%	WB	28.6	28.8	30.8	36.2	43.4	48.6	53.3	52.4	47.8	39.4	33.5	30.4	(33)
		MCDB	30.5	31.0	34.1	40.9	50.6	56.0	60.6	58.5	52.5	42.6	35.6	32.4	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	9.0	9.8	11.9	12.3	14.7	15.5	15.3	14.1	12.5	10.5	9.0	9.4	(35)
		MCDBR	9.6	10.0	12.6	15.7	21.2	22.8	22.3	18.7	16.9	14.0	10.3	10.2	(36)
	5% WB	MCWBR	8.7	8.3	9.3	9.6	11.3	11.4	10.3	9.7	10.0	9.7	8.9	9.1	(37)
		MCWBR	9.5	9.4	12.0	13.4	18.5	19.0	18.7	16.5	14.3	11.5	10.1	10.0	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.189	0.239	0.270	0.300	0.310	0.311	0.322	0.312	0.283	0.263	0.198	0.160	(40)
		taud	2.083	2.257	2.246	2.243	2.375	2.490	2.479	2.498	2.562	2.451	2.118	1.956	(41)
	Ebn at Noon	Ebn at Noon	173	239	270	282	289	291	284	278	269	230	163	118	(42)
		Edh at Noon	10	19	28	35	33	30	30	27	21	16	10	6	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	78	285	754	1367	1657	1610	1481	1153	729	330	103	43	(44)
	RadStd	RadStd	13	46	84	103	128	128	145	94	69	39	16	3	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (52 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	-216	-259	N/A	N/A

Nomenclature: See separate page