

HJERKINN II, Norway

WMO: 012390

Lat: 62.221N

Lon: 9.542E

Elev: 3320

StdP: 13.02

Time Zone: 1.00 (EUC)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -5.3	(c) -1.9	(d) -10.5	(e) 3.5	(f) -3.3	(g) -7.4	(h) 4.2	(i) -0.4	(j) 29.7	(k) 29.7	(l) 27.1	(m) 30.5	(n) 3.9	(o) 310	(p) 0.776

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.0	69.4	54.5	65.6	52.7	62.3	51.3	57.0	64.7	55.0	62.1	53.1	59.9	6.6	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
53.5	69.0	59.2	51.6	64.2	58.2	49.7	59.7	56.0	25.8	64.5	24.5	62.3	23.3	60.0	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.4	21.0	18.2		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	33.2	17.5	19.9	23.0	30.4	40.0	46.2	51.9	49.0	43.4	32.9	23.7	20.1
	DBStd	14.26	9.56	8.87	8.70	7.65	8.49	5.14	6.12	4.46	5.66	6.48	9.42	10.03
	HDD50	6321	1009	844	836	587	328	136	51	75	208	530	790	927
	HDD65	11594	1474	1264	1301	1037	776	564	408	496	647	995	1240	1392
	CDD50	201	0	0	0	0	17	21	109	43	11	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	15	0	0	0	0	0	0	15	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
(14) Wind	WSAvg	7.4	7.7	8.2	9.5	7.7	7.2	7.5	6.1	5.8	6.9	6.7	7.0	9.0
(15) Precipitation	PrecAvg	25.3	2.0	1.9	1.9	1.2	1.5	2.5	3.1	3.1	2.1	2.0	1.9	2.2
	PrecMax	31.9	5.1	3.3	4.5	4.1	2.5	4.9	4.8	6.3	5.5	4.3	5.3	4.8
	PrecMin	19.4	0.1	0.2	0.5	0.3	0.6	0.8	1.4	1.1	0.7	0.7	0.2	0.7
	PrecStd	3.1	1.3	0.9	1.1	0.7	0.5	1.1	0.9	1.2	1.0	0.7	1.4	1.0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.0	42.4	45.3	54.6	69.2	68.5	76.2	68.4	64.5	52.4	45.1	43.8
		MCWB	35.0	36.2	38.7	43.7	51.7	51.3	58.8	54.3	51.6	45.9	40.3	40.4
	2%	DB	36.2	38.5	41.2	49.6	63.3	63.9	72.2	64.4	60.6	47.8	41.9	39.7
		MCWB	32.6	33.5	36.1	40.5	49.5	49.7	56.3	52.2	50.6	41.9	38.2	36.2
	5%	DB	33.7	35.3	38.3	45.6	59.3	60.0	68.1	61.1	56.9	44.8	38.8	36.4
		MCWB	30.8	31.2	33.9	38.6	47.9	48.6	55.1	51.4	48.7	40.2	36.2	33.2
	10%	DB	30.6	32.3	35.4	42.2	55.1	56.7	64.3	57.9	53.0	42.2	35.5	32.7
		MCWB	28.3	28.9	31.4	36.5	46.2	47.8	53.8	50.5	47.0	38.1	32.8	30.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	35.9	37.2	39.7	44.5	53.8	55.5	60.4	56.9	54.5	47.6	40.9	40.3
		MCDB	39.5	41.6	44.2	52.9	66.4	60.9	71.6	62.6	62.1	51.0	44.9	43.3
	2%	WB	32.9	34.0	36.4	41.5	51.4	52.9	58.7	54.9	51.4	42.8	38.4	36.5
		MCDB	35.9	37.7	40.6	48.1	60.6	58.6	68.7	60.7	57.5	46.4	41.3	39.7
	5%	WB	30.7	31.3	34.1	39.0	48.8	50.9	56.6	52.8	49.5	40.7	36.3	33.3
		MCDB	33.5	34.8	38.1	44.6	57.0	57.7	64.7	58.6	55.3	44.3	38.8	36.1
	10%	WB	28.4	28.7	31.6	36.6	46.4	48.5	54.7	51.1	47.6	38.1	32.9	30.0
		MCDB	30.6	31.8	35.2	42.3	54.7	55.2	62.1	56.7	52.7	41.6	35.2	32.4
(35) Mean Daily Temperature Range	5% DB	MDBR	10.1	10.6	12.5	13.6	15.3	16.0	17.0	15.5	13.5	11.3	9.5	10.5
		MCDBR	10.3	11.4	12.3	16.6	22.1	23.2	24.4	20.5	19.2	14.3	11.2	12.4
		MCWBR	8.8	9.4	9.2	10.2	11.3	11.6	11.1	10.3	10.9	10.1	9.2	11.3
	5% WB	MCDBR	10.0	10.9	12.1	15.7	19.8	18.3	21.1	17.5	16.8	12.7	11.4	12.8
		MCWBR	8.7	9.1	9.4	10.2	11.0	10.3	10.4	9.9	10.5	9.6	9.5	11.7
(40) Clear-Sky Solar Irradiance	taub		0.187	0.238	0.269	0.298	0.309	0.309	0.320	0.311	0.281	0.262	0.196	0.160
	taud		2.078	2.257	2.249	2.249	2.381	2.494	2.482	2.501	2.566	2.454	2.114	1.955
	Ebn at Noon		172	239	270	283	289	291	284	278	269	230	162	116
	Edh at Noon		10	19	28	34	33	30	30	27	21	16	10	6
(44) All-Sky Solar Radiation	RadAvg		75	282	750	1366	1662	1611	1480	1153	728	328	101	41
	RadStd		12	44	82	96	121	123	142	95	69	38	16	3

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (52 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-216	-259	N/A	N/A

Nomenclature: See separate page