

AFJORD II, Norway

WMO: 012420

Lat: 63.966N

Lon: 10.216E

Elev: 98

StdP: 14.64

Time Zone: 1.00 (EUC)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 6.8	(c) 12.0	(d) 0.9	(e) 5.8	(f) 11.4	(g) 4.7	(h) 7.0	(i) 15.7	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.1	79.6	63.8	75.0	61.2	71.2	59.3	65.3	76.5	62.7	72.4	60.6	68.9	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.7	79.6	69.8	58.4	73.2	66.9	56.6	68.4	63.9	30.2	76.4	28.3	72.7	26.8	69.3	74.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) N/A	(b) N/A	(c) N/A	(e) 4.1	(f) 84.8	(g) 4.3	(h) 4.0	(i) 1.0	(j) 87.7	(k) -1.6	(l) 90.1	(m) -4.0	(n) 92.3	(o) -7.2	(p) 95.3		
(4) N/A	(5) N/A	(6) N/A	(7) 3.3	(8) 67.8	(9) 4.2	(10) 3.1	(11) 0.3	(12) 70.1	(13) -2.2	(14) 71.9	(15) -4.5	(16) 73.7	(17) -7.6	(18) 76.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	43.3	29.3	30.8	34.2	40.9	48.5	53.7	59.0	58.0	52.5	43.3	35.5	32.5
	DBStd	12.44	8.41	8.02	6.86	6.10	7.03	5.85	6.64	5.10	5.18	5.88	7.75	7.87
	HDD50	3323	642	537	491	284	113	24	2	1	32	219	437	541
	HDD65	7980	1107	957	956	724	512	343	214	227	375	673	886	1006
	CDD50	860	0	0	0	10	68	134	282	248	107	11	0	0
	CDD65	42	0	0	0	0	2	3	28	9	0	0	0	0
	CDH74	478	0	0	0	0	26	48	318	85	1	0	0	0
	CDH80	105	0	0	0	0	2	5	93	5	0	0	0	0
	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	PrecAvg	57.9	5.9	5.4	5.7	3.3	3.0	4.0	3.3	3.9	5.7	5.9	5.6	6.3
(15) Precipitation	PrecMax	71.5	17.5	13.2	15.3	8.6	5.5	8.0	7.2	7.6	15.4	11.3	12.8	13.0
	PrecMin	40.0	0.2	0.7	2.2	1.0	1.3	0.7	0.8	0.7	1.2	1.1	0.2	1.3
	PrecStd	8.3	3.8	2.9	3.1	1.9	1.0	1.6	1.6	1.9	3.6	2.0	3.7	2.9
	PrecStd	8.3	3.8	2.9	3.1	1.9	1.0	1.6	1.6	1.9	3.6	2.0	3.7	2.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.3	46.2	52.2	68.1	77.2	79.7	87.3	80.7	72.2	64.4	52.7	48.4
		MCWB	41.3	41.0	42.0	52.4	58.5	60.7	67.6	62.9	58.8	54.7	48.2	43.9
	2%	DB	44.2	44.6	47.5	61.5	71.9	73.5	82.5	76.4	67.3	58.2	50.2	46.5
		MCWB	40.8	40.2	40.1	48.4	56.7	59.8	66.1	62.2	57.1	50.8	45.9	42.9
	5%	DB	41.9	42.9	45.0	56.5	66.9	68.9	76.8	72.0	64.2	54.4	47.6	44.5
		MCWB	38.7	39.3	40.2	45.8	54.6	56.9	63.9	59.9	55.7	48.0	43.9	40.8
	10%	DB	39.7	41.1	43.3	51.2	61.7	65.1	72.3	68.6	61.3	51.5	45.5	42.6
		MCWB	37.0	37.6	39.2	42.9	51.1	55.4	61.0	58.8	54.0	46.7	41.9	39.2
	0.4%	WB	44.1	43.7	44.9	53.0	61.1	63.4	71.2	66.2	60.9	55.6	50.0	46.8
		MCDB	45.4	44.5	47.1	66.8	74.0	76.3	84.7	75.9	68.7	61.4	52.0	47.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	41.8	41.9	43.3	49.2	57.6	60.4	67.4	63.4	58.6	51.7	47.1	44.1
		MCDB	43.2	43.4	45.2	60.2	69.8	71.0	79.4	73.0	64.6	57.0	49.2	45.1
	5%	WB	39.3	39.9	41.3	46.6	55.1	58.1	64.6	61.2	56.9	49.3	44.7	41.4
		MCDB	41.0	42.1	44.4	54.1	65.6	66.6	75.6	69.7	62.0	53.2	47.2	43.5
	10%	WB	37.1	37.6	39.4	44.2	52.3	56.0	61.9	59.3	55.0	47.5	42.1	39.1
		MCDB	39.3	40.7	43.1	49.5	60.8	63.8	70.6	66.9	60.0	50.8	44.7	42.1
(35) Mean Daily Temperature Range	5% DB	MDBR	8.5	9.5	12.5	15.5	16.8	15.3	16.1	15.9	13.4	11.3	8.7	9.1
		MCDBR	9.1	9.8	12.7	23.3	25.9	23.5	25.1	22.3	18.0	14.6	9.6	9.8
		MCWBR	7.1	7.4	8.5	12.9	13.0	12.0	11.6	10.9	10.2	9.1	7.4	8.0
	5% WB	MCDBR	8.4	9.2	10.6	20.1	23.6	21.8	24.2	19.5	16.3	12.5	9.6	10.1
		MCWBR	7.3	8.0	8.3	11.7	12.7	11.8	11.7	10.6	9.9	8.6	8.0	9.0
(40) Clear-Sky Solar Irradiance	taub		0.391	0.306	0.333	0.358	0.355	0.356	0.363	0.351	0.337	0.313	0.358	0.362
	taud		2.640	2.207	2.279	2.351	2.429	2.459	2.465	2.494	2.510	2.396	2.557	2.493
	Ebn at Noon		101	190	238	259	272	274	268	261	240	192	98	44
	Edh at Noon		9	19	26	31	31	31	30	27	22	16	8	5
	RadAvg		41	191	572	1117	1463	1552	1473	1131	663	287	69	18
(45) All-Sky Solar Radiation	RadStd		6	30	89	96	90	169	147	121	76	42	12	2

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (33 neighbors)	+0.83	N/A	N/A	N/A	N/A	N/A	N/A	-257	-340	+121	N/A

Nomenclature: See separate page