

OPPDAL-SETER, Norway

WMO: 012450

Lat: 62.604N

Lon: 9.667E

Elev: 606

StdP: 94.25

Time Zone: 1.00 (EUC)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.5	-14.5	-21.6	0.6	-13.2	-19.8	0.7	-12.2	10.2	-1.8	9.2	-1.2	1.1	280	0.669

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.0	23.5	14.9	21.2	13.8	19.5	13.1	16.0	21.4	14.9	20.0	13.8	18.4	2.8	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
13.6	10.4	18.2	12.6	9.8	16.9	11.5	9.1	15.9	46.9	21.3	43.7	20.0	40.6	18.3	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.4	7.2	6.2	-19.3	26.3	2.7	2.3	-21.2	27.9	-22.8	29.3	-24.3	30.6	-26.2	32.2		
(5)			-19.7	17.6	2.6	1.2	-21.6	18.5	-23.1	19.2	-24.5	19.8	-26.4	20.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	4.1	-4.0	-2.7	-1.3	2.4	7.4	10.3	13.5	12.3	9.5	4.2	-0.6	-2.7	(6)
(7)		DBStd	7.41	4.77	4.55	4.16	4.19	4.65	3.25	3.80	2.89	3.30	3.77	5.20	5.27	(7)
(8)		HDD10.0	2479	434	356	349	229	109	37	10	11	49	182	319	394	(8)
(9)		HDD18.3	5214	693	589	607	477	338	242	156	189	265	438	569	652	(9)
(10)		CDD10.0	312	0	0	0	2	30	44	119	80	34	3	0	0	(10)
(11)		CDD18.3	7	0	0	0	0	0	0	7	1	0	0	0	0	(11)
(12)		CDH23.3	75	0	0	0	0	4	1	67	3	0	0	0	0	(12)
(13)		CDH26.7	10	0	0	0	0	0	0	10	0	0	0	0	0	(13)
(14)	Wind	WSAvg	2.8	2.9	3.0	3.3	2.9	2.9	2.5	2.3	2.4	2.6	2.6	2.9	(14)	
(15)	Precipitation	PrecAvg	615	49	46	48	30	31	62	78	81	47	45	46	52	(15)
(16)		PrecMax	876	149	101	135	135	63	140	121	178	133	122	164	120	(16)
(17)		PrecMin	464	1	0	8	3	9	16	37	31	12	9	2	10	(17)
(18)		PrecStd	95	39	27	34	26	12	33	22	36	28	25	44	28	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.0	9.1	9.5	16.4	23.4	22.2	28.3	23.3	20.7	17.4	12.0	9.4	(19)
(20)			MCWB	3.4	4.1	4.4	8.7	13.8	13.2	17.0	14.2	13.3	12.8	7.2	5.9	(20)
(21)		2%	DB	5.2	6.7	7.3	13.7	20.1	20.2	25.2	20.7	18.5	12.6	9.6	7.2	(21)
(22)			MCWB	2.0	3.0	3.5	6.9	12.0	12.6	16.0	13.3	12.1	7.6	5.7	3.9	(22)
(23)		5%	DB	3.7	4.6	6.1	11.2	18.1	18.2	22.7	19.0	16.6	11.2	7.7	5.6	(23)
(24)			MCWB	1.0	1.3	2.7	5.8	10.7	11.8	15.1	13.1	11.4	6.9	4.4	2.7	(24)
(25)		10%	DB	2.6	3.1	4.7	9.0	15.8	16.4	20.3	17.5	15.0	9.7	6.0	3.9	(25)
(26)			MCWB	0.0	0.3	1.6	4.2	9.7	11.0	14.4	12.4	10.5	6.0	3.0	1.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.0	4.7	5.5	9.2	14.4	15.2	18.1	16.2	14.1	12.7	7.6	6.2	(27)
(28)			MCDWB	7.0	8.5	8.3	15.7	22.1	20.1	25.4	20.0	18.8	17.2	11.5	9.2	(28)
(29)		2%	WB	2.5	3.0	4.1	7.4	12.7	13.7	16.9	14.7	12.9	8.7	6.0	4.3	(29)
(30)			MCDWB	4.6	6.2	6.8	12.6	19.1	18.6	23.5	18.9	17.6	12.1	9.2	6.9	(30)
(31)		5%	WB	1.3	1.6	3.0	6.1	11.3	12.4	15.8	13.7	11.8	7.3	4.7	2.9	(31)
(32)			MCDWB	3.5	4.2	5.9	10.8	17.1	16.9	21.4	17.6	15.8	10.9	7.5	5.4	(32)
(33)		10%	WB	0.2	0.5	1.8	4.7	9.9	11.3	14.7	12.7	10.8	6.0	3.2	1.3	(33)
(34)			MCDWB	2.3	2.9	4.5	8.8	15.3	15.4	19.8	16.6	14.6	9.3	5.8	3.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.4	5.7	7.2	7.6	8.5	8.5	9.0	8.2	7.6	6.7	5.5	5.8	(35)
(36)			MCDBR	5.5	6.6	7.8	10.2	12.4	12.1	13.3	10.4	10.5	8.6	6.7	7.4	(36)
(37)			MCWBR	4.2	4.5	5.3	5.7	6.4	5.9	6.2	5.3	6.0	5.5	4.8	5.8	(37)
(38)		5% WB	MCDBR	5.3	6.6	7.6	9.4	12.1	10.6	11.8	9.2	9.9	8.1	6.7	7.5	(38)
(39)			MCWBR	4.3	4.7	5.2	5.5	6.4	5.6	5.7	5.1	6.0	5.6	5.0	5.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.201	0.257	0.291	0.319	0.330	0.330	0.341	0.329	0.300	0.279	0.211	0.179	(40)	
(41)		taud	2.039	2.213	2.206	2.220	2.337	2.446	2.445	2.475	2.540	2.426	2.090	1.949	(41)	
(42)		Ebn at Noon	480	707	813	863	887	894	872	854	820	687	452	289	(42)	
(43)		Edh at Noon	32	61	90	111	108	99	97	86	66	50	30	18	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.21	0.84	2.28	4.21	5.19	5.05	4.65	3.62	2.26	1.01	0.29	0.11	(44)	
(45)		RadStd	0.03	0.12	0.24	0.25	0.31	0.37	0.42	0.32	0.21	0.11	0.05	0.01	(45)	

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (48 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	-120	-144	N/A	N/A

Nomenclature: See separate page