

KOTSOY, Norway

WMO: 012540

Lat: 62.976N

Lon: 10.561E

Elev: 417

StdP: 14.48

Time Zone: 1.00 (EUC)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -8.3	(c) -2.5	(d) -12.5	(e) 2.8	(f) -8.3	(g) -6.2	(h) 4.0	(i) -2.0	(j) 17.5	(k) 27.6	(l) 15.8	(m) 27.6	(n) 2.9	(o) 160	(p) 0.615

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.7	79.2	62.6	75.2	60.8	71.7	59.3	65.3	74.8	63.0	71.6	61.0	69.0	5.2	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.6	83.3	69.2	59.5	77.0	66.5	57.6	71.9	64.1	30.4	74.4	28.7	71.9	27.3	69.1	74.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 13.6	(b) 11.4	(c) 9.6	(e) -10.3	(f) 85.5	(g) 7.5	(h) 4.7	(i) -15.8	(j) 88.8	(k) -20.2	(l) 91.6	(m) -24.4	(n) 94.2	(o) -29.9	(p) 97.6		
(a) 13.6	(b) 11.4	(c) 9.6	(e) -10.7	(f) 68.8	(g) 7.5	(h) 2.7	(i) -16.1	(j) 70.7	(k) -20.5	(l) 72.3	(m) -24.7	(n) 73.8	(o) -30.1	(p) 75.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	40.1	21.8	24.3	30.8	39.2	48.0	53.9	59.9	57.6	50.9	39.4	29.5	24.4		
	DBStd	15.47	11.33	10.80	7.85	5.72	7.20	5.97	6.27	5.03	5.38	6.58	9.48	11.00		
	HDD50	4475	875	718	594	326	128	27	3	3	56	335	616	794		
	HDD65	9132	1340	1138	1059	774	527	335	183	234	424	793	1066	1259		
	CDD50	850	0	0	0	3	65	145	309	239	82	7	0	0		
	CDD65	33	0	0	0	0	0	3	25	5	0	0	0	0		
	CDH74	477	0	0	0	0	44	56	316	61	0	0	0	0		
	CDH80	102	0	0	0	0	4	9	87	2	0	0	0	0		
	WSAvg	3.5	3.9	3.7	4.1	3.9	4.1	3.8	3.2	2.8	2.9	3.1	3.1	3.4		
	PrecAvg	34.1	2.8	2.5	2.4	1.6	2.3	3.5	3.8	3.9	3.4	2.7	2.5	2.6		
(15) Precipitation	PrecMax	42.4	6.7	4.5	5.0	5.8	4.1	6.3	6.5	8.0	8.5	6.7	7.5	6.0		
	PrecMin	25.2	0.1	0.2	0.9	0.6	1.2	1.2	1.9	1.3	1.0	0.8	0.0	0.6		
	PrecStd	4.2	1.8	1.2	1.3	1.1	0.9	1.3	1.3	1.7	2.1	1.3	2.1	1.3		
	PrecStd	4.2	1.8	1.2	1.3	1.1	0.9	1.3	1.3	1.7	2.1	1.3	2.1	1.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.8	46.9	50.7	66.6	79.1	80.5	88.5	79.6	70.2	62.3	49.8	45.8		
		MCWB	38.1	40.7	42.9	51.8	60.0	61.3	67.1	62.7	59.0	55.0	44.4	39.6		
	2%	DB	40.0	43.5	46.8	60.1	74.0	74.4	81.5	75.3	66.8	56.6	46.4	42.3		
		MCWB	36.0	37.9	40.3	46.8	57.5	59.5	64.9	61.9	58.0	49.7	42.4	37.0		
	5%	DB	36.5	40.8	44.0	54.1	68.9	70.2	77.2	71.6	63.4	52.8	43.7	39.8		
		MCWB	34.1	35.8	38.3	43.7	55.4	58.0	63.1	60.3	56.2	47.6	39.9	35.5		
	10%	DB	34.0	37.5	40.9	49.9	62.6	65.8	72.6	68.0	60.1	48.7	40.8	36.3		
		MCWB	33.0	33.8	36.3	41.7	51.5	55.7	61.1	59.1	54.0	44.9	38.3	33.9		
	0.4%	WB	38.7	41.3	44.0	51.6	61.3	63.8	70.1	66.2	61.8	56.9	45.5	40.3		
		MCDB	40.6	46.1	48.8	65.2	74.3	74.5	85.0	75.0	67.5	61.1	47.9	44.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	36.2	38.8	41.3	47.6	58.7	61.4	66.9	63.8	59.1	50.4	42.9	37.6		
		MCDB	38.9	42.7	46.1	58.3	71.7	71.4	77.6	71.2	64.9	55.3	45.6	41.2		
	5%	WB	34.5	36.2	38.9	44.8	55.7	59.0	64.4	61.8	56.9	48.0	40.3	35.8		
		MCDB	36.1	39.9	43.0	52.8	66.9	68.2	74.3	68.8	62.4	52.6	43.1	39.0		
	10%	WB	33.1	34.2	36.8	42.3	52.6	56.8	62.1	59.8	54.7	45.2	38.2	34.1		
		MCDB	33.9	36.8	39.8	49.0	62.0	64.1	70.6	66.4	59.0	47.9	40.6	35.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.7	13.0	16.5	18.9	20.0	17.7	18.7	18.1	16.4	12.4	9.1	10.5		
		MCDBR	11.1	13.6	17.4	26.4	31.7	27.0	28.6	24.5	21.5	16.8	12.9	13.7		
		MCWBR	8.3	9.7	11.4	14.8	16.1	13.3	13.3	12.5	13.2	11.0	9.1	9.7		
		MCDBR	9.2	13.1	15.3	24.2	30.2	23.6	25.7	21.9	20.9	15.8	12.2	12.3		
	5% WB	MCWBR	7.1	9.7	10.6	14.1	16.0	12.5	13.0	12.4	13.5	11.0	9.2	9.1		
		MCWBR	7.1	9.7	10.6	14.1	16.0	12.5	13.0	12.4	13.5	11.0	9.2	9.1		
(40) Clear-Sky Solar Irradiance	taub		0.217	0.276	0.310	0.341	0.352	0.351	0.361	0.349	0.320	0.301	0.233	N/A		
	taud		2.031	2.190	2.189	2.246	2.393	2.442	2.433	2.463	2.528	2.436	2.122	N/A		
	Ebn at Noon		134	211	248	266	274	276	269	263	251	206	127	N/A		
	Edh at Noon		10	20	29	34	32	32	31	28	22	16	9	N/A		
(44) All-Sky Solar Radiation	RadAvg		62	250	688	1268	1505	1533	1464	1126	694	308	89	31		
	RadStd		8	33	75	91	93	144	152	120	69	40	13	2		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (47 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	-256	-320	N/A	N/A

Nomenclature: See separate page