

NORDOYAN FYR, Norway

WMO: 012620

Lat: 64.799N

Lon: 10.547E

Elev: 108

StdP: 14.64

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	18.1	21.6	9.9	9.2	19.1	13.0	10.7	22.7	53.3	38.0	50.4	37.4	24.9	120	0.971

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.7	67.2	59.4	64.5	57.8	62.3	56.7	60.3	65.9	58.6	63.3	57.1	61.2	12.9	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.5	70.8	62.7	56.0	66.9	61.2	54.7	63.8	59.7	26.6	66.3	25.5	63.5	24.5	61.3	68.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
48.6	43.6	39.0	DB	17.0	72.8	5.4	3.8	13.1	75.6	10.0	77.8	7.0	80.0	3.1	82.8
			WB	14.7	62.5	5.7	2.6	10.6	64.3	7.2	65.8	4.0	67.3	-0.2	69.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.6	35.3	34.6	36.2	40.9	46.5	50.9	55.9	56.7	52.7	46.4	40.7	37.3	
	DBStd	9.22	5.64	6.48	4.96	4.14	4.91	4.36	4.56	3.78	3.71	4.86	5.37	5.96	
	HDD50	2583	454	432	429	274	134	40	2	1	16	130	278	393	
	HDD65	7461	919	852	894	722	574	423	284	259	370	578	728	858	
	CDD50	599	0	0	0	1	25	66	186	208	96	17	0	0	
	CDD65	4	0	0	0	0	0	0	3	1	0	0	0	0	
	CDH74	5	0	0	0	0	0	0	5	0	0	0	0	0	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	19.9	24.8	23.9	22.0	17.5	16.3	15.0	14.4	15.0	19.0	21.9	23.6	25.7	
Precipitation	PrecAvg	56.6	5.7	5.2	5.4	3.5	2.8	3.7	3.3	3.7	5.6	5.9	5.5	6.3	
	PrecMax	70.9	13.3	12.1	12.1	7.5	5.0	7.1	7.2	6.7	12.7	9.6	10.8	11.3	
	PrecMin	40.1	0.3	1.2	2.2	1.1	1.3	0.8	1.3	0.8	1.6	1.6	0.9	1.9	
	PrecStd	7.8	3.1	2.6	2.5	1.6	0.9	1.5	1.5	1.6	3.0	2.0	3.1	2.5	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.6	45.5	46.3	55.0	64.2	66.9	72.9	70.2	62.8	57.8	51.8	48.4	
		MCWB	44.1	43.0	42.0	47.3	53.4	56.6	61.7	61.0	55.7	52.9	48.7	45.6	
	2%	DB	45.0	44.4	44.6	50.6	59.5	63.1	68.5	66.4	60.4	55.5	50.2	47.0	
		MCWB	42.9	42.2	42.0	45.0	51.1	55.6	60.8	59.4	54.9	51.5	47.6	44.4	
	5%	DB	43.9	43.3	43.7	48.1	56.1	59.8	64.9	64.3	58.8	54.0	48.7	45.9	
		MCWB	41.9	41.1	41.1	44.1	49.7	53.8	58.5	58.6	54.3	50.4	45.8	43.3	
	10%	DB	42.7	42.1	42.7	45.9	53.2	57.2	62.3	62.2	57.5	52.7	47.5	44.8	
		MCWB	40.7	39.7	40.1	42.4	48.0	52.4	57.0	57.3	53.6	49.4	44.4	42.0	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.9	44.0	44.0	48.2	55.0	58.6	63.9	61.8	56.9	54.7	50.3	46.8
			MCDB	45.9	44.5	44.6	52.3	63.0	65.6	68.9	67.5	60.1	55.9	51.1	47.7
2%		WB	43.9	42.6	42.7	46.1	52.0	56.3	60.9	60.2	55.7	52.7	48.1	44.9	
		MCDB	44.9	43.6	43.9	49.8	58.4	62.3	67.4	65.4	58.7	54.7	49.3	46.4	
5%		WB	42.5	41.4	41.5	44.4	50.1	54.6	58.7	58.9	54.9	51.3	46.4	43.4	
		MCDB	43.8	42.9	43.1	47.2	55.6	59.2	63.8	63.4	57.9	53.7	48.3	45.2	
10%		WB	41.2	40.0	40.3	43.2	48.2	53.1	57.1	57.5	54.0	49.9	44.7	42.0	
		MCDB	42.8	41.8	42.3	45.5	52.8	56.9	61.3	61.4	57.0	52.5	47.2	44.3	
Mean Daily Temperature Range	5% DB	MDBR	5.3	5.4	5.3	5.6	6.5	5.8	6.2	5.7	4.8	4.6	5.0	5.4	
		MCDBR	5.7	5.7	5.7	7.8	11.3	10.3	11.6	9.2	6.1	5.1	5.3	6.4	
		MCWBR	5.6	5.8	5.6	4.7	5.8	5.8	6.0	4.8	4.1	4.5	5.6	6.4	
	5% WB	MCDBR	4.9	5.8	5.8	7.1	11.1	9.7	10.7	8.6	5.8	5.0	5.8	5.8	
		MCWBR	5.4	6.2	6.0	5.1	6.0	6.2	6.1	5.2	4.5	4.7	6.4	6.3	
Clear-Sky Solar Irradiance	taub	0.368	0.312	0.336	0.357	0.352	0.352	0.359	0.348	0.337	0.313	0.345	0.363		
	taud	2.498	2.226	2.315	2.375	2.455	2.489	2.496	2.520	2.519	2.372	2.488	2.450		
	Ebn at Noon	83	182	234	259	272	274	268	261	238	184	83	28		
	Edh at Noon	8	18	25	30	30	30	29	26	21	15	7	4		
All-Sky Solar Radiation	RadAvg	31	165	530	1067	1468	1580	1476	1136	640	269	57	11		
	RadStd	4	27	88	102	92	193	154	113	78	43	10	1		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (28 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page