

STEINKJER, Norway

WMO: 012770

Lat: 64.022N

Lon: 11.451E

Elev: 80

StdP: 100.37

Time Zone: 1.00 (EUC)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.5	-13.1	-18.6	0.7	-14.5	-16.5	0.9	-11.9	8.4	3.2	7.4	2.6	1.7	90	0.590

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.4	26.0	17.5	24.0	16.4	22.1	15.7	18.5	24.4	17.4	22.7	16.3	21.1	2.1	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.1	11.5	21.4	15.0	10.7	20.0	14.0	10.1	18.5	52.6	24.5	49.1	22.6	45.8	21.1	22.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.1	5.9	5.0	-17.6	29.2	2.6	2.1	-19.5	30.7	-21.0	32.0	-22.4	33.2	-24.3	34.7		
(5)			-17.9	20.6	2.6	1.2	-19.8	21.5	-21.3	22.2	-22.7	22.9	-24.6	23.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	5.8	-2.6	-2.3	0.0	4.7	9.4	12.5	15.7	14.9	11.0	5.4	1.0	-1.1	(6)
(7)		DBStd	7.54	4.71	4.77	4.04	3.12	3.95	3.49	3.34	3.08	2.87	3.31	4.01	4.66	(7)
(8)		HDD10.0	2064	392	343	309	163	60	12	0	2	22	146	270	345	(8)
(9)		HDD18.3	4615	651	577	567	409	279	177	97	114	221	400	520	603	(9)
(10)		CDD10.0	516	0	0	0	4	40	88	176	152	51	4	0	0	(10)
(11)		CDD18.3	25	0	0	0	0	1	3	14	7	0	0	0	0	(11)
(12)		CDH23.3	234	0	0	0	0	11	39	131	53	0	0	0	0	(12)
(13)		CDH26.7	36	0	0	0	0	1	6	26	3	0	0	0	0	(13)
(14)	Wind	WSAvg	2.1	2.2	2.2	2.4	2.3	2.2	1.8	1.7	1.9	1.9	2.0	2.2	(14)	
(15)	Precipitation	PrecAvg	1274	135	120	115	76	60	77	78	83	123	134	124	147	(15)
(16)		PrecMax	1658	301	306	267	153	97	151	174	141	312	224	257	277	(16)
(17)		PrecMin	833	11	23	38	20	24	9	25	18	28	44	17	54	(17)
(18)		PrecStd	183	73	63	61	35	19	34	34	35	71	47	72	61	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.3	7.6	10.2	19.1	24.7	27.5	29.7	26.9	21.4	16.1	10.4	8.3	(19)
(20)			MCWB	4.5	4.5	5.4	10.3	14.7	17.3	19.1	17.3	15.2	11.3	8.6	6.0	(20)
(21)		2%	DB	5.2	6.2	7.8	15.3	22.0	23.8	26.7	24.8	18.8	13.6	8.6	6.8	(21)
(22)			MCWB	3.6	3.9	4.6	8.8	13.7	15.5	17.9	17.5	13.9	10.4	6.9	4.8	(22)
(23)		5%	DB	4.1	4.9	6.5	12.6	19.3	21.3	24.5	22.8	17.2	11.6	7.2	5.6	(23)
(24)			MCWB	2.6	2.9	4.0	7.3	12.4	14.4	17.2	16.5	12.9	9.2	5.5	4.0	(24)
(25)		10%	DB	2.8	3.5	5.3	10.0	16.4	19.2	22.5	20.8	15.5	10.0	6.1	4.4	(25)
(26)			MCWB	1.5	1.9	3.2	5.8	10.8	13.6	16.4	15.7	12.1	8.2	4.7	2.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.2	5.4	6.6	11.1	16.0	18.1	20.3	19.6	16.0	12.4	8.8	6.7	(27)
(28)			MCD B	6.1	7.0	8.6	17.9	23.0	24.8	26.5	25.3	20.0	14.8	9.6	7.7	(28)
(29)		2%	WB	4.1	4.4	5.2	9.3	14.2	16.6	19.0	18.1	14.6	10.6	7.2	5.2	(29)
(30)			MCD B	4.9	5.8	7.0	14.6	20.4	22.7	25.5	23.1	17.8	13.2	8.3	6.4	(30)
(31)		5%	WB	2.7	3.2	4.4	7.7	12.8	15.3	17.8	17.1	13.5	9.6	5.9	4.1	(31)
(32)			MCD B	3.7	4.5	6.2	11.7	19.0	20.1	23.5	21.7	16.3	11.4	7.0	5.3	(32)
(33)		10%	WB	1.7	2.1	3.4	6.4	11.2	13.8	16.6	16.0	12.6	8.4	4.7	3.1	(33)
(34)			MCD B	2.6	3.5	5.2	9.4	16.1	18.6	21.7	20.1	15.0	9.8	5.9	4.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.8	5.5	7.2	8.2	9.0	8.9	9.4	8.8	7.3	6.0	4.8	5.0	(35)
(36)			MCDBR	5.0	5.9	7.5	12.4	13.8	13.8	13.9	12.3	9.9	7.6	5.7	5.7	(36)
(37)			MCWBR	4.0	4.3	5.3	7.3	7.3	7.4	6.9	6.3	5.8	5.1	4.4	4.5	(37)
(38)		5% WB	MCD BR	4.6	5.4	6.9	10.8	13.1	12.8	12.8	11.1	9.0	6.7	5.5	5.3	(38)
(39)			MCWBR	3.8	4.4	5.2	6.7	7.2	7.3	7.0	6.2	5.8	4.8	4.6	4.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.227	0.291	0.322	0.347	0.348	0.348	0.355	0.343	0.327	0.304	0.353	0.359	(40)	
(41)		taud	2.012	2.216	2.290	2.373	2.441	2.472	2.472	2.499	2.533	2.426	2.621	2.585	(41)	
(42)		Ebn at Noon	342	621	764	831	865	871	852	831	772	620	329	162	(42)	
(43)		Edh at Noon	27	58	82	95	97	96	94	83	66	48	24	15	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.13	0.61	1.80	3.53	4.55	4.82	4.62	3.55	2.07	0.90	0.22	0.06	(44)	
(45)		RadStd	0.02	0.10	0.29	0.31	0.30	0.55	0.47	0.39	0.23	0.13	0.04	0.01	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (40 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	-142	-178	N/A	N/A

Nomenclature: See separate page