

SOLENET, Norway

WMO: 012870

Lat: 62.680N

Lon: 11.817E

Elev: 2451

StdP: 13.44

Time Zone: 1.00 (EUC)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -10.5	(c) -6.2	(d) -15.0	(e) 2.7	(f) -10.3	(g) -10.3	(h) 3.4	(i) -5.7	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 16.9	(c) 72.5	(d) 57.6	(e) 68.3	(f) 55.7	(g) 64.6	(h) 54.2	(i) 60.1	(j) 69.5	(k) 57.8	(l) 65.4	(m) 55.6	(n) 62.4	(o) N/A	(p) N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
56.2	73.6	62.8	54.3	68.6	60.9	52.3	63.8	58.7	27.6	70.1	26.0	65.3	24.5	62.4	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) N/A	(b) N/A	(c) N/A	(e) -16.2	(f) 76.3	(g) 6.2	(h) 4.0	(i) -20.6	(j) 79.2	(k) -24.3	(l) 81.5	(m) -27.8	(n) 83.8	(o) -32.3	(p) 86.7		
(4) N/A	(5) N/A	(6) N/A	(e) -16.6	(f) 61.8	(g) 6.4	(h) 2.9	(i) -21.2	(j) 63.8	(k) -24.9	(l) 65.5	(m) -28.5	(n) 67.1	(o) -33.2	(p) 69.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	34.3	16.4	20.6	23.3	31.8	40.9	47.2	53.7	50.7	44.7	34.4	25.9	20.8		
	DBStd	14.64	10.92	9.02	8.33	7.06	8.17	6.34	6.60	4.95	5.55	6.24	8.14	9.35		
	HDD50	6041	1040	824	827	546	305	127	36	52	173	484	723	904		
	HDD65	11213	1505	1244	1292	996	746	533	354	445	608	948	1173	1369		
	CDD50	307	0	0	0	0	24	44	150	73	15	1	0	0		
	CDD65	3	0	0	0	0	0	0	3	0	0	0	0	0		
	CDH74	58	0	0	0	0	1	4	53	0	0	0	0	0		
	CDH80	2	0	0	0	0	0	0	2	0	0	0	0	0		
	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	PrecAvg	27.7	2.2	1.9	1.8	1.3	2.0	3.0	3.5	3.4	2.6	2.3	1.9	1.9		
(15) Precipitation	PrecMax	35.1	5.3	3.1	4.3	3.9	3.4	5.6	6.2	5.7	5.6	4.4	5.6	4.3		
	PrecMin	21.9	0.2	0.1	0.7	0.4	0.9	1.2	1.3	1.4	0.9	0.6	0.2	0.7		
	PrecStd	3.3	1.4	0.9	0.9	0.7	0.7	1.1	1.3	1.2	1.3	0.8	1.4	0.8		
	PrecStd	3.3	1.4	0.9	0.9	0.7	0.7	1.1	1.3	1.2	1.3	0.8	1.4	0.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.9	39.6	42.7	54.2	72.0	73.9	79.2	70.1	64.8	55.9	45.5	39.7		
		MCWB	34.3	35.8	36.0	42.7	53.8	55.4	60.6	57.7	53.1	53.2	42.2	37.5		
	2%	DB	34.9	35.9	39.0	49.9	66.4	68.4	74.9	66.3	60.8	49.3	41.0	37.1		
		MCWB	33.3	33.0	35.0	40.0	52.3	53.8	60.2	55.3	52.2	45.4	39.0	35.6		
	5%	DB	32.6	33.5	36.5	45.9	61.2	63.3	70.8	63.2	56.7	45.9	38.4	34.8		
		MCWB	31.1	31.5	33.2	37.7	50.5	51.8	58.4	54.4	50.5	42.7	36.8	33.3		
	10%	DB	30.3	31.8	34.4	42.4	55.4	58.8	66.5	59.9	53.9	43.3	35.9	32.2		
		MCWB	29.0	30.1	31.4	36.2	47.8	50.0	56.7	53.3	49.4	40.7	34.2	30.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	35.0	36.4	37.7	43.6	56.2	57.6	63.7	59.9	55.2	53.6	42.7	38.2		
		MCDB	37.3	39.3	40.4	52.7	65.1	68.2	73.1	65.2	60.5	56.9	45.2	38.9		
	2%	WB	33.3	33.6	35.8	40.7	53.8	55.0	61.6	57.5	53.2	46.2	39.4	35.9		
		MCDB	34.7	35.3	38.7	47.9	64.4	64.9	72.2	63.4	57.8	48.0	40.7	36.9		
	5%	WB	31.4	31.9	33.6	38.6	50.9	53.0	59.7	55.7	51.5	43.3	37.1	33.3		
		MCDB	32.6	33.3	35.9	44.5	60.3	61.8	69.5	60.9	56.2	45.6	38.3	34.6		
	10%	WB	29.0	30.0	31.6	36.6	47.8	50.9	57.6	53.7	49.6	40.7	34.4	30.8		
		MCDB	30.2	31.7	34.1	41.8	55.1	57.5	65.5	58.6	53.3	43.2	35.7	32.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.0	10.4	13.9	14.8	15.3	15.8	16.9	15.5	13.6	9.9	9.1	10.8		
		MCDBR	9.9	9.8	13.5	19.2	25.3	25.2	24.1	20.3	19.0	13.9	9.8	11.0		
		MCWBR	9.0	8.4	10.0	10.8	13.4	12.2	11.4	11.1	11.4	10.5	8.3	10.4		
	5% WB	MCDBR	9.7	9.5	12.2	16.3	23.5	22.2	22.5	17.1	17.0	12.1	9.4	11.3		
		MCWBR	8.9	8.4	9.3	9.2	12.7	11.4	10.7	10.1	10.8	9.9	8.4	10.9		
(40) Clear-Sky Solar Irradiance	taub	0.193	0.249	0.279	0.309	0.322	0.319	0.330	0.321	0.294	0.275	0.204	0.171			
	taud	2.044	2.233	2.237	2.256	2.415	2.501	2.481	2.498	2.560	2.458	2.101	1.955			
	Ebn at Noon	157	229	264	278	285	287	280	274	263	221	148	96			
	Edh at Noon	10	19	28	34	32	30	30	27	21	15	9	5			
(44) All-Sky Solar Radiation	RadAvg	69	266	729	1317	1529	1564	1467	1131	708	312	94	35			
	RadStd	8	35	65	94	96	138	160	110	71	41	14	3			

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (46 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	-256	-320	N/A	N/A

Nomenclature: See separate page