

STRYN, Norway

WMO: 013210

Lat: 61.916N

Lon: 6.558E

Elev: 208

StdP: 98.85

Time Zone: 1.00 (EUC)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.9	-11.3	-17.6	0.8	-9.1	-15.7	1.0	-8.3	6.9	2.3	6.1	2.0	1.3	150	0.588

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.4	25.9	15.9	23.5	14.9	21.5	14.2	17.1	23.0	16.1	21.4	15.2	19.8	2.2	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
14.9	10.8	17.9	14.0	10.3	17.3	13.2	9.7	16.8	48.7	23.3	45.7	21.5	43.2	20.0	19.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.1	4.3	3.6	-14.4	28.4	2.2	1.9	-16.0	29.8	-17.3	30.9	-18.6	32.0	-20.2	33.4		
(5)			-14.3	18.2	2.6	1.0	-16.2	18.9	-17.7	19.5	-19.1	20.1	-21.0	20.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	6.0	-1.3	-0.9	1.1	5.0	9.0	12.2	15.2	13.8	10.4	5.8	1.7	-0.6	(6)
(7)		DBStd	6.86	4.17	4.29	3.35	3.44	3.88	2.90	3.36	2.81	3.06	3.69	4.21	4.43	(7)
(8)		HDD10.0	1915	351	307	274	154	67	10	1	3	32	137	250	328	(8)
(9)		HDD18.3	4517	609	540	533	399	290	184	109	141	238	388	499	587	(9)
(10)		CDD10.0	455	0	0	0	4	36	77	163	122	44	8	1	0	(10)
(11)		CDD18.3	16	0	0	0	0	1	1	12	2	0	0	0	0	(11)
(12)		CDH23.3	213	0	0	0	0	13	36	148	16	0	0	0	0	(12)
(13)		CDH26.7	37	0	0	0	0	1	2	34	1	0	0	0	0	(13)
(14)	Wind	WSAvg	1.6	1.7	1.6	1.6	1.7	1.8	1.6	1.4	1.5	1.5	1.5	1.6	(14)	
(15)	Precipitation	PrecAvg	1591	171	122	127	71	56	73	84	100	197	189	196	217	(15)
(16)		PrecMax	2596	604	466	664	185	172	192	175	163	363	508	575	550	(16)
(17)		PrecMin	1053	12	7	3	17	16	8	18	20	42	50	27	15	(17)
(18)		PrecStd	406	137	97	128	47	34	43	41	38	82	105	126	131	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.3	10.3	11.2	18.8	25.0	26.6	29.9	25.3	21.3	18.5	13.0	10.0	(19)
(20)			MCWB	4.0	5.5	6.0	9.9	14.6	14.9	17.8	15.3	14.4	11.4	9.3	6.2	(20)
(21)		2%	DB	6.8	7.5	8.4	16.8	22.1	24.1	27.4	23.0	18.7	15.2	10.6	7.7	(21)
(22)			MCWB	3.1	3.9	4.2	8.9	12.6	14.0	17.1	14.9	12.4	9.7	6.9	4.3	(22)
(23)		5%	DB	4.9	6.0	6.9	13.9	19.7	21.3	24.6	21.2	17.1	12.7	9.2	6.4	(23)
(24)			MCWB	2.5	2.4	3.5	7.4	11.4	12.9	16.1	14.6	11.9	8.7	6.2	3.8	(24)
(25)		10%	DB	3.6	4.5	5.8	11.4	17.0	19.0	22.1	19.3	15.5	11.2	7.6	4.9	(25)
(26)			MCWB	1.6	1.8	2.8	6.3	10.2	12.3	15.5	14.1	11.4	7.9	5.4	2.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.2	6.3	6.7	10.9	15.0	15.9	18.8	17.2	15.5	12.5	9.5	6.9	(27)
(28)			MCDWB	7.0	9.0	9.1	17.0	23.7	24.2	27.4	22.2	18.4	15.9	11.7	8.9	(28)
(29)		2%	WB	3.8	4.5	5.4	9.3	13.4	14.7	17.8	16.2	14.1	11.0	8.2	5.7	(29)
(30)			MCDWB	5.6	6.8	7.5	14.6	20.3	21.7	24.9	20.6	16.9	14.2	9.7	7.4	(30)
(31)		5%	WB	3.0	3.3	4.3	8.0	12.0	13.8	16.9	15.6	13.0	9.7	6.9	4.4	(31)
(32)			MCDWB	4.5	5.2	6.0	13.3	18.4	19.4	22.8	19.6	15.7	12.4	8.6	5.8	(32)
(33)		10%	WB	2.2	2.2	3.4	6.9	10.8	12.8	15.9	14.8	12.0	8.5	5.6	3.2	(33)
(34)			MCDWB	3.4	4.0	5.2	11.2	16.6	17.6	21.4	18.3	14.6	10.7	7.5	4.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.6	5.8	7.5	9.3	10.1	9.8	9.4	8.6	7.5	6.6	4.7	4.5	(35)
(36)			MCDBR	5.3	6.1	8.4	13.5	14.8	15.3	14.5	11.9	10.1	8.2	6.2	6.0	(36)
(37)			MCWBR	3.7	3.5	5.1	7.0	6.9	6.7	5.7	5.4	5.3	4.8	3.9	4.1	(37)
(38)		5% WB	MCDWR	4.7	5.7	7.1	11.9	14.0	12.4	12.7	10.1	8.5	7.3	5.8	6.0	(38)
(39)			MCWBR	3.6	4.0	4.7	6.6	6.8	5.9	5.4	5.1	5.1	4.9	4.3	4.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.234	0.283	0.314	0.343	0.347	0.345	0.357	0.349	0.325	0.302	0.244	N/A	(40)	
(41)		taud	2.053	2.189	2.193	2.213	2.334	2.411	2.423	2.443	2.498	2.412	2.128	N/A	(41)	
(42)		Ebn at Noon	452	678	789	840	871	880	858	834	792	667	436	N/A	(42)	
(43)		Edh at Noon	36	66	94	113	109	104	100	90	71	53	33	N/A	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.18	0.67	1.81	3.46	4.64	4.84	4.58	3.50	2.11	0.97	0.28	0.11	(44)	
(45)		RadStd	0.04	0.17	0.35	0.51	0.52	0.50	0.44	0.35	0.29	0.15	0.06	0.01	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (38 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page