

KVAMSKOGEN-JONSHOGDI, Norway

WMO: 013270

Lat: 60.3886N

Lon: 5.9639E

Elev: 1493

StdP: 13.92

Time Zone: 1.00 (EUC)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.8	12.1	-0.1	5.8	14.3	3.3	6.9	14.1	36.1	29.0	32.0	32.3	2.4	190	0.682

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.1	74.2	59.8	70.1	57.8	66.1	56.0	61.4	70.7	59.6	67.3	57.6	64.1	7.4	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
57.7	75.2	64.4	55.9	70.3	62.5	54.3	66.4	60.5	28.1	70.5	26.7	67.6	25.4	64.5	67.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
25.3	20.9	17.5	DB	7.0	78.5	3.7	4.5	4.3	81.8	2.1	84.4	0.0	86.9	-2.7	90.2
			WB	5.9	63.4	3.8	2.4	3.1	65.1	0.9	66.5	-1.2	67.8	-4.0	69.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	40.8	28.0	28.6	31.9	38.3	45.5	51.5	55.9	53.8	49.0	41.4	34.4	30.1	(6)
	DBStd	11.59	6.69	6.78	5.95	5.95	7.24	5.56	6.08	4.45	5.08	5.54	6.63	7.40	(7)
	HDD50	3876	683	599	561	352	184	44	9	12	76	271	469	616	(8)
	HDD65	8854	1148	1019	1026	800	606	406	291	348	479	731	919	1081	(9)
	CDD50	508	0	0	0	2	43	89	193	129	47	5	0	0	(10)
	CDD65	10	0	0	0	0	0	0	10	0	0	0	0	0	(11)
	CDH74	111	0	0	0	0	6	10	93	2	0	0	0	0	(12)
	CDH80	10	0	0	0	0	0	0	10	0	0	0	0	0	(13)
(14) Wind	WSAvg	6.9	8.2	7.0	7.4	6.0	6.5	6.8	6.2	6.1	7.1	7.2	6.7	7.4	(14)
(15) Precipitation	PrecAvg	110.8	12.3	10.6	10.2	5.9	4.8	6.1	6.7	7.6	10.3	12.1	11.3	13.0	(15)
	PrecMax	157.0	25.7	25.6	31.1	11.9	8.9	14.1	10.8	12.0	19.4	25.7	23.1	24.0	(16)
	PrecMin	70.3	0.0	0.0	0.2	0.9	0.0	1.7	0.9	2.5	1.9	2.7	1.4	2.3	(17)
	PrecStd	19.0	6.6	6.5	6.3	2.8	2.6	2.9	2.2	3.0	5.6	5.8	5.9	6.8	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.3	43.1	50.2	60.7	73.5	75.6	81.2	72.7	67.7	60.2	51.1	46.0	(19)
		MCWB	39.9	38.1	42.2	48.4	55.9	58.2	63.2	60.3	57.6	52.5	45.8	42.9	(20)
	2%	DB	40.1	40.5	43.5	56.4	67.4	71.6	76.4	68.3	62.8	54.7	47.7	43.4	(21)
		MCWB	38.1	37.7	38.3	45.6	54.1	56.7	61.8	57.7	54.4	48.3	44.0	41.1	(22)
	5%	DB	38.2	38.9	40.8	52.2	63.2	66.6	72.1	64.7	59.9	51.7	45.5	41.1	(23)
		MCWB	36.5	36.3	37.2	43.2	51.3	54.1	60.3	56.1	52.7	47.4	42.3	39.1	(24)
	10%	DB	36.3	37.2	39.0	48.2	59.1	62.4	66.9	61.9	57.2	49.0	43.4	39.0	(25)
		MCWB	34.7	34.9	36.0	41.1	49.1	52.5	58.1	55.0	51.4	44.8	40.3	37.0	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	40.7	40.2	43.0	49.2	58.2	60.1	65.5	61.9	59.2	54.0	47.0	44.0	(27)
		MCDB	41.8	41.7	49.0	58.4	70.4	72.5	77.0	70.1	65.0	56.8	49.4	45.4	(28)
	2%	WB	38.9	38.6	40.0	46.5	55.0	57.9	63.0	59.4	56.0	50.6	44.9	41.4	(29)
		MCDB	39.9	39.8	42.6	54.0	65.4	68.0	74.4	65.6	60.4	53.6	47.0	42.8	(30)
	5%	WB	36.7	36.9	38.2	44.1	52.4	55.6	60.9	57.6	54.0	48.1	43.1	39.4	(31)
		MCDB	37.8	38.2	40.0	51.3	61.4	63.7	69.1	62.6	58.6	51.0	45.4	40.7	(32)
	10%	WB	34.9	35.2	36.4	41.7	49.9	53.6	59.2	56.0	52.1	45.7	40.4	37.3	(33)
		MCDB	36.1	36.7	38.4	47.2	58.0	60.8	66.4	60.3	56.0	48.3	42.7	38.8	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	8.2	9.4	10.2	12.9	14.4	14.1	13.1	12.0	10.9	10.0	8.2	7.7	(35)
		MCDBR	8.7	9.1	11.0	18.3	21.5	22.4	21.7	16.9	15.5	14.2	9.9	9.0	(36)
		MCWBR	7.3	7.1	7.4	10.6	11.2	10.4	9.5	8.7	8.5	9.2	7.7	7.6	(37)
	5% WB	MCDBR	8.2	8.4	10.2	16.4	20.2	18.9	19.6	14.6	13.9	11.2	9.9	9.1	(38)
		MCWBR	7.4	7.3	7.6	10.0	10.7	9.7	9.4	8.5	8.3	8.6	8.4	8.2	(39)
(40) Clear-Sky Solar Irradiance	taub		0.246	0.284	0.311	0.342	0.341	0.337	0.350	0.344	0.324	0.304	0.259	0.221	(40)
	taud		2.135	2.263	2.285	2.284	2.420	2.472	2.455	2.466	2.521	2.475	2.228	2.032	(41)
	Ebn at Noon		164	228	259	271	281	284	276	269	256	222	159	120	(42)
	Edh at Noon		13	21	28	34	32	31	31	29	23	17	12	9	(43)
(44) All-Sky Solar Radiation	RadAvg		76	244	613	1159	1541	1598	1464	1133	705	335	109	49	(44)
	RadStd		16	55	107	158	202	192	160	107	85	49	16	7	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (41 neighbors)	+0.67	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page