

KVAMSKOGEN-JONSHOGDI, Norway

WMO: 013270

Lat: 60.3886N

Lon: 5.9639E

Elev: 455

StdP: 95.98

Time Zone: 1.00 (EUC)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.3	-11.0	-17.8	0.8	-9.8	-15.9	1.0	-9.9	16.1	-1.7	14.3	0.1	1.1	190	0.682

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 7.3	(c) 23.5	(d) 15.4	(e) 21.2	(f) 14.3	(g) 18.9	(h) 13.3	(i) 16.3	(j) 21.5	(k) 15.3	(l) 19.6	(m) 14.2	(n) 17.8	(o) 3.3	(p) 120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
14.3	10.7	18.0	13.3	10.0	17.0	12.4	9.5	15.8	47.4	21.4	44.3	19.8	41.2	18.0	19.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 11.3	(b) 9.4	(c) 7.8	(e) -13.9	(f) 25.8	(g) 2.1	(h) 2.5	(i) -15.4	(j) 27.6	(k) -16.6	(l) 29.1	(m) -17.8	(n) 30.5	(o) -19.3	(p) 32.3		
(a) 11.3	(b) 9.4	(c) 7.8	(e) -14.5	(f) 17.5	(g) 2.1	(h) 1.3	(i) -16.0	(j) 18.4	(k) -17.3	(l) 19.2	(m) -18.5	(n) 19.9	(o) -20.0	(p) 20.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	4.9	-2.2	-1.9	-0.1	3.5	7.5	10.8	13.3	12.1	9.5	5.2	1.3	-1.0
	DBStd	6.44	3.72	3.77	3.31	3.30	4.02	3.09	3.38	2.47	2.82	3.08	3.68	4.11
	HDD10.0	2153	379	333	312	196	102	24	5	7	42	151	261	342
	HDD18.3	4919	638	566	570	444	337	226	162	193	266	406	511	601
	CDD10.0	282	0	0	0	1	24	49	107	72	26	3	0	0
	CDD18.3	6	0	0	0	0	0	0	6	0	0	0	0	0
	CDH23.3	62	0	0	0	0	3	6	52	1	0	0	0	0
	CDH26.7	6	0	0	0	0	0	0	6	0	0	0	0	0
Wind	WSAvg	3.1	3.7	3.1	3.3	2.7	2.9	3.0	2.8	2.7	3.2	3.2	3.0	3.3
Precipitation	PrecAvg	2814	312	270	258	150	123	156	169	192	261	307	288	329
	PrecMax	3989	654	651	789	303	227	359	275	306	494	653	587	610
	PrecMin	1785	0	0	6	23	0	44	24	63	49	68	35	58
	PrecStd	483	167	166	160	70	66	73	57	77	141	147	150	172
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.7	6.2	10.1	16.0	23.0	24.2	27.3	22.6	19.9	15.7	10.6	7.8
		MCWB	4.4	3.4	5.7	9.1	13.3	14.5	17.3	15.7	14.2	11.4	7.7	6.1
	2%	DB	4.5	4.7	6.4	13.6	19.7	22.0	24.7	20.1	17.1	12.6	8.7	6.3
		MCWB	3.4	3.2	3.5	7.5	12.3	13.7	16.6	14.3	12.5	9.1	6.7	5.0
	5%	DB	3.4	3.8	4.9	11.2	17.3	19.2	22.3	18.2	15.5	11.0	7.5	5.1
		MCWB	2.5	2.4	2.9	6.2	10.7	12.3	15.7	13.4	11.5	8.6	5.7	4.0
	10%	DB	2.4	2.9	3.9	9.0	15.0	16.9	19.4	16.6	14.0	9.4	6.3	3.9
		MCWB	1.5	1.6	2.2	5.0	9.5	11.4	14.5	12.8	10.8	7.1	4.6	2.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.8	4.6	6.1	9.6	14.6	15.6	18.6	16.6	15.1	12.2	8.3	6.7
		MCDB	5.5	5.4	9.4	14.7	21.3	22.5	25.0	21.2	18.3	13.8	9.7	7.4
	2%	WB	3.8	3.7	4.4	8.1	12.8	14.4	17.2	15.2	13.4	10.3	7.2	5.2
		MCDB	4.4	4.3	5.9	12.2	18.6	20.0	23.6	18.7	15.8	12.0	8.3	6.0
	5%	WB	2.6	2.7	3.4	6.7	11.3	13.1	16.1	14.2	12.2	8.9	6.1	4.1
		MCDB	3.2	3.4	4.5	10.7	16.3	17.6	20.6	17.0	14.8	10.6	7.5	4.8
	10%	WB	1.6	1.8	2.4	5.4	10.0	12.0	15.1	13.3	11.2	7.6	4.6	2.9
		MCDB	2.3	2.6	3.6	8.5	14.4	16.0	19.1	15.7	13.3	9.0	5.9	3.8
Mean Daily Temperature Range	5% DB	MDBR	4.6	5.2	5.6	7.2	8.0	7.9	7.3	6.7	6.0	5.6	4.5	4.3
		MCDBR	4.8	5.1	6.1	10.2	11.9	12.4	12.0	9.4	8.6	7.9	5.5	5.0
		MCWBR	4.0	3.9	4.1	5.9	6.2	5.8	5.3	4.8	4.7	5.1	4.3	4.2
	5% WB	MCDBR	4.6	4.7	5.6	9.1	11.2	10.5	10.9	8.1	7.7	6.2	5.5	5.1
		MCWBR	4.1	4.1	4.2	5.5	6.0	5.4	5.2	4.7	4.6	4.8	4.7	4.5
Clear-Sky Solar Irradiance	taub	0.246	0.284	0.311	0.342	0.341	0.337	0.350	0.344	0.324	0.304	0.259	0.221	
	taud	2.135	2.263	2.285	2.284	2.420	2.472	2.455	2.466	2.521	2.475	2.228	2.032	
	Ebn at Noon	517	718	816	854	886	895	871	848	808	701	502	377	
	Edh at Noon	41	66	89	108	102	99	98	90	72	54	37	28	
All-Sky Solar Radiation	RadAvg	0.24	0.77	1.93	3.65	4.86	5.04	4.62	3.57	2.22	1.06	0.34	0.15	
	RadStd	0.05	0.17	0.34	0.50	0.64	0.60	0.51	0.34	0.27	0.16	0.05	0.02	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (41 neighbors)		+0.37	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page