

FET I EIDFJORD, Norway

WMO: 013400

Lat: 60.4083N

Lon: 7.2797E

Elev: 737

StdP: 92.78

Time Zone: 1.00 (EUC)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-17.1	-15.4	-22.0	0.6	-15.5	-20.0	0.7	-15.2	14.5	-7.0	13.4	-6.4	3.4	130	0.746

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.3	22.0	13.5	19.9	13.0	17.9	12.2	14.7	19.9	13.7	18.4	12.8	16.9	3.1	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
12.5	9.8	16.2	11.6	9.3	15.6	10.7	8.8	14.7	43.4	19.7	40.7	18.5	38.3	16.9	17.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.9	10.3	8.9	-20.3	23.6	1.6	1.6	-21.4	24.7	-22.3	25.6	-23.2	26.5	-24.3	27.6
			-20.4	15.9	1.7	1.3	-21.6	16.8	-22.6	17.5	-23.5	18.2	-24.7	19.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	2.8	-5.1	-5.0	-3.1	1.1	5.7	9.3	12.0	11.0	8.0	3.3	-1.0	-3.6		
	DBStd	7.24	4.62	4.71	4.62	3.56	3.71	3.07	3.35	2.58	3.07	3.52	4.32	4.82		
	HDD10.0	2823	469	421	407	268	142	48	16	19	76	208	329	421		
	HDD18.3	5684	727	654	666	518	391	270	197	228	310	465	579	679		
	CDD10.0	182	0	0	0	0	9	28	79	50	15	1	0	0		
	CDD18.3	2	0	0	0	0	0	0	2	0	0	0	0	0		
	CDH23.3	19	0	0	0	0	1	1	17	1	0	0	0	0		
	CDH26.7	1	0	0	0	0	0	0	1	0	0	0	0	0		
(14) Wind	WSAvg	3.7	4.8	4.3	4.1	3.7	3.4	3.1	2.9	2.9	3.3	3.9	4.3	4.3		
(15) Precipitation	PrecAvg	1103	120	105	101	56	51	63	84	87	103	106	103	124		
	PrecMax	1533	258	238	419	125	103	139	156	154	197	215	301	319		
	PrecMin	598	0	0	0	12	11	16	38	32	31	26	0	0		
	PrecStd	225	75	71	84	30	22	34	29	31	45	50	70	91		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.5	5.1	6.8	11.8	20.9	22.6	25.2	21.8	19.2	14.3	9.3	5.9		
		MCWB	2.6	2.9	2.9	6.0	11.5	12.6	15.2	13.8	12.1	10.6	6.9	4.1		
	2%	DB	3.2	3.0	5.0	9.3	17.2	20.6	23.0	19.4	16.2	11.3	7.1	4.4		
		MCWB	1.8	1.6	2.3	5.1	10.2	12.0	14.7	13.0	11.4	7.8	5.1	2.9		
	5%	DB	2.1	1.9	3.6	7.5	14.6	17.9	20.9	17.5	14.5	9.9	5.8	3.1		
		MCWB	0.7	0.6	1.7	4.1	8.6	10.7	14.0	12.4	10.7	7.2	4.1	1.8		
	10%	DB	0.9	0.8	2.4	6.1	11.9	15.7	18.6	15.8	12.8	8.4	4.4	2.1		
		MCWB	-0.3	-0.6	0.7	3.3	7.4	9.9	13.3	11.7	9.9	6.1	2.9	0.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.1	2.9	3.7	6.7	12.4	13.7	16.5	14.7	13.4	10.8	7.1	4.4		
		MCDB	4.0	4.2	5.8	10.2	18.9	19.7	22.8	19.3	17.4	13.8	9.0	5.6		
	2%	WB	2.1	2.0	2.8	5.4	10.6	12.6	15.4	13.9	12.0	8.6	5.5	3.1		
		MCDB	3.1	3.0	4.3	8.6	16.4	18.8	21.2	18.0	15.2	10.7	6.9	4.2		
	5%	WB	0.8	0.8	2.0	4.5	9.0	11.5	14.5	13.1	11.0	7.5	4.3	2.0		
		MCDB	1.8	1.6	3.4	7.3	13.6	16.8	19.7	16.5	13.9	9.5	5.7	2.8		
	10%	WB	-0.2	-0.3	0.7	3.5	7.6	10.4	13.5	12.2	10.0	6.3	3.0	1.0		
		MCDB	0.7	0.6	2.2	5.9	11.5	14.7	18.1	15.2	12.7	8.1	4.3	1.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.0	5.3	6.1	6.8	7.7	8.8	8.3	7.8	6.6	5.8	4.8	5.0		
		MCDBR	5.0	5.2	6.4	8.0	11.6	13.0	12.4	10.3	9.3	7.9	5.8	5.3		
		MCWBR	4.4	4.1	4.5	4.9	6.3	6.6	5.7	5.5	5.4	5.1	4.7	4.6		
		MCDBR	5.1	5.0	5.9	7.5	10.8	11.1	11.1	9.4	8.2	6.6	5.8	5.2		
	5% WB	MCWBR	4.6	4.4	4.3	4.7	6.1	6.1	5.5	5.5	5.1	4.8	4.8	4.7		
(40) Clear-Sky Solar Irradiance	taub		0.217	0.257	0.291	0.324	0.330	0.327	0.341	0.333	0.304	0.283	0.227	0.189		
	taud		2.124	2.237	2.192	2.163	2.269	2.429	2.424	2.439	2.509	2.415	2.158	2.001		
	Ebn at Noon		571	754	834	869	893	904	879	859	831	722	541	434		
	Edh at Noon		39	66	96	121	118	103	101	92	72	56	37	27		
(44) All-Sky Solar Radiation	RadAvg		0.26	0.79	2.07	3.92	4.78	4.80	4.58	3.58	2.27	1.05	0.36	0.17		
	RadStd		0.07	0.22	0.41	0.67	0.83	0.57	0.58	0.32	0.26	0.15	0.06	0.02		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (50 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page