

FILEFJELL, Norway

WMO: 013640

Lat: 61.1778N

Lon: 8.1125E

Elev: 955

StdP: 90.37

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-27.2	-23.8	-29.9	0.3	-27.2	-26.3	0.4	-23.8	14.6	-2.3	12.8	-1.9	1.0	100	0.752

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.2	21.0	12.5	19.2	11.8	17.2	11.0	13.9	18.5	12.9	17.1	12.0	15.8	3.0	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.2	9.9	15.0	11.1	9.2	14.1	10.1	8.6	13.3	42.0	18.5	39.3	17.2	36.6	15.9	17.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.8	9.8	8.4	DB	-28.9	22.8	3.6	1.9	-31.5	24.1	-33.6	25.2	-35.6	26.3	-38.3	27.7	(4)
(5)			WB	-28.0	15.5	4.2	1.2	-31.0	16.4	-33.5	17.2	-35.9	17.8	-39.0	18.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	0.8	-7.7	-7.7	-5.3	-1.1	4.1	8.5	11.3	9.9	6.5	1.3	-4.3	-6.8
	DBStd	8.35	6.62	6.46	5.67	4.18	3.47	2.62	2.97	2.85	2.96	3.58	5.77	6.84
	HDD10.0	3485	548	497	476	333	184	60	21	37	111	270	428	520
	HDD18.3	6411	807	730	734	583	441	296	217	262	357	528	678	778
	CDD10.0	117	0	0	0	0	2	13	62	34	5	1	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	4	0	0	0	0	0	1	3	1	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	3.5	4.1	4.1	4.4	3.5	3.2	3.2	2.9	2.8	3.4	3.5	3.4	3.9
Precipitation	PrecAvg	682	57	49	50	34	37	59	76	82	63	61	60	55
	PrecMax	991	148	104	185	66	98	133	162	165	101	105	147	121
	PrecMin	496	0	0	11	12	5	16	23	23	24	22	9	6
	PrecStd	111	40	30	33	13	20	28	32	30	18	25	34	31
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.8	4.8	5.9	10.3	18.7	20.6	23.5	22.5	17.9	12.5	7.1	5.7
		MCWB	2.0	2.2	2.7	5.0	10.4	10.9	14.2	12.8	11.0	9.0	4.6	3.5
	2%	DB	3.3	3.3	4.2	8.1	15.2	18.1	21.7	20.0	15.2	9.3	5.5	4.2
		MCWB	1.3	1.5	1.8	3.6	8.8	10.1	13.3	12.0	10.1	6.6	3.6	2.4
	5%	DB	2.1	2.0	3.3	6.3	12.8	15.9	20.1	17.8	13.2	7.9	4.2	2.9
		MCWB	0.3	0.0	1.2	2.9	7.3	9.2	12.6	11.4	9.2	5.6	2.5	1.4
	10%	DB	0.6	0.5	2.1	4.9	10.5	14.1	18.2	15.6	11.6	6.5	2.6	1.4
		MCWB	-1.0	-1.1	0.0	2.1	5.9	8.6	11.8	10.8	8.5	4.5	1.1	0.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.6	2.7	3.3	6.1	11.5	12.8	15.7	14.4	12.1	9.4	5.3	3.8
		MCDB	4.3	4.1	5.2	9.5	17.1	17.7	20.8	18.1	15.4	11.8	7.0	5.2
	2%	WB	1.6	1.6	2.2	4.2	9.3	11.5	14.5	13.2	10.9	7.2	3.9	2.6
		MCDB	3.1	3.2	4.0	7.0	14.1	15.1	19.6	17.3	14.1	8.9	5.3	4.0
	5%	WB	0.4	0.2	1.3	3.2	7.9	10.4	13.6	12.3	10.0	5.9	2.7	1.4
		MCDB	2.0	1.8	3.1	5.7	11.6	14.2	18.1	16.2	12.4	7.5	4.1	2.7
	10%	WB	-0.9	-1.1	0.1	2.4	6.5	9.4	12.7	11.4	9.0	4.6	1.2	0.1
		MCDB	0.5	0.5	1.9	4.8	9.9	13.0	16.8	14.9	11.1	6.3	2.4	1.3
Mean Daily Temperature Range	5% DB	MDBR	6.5	7.1	7.8	8.0	8.1	8.7	9.2	8.7	7.1	5.7	6.0	6.5
		MCDBR	6.3	5.6	6.6	9.4	13.5	13.5	14.2	12.6	11.6	8.2	6.4	5.7
		MCWBR	5.5	4.9	5.1	6.0	7.9	7.0	7.0	6.0	7.2	6.1	5.4	5.0
	5% WB	MCDBR	6.1	6.0	6.2	8.5	12.1	10.3	11.7	10.0	9.2	6.3	6.3	5.7
		MCWBR	5.6	5.4	5.1	5.6	7.6	6.3	6.6	5.7	6.3	5.1	5.4	5.1
Clear-Sky Solar Irradiance	taub	0.197	0.241	0.272	0.302	0.309	0.309	0.322	0.314	0.285	0.264	0.206	0.166	
	taud	2.123	2.264	2.240	2.224	2.304	2.457	2.470	2.481	2.546	2.425	2.145	1.974	
	Ebn at Noon	579	772	856	891	913	920	898	878	851	738	549	432	
	Edh at Noon	35	61	90	112	113	99	96	87	68	53	34	24	
All-Sky Solar Radiation	RadAvg	0.27	0.88	2.27	4.04	4.89	5.00	4.64	3.60	2.29	1.06	0.35	0.16	
	RadStd	0.05	0.20	0.31	0.55	0.61	0.51	0.54	0.31	0.27	0.16	0.06	0.02	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (55 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page